

Project No.: R.068558.001

August 25, 2014

The following changes to the tender documents are effective immediately and will form part of the contract documents:

1. Changes to Drawings:

1.1 Refer to Drawing E01 ELECTRICAL - SITE PLAN CONDUITS LAYOUT

1.1.1 Change 53 to 63ø in note directed to building B8 conduit runs and revise note to read: NEW 63 DIAMETER CONDUIT UP TO MECHANICAL/ELECTRICAL ROOM. SEE DRAWING E04.

1.1.2 Insert 63ø after 53ø in note directed to building B8 conduit runs. Revise note to read: NEW AND EXISTING 53ø AND 63ø Conduits DOWN TO CRAWL SPACE; SEE DRAWINGS E04.

1.2 Refer to Drawing E02 ELECTRICAL - ADMINISTRATION BUILDING A1 PLAN – CONDUITS LAYOUT, POWER, AND DETAILS

1.2.1 Floor Plan 1/E02: Change to 53ø conduit from 63ø for the conduit run between room B11 and through/pull box in B08.

1.3 Refer to Drawing E04 ELECTRICAL - MULTI-PURPOSE BUILDING B8-UNIT5 TUNNEL, CRAWLSPACE, AND SECOND FLOOR PLANS -CONDUITS LAYOUT

1.3.1 All new conduits in Multipurpose Building B8/Unit 5 to be 63ø.

END OF ADDENDUM NO. 1