



## Addendum 3

**Project Title:** Roof Replacement  
Building 20  
Central Experimental Farm (CEF), Ottawa (Ontario)

**Solicitation No:** 14-1109

August 26, 2014

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents

---

### Q & A

**Q6. What does the curb detail for HVAC units show? Up and over the membrane?**

A6. Units are to remain in place and membrane is to be terminated under existing metal flashing.

**Q7. The duct covering that is to be removed, was an ACM completed for this material?**

A7. A Designated Substance Report will be provided by the CEF. However, it is unknown if the report addresses duct covering or if it is included in the report. Since there is no confirmation of Asbestos in duct covering, Bidders are to assume that none is present.

**Q8. What type of insulation is required for the ductwork?**

A8. The insulation type for the ductwork is specified at Section 23 07 13 "Duct Insulation". Note that this Section was added to the specifications in Addendum 2.

**Q9. What type of self-adhering membrane is required?**

A9. The self-adhering membrane type is specified at Section 23 07 13 "Duct Insulation". Note that this Section was added to the specifications in Addendum 2.

### INVITATION TO TENDER

**1. At the cover page "Invitation to Tender", Solicitation Closes:**

**Delete:** Friday August 29

**Replace with:** Thursday September 4

**ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME**