



**RETOURNER LES SOUMISSIONS Á:
RETURN BIDS TO:**

**Parks Canada Agency
Procurement Department
3 Passage du Chien-d'Or, Room 200
Québec (QC) G1R 3Z8**

AMENDMENT # 1

**DEMANDE DE PRIX
REQUEST FOR QUOTATION**

Prix à : l'Agence Parcs Canada
Nous offrons par la présente de vendre à sa Majesté la Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les articles et les services énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Quotations to: Parks Canada Agency
We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred or attached hereto, the supplies and services listed herein or on any attached sheets at the price(s) set out therefore.

**Raison sociale et adresse du
fournisseur/de l'entrepreneur
Vendor/Firm Name and Address**

Sujet - Title :	
Beaver Glen Campground Electrical Expansion Prince Albert National Park	
No. de l'invitation - Solicitation No. 5P412-14-0663/A	Date September 2, 2014
No de reference de SEAG -GETS Reference No.	
No. de référence du client - Client Reference No. -	
L'invitation prend fin - Solicitation Closes	Fuseau horaire - Time Zone
à - at 02:00 PM le - on SEPTEMBER 10, 2014	Eastern Daylight Time (EDT)
Adresser toute demande de renseignements à : - Address Inquiries to:	
Marilyn Bernier	
No de téléphone - Telephone No.	No de FAX: - Fax No.
(418) 648-4569	(418) 648-5392
Destinations des biens, services et construction: Destination of Goods, Services, and Construction:	
Raison sociale et adresse du fournisseur/de l'entrepreneur : Vendor/Firm Name and Address	
No de téléphone: - Telephone No. N° de télécopieur: - Facsimile No.	
Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) Name and title of person authorized to sign on behalf of the Vendor/Firm (type or print)	
_____	_____
Nom / Name	Titre /Title
_____	_____
Signature	Date



MODIFICATION DE SOUMISSION **No.1** AMENDMENT TO TENDER

Dossier No – File No 5P412-14-0663/A
Date limite au plus tard - Closing Date on or before Wednesday, September 10, 2014 at 2 o'clock (EDT)
Date d'émission – Date of issue September 2, 2014

Projet - Project Beaver Glen Campground Electrical Expansion Prince Albert National Park

OBJET DE LA PRÉSENTE MODIFICATION – THE PURPOSE OF THIS AMENDMENT IS TO GIVE EFFECT TO THE FOLLOWING

REMINDER : TENDER CLOSE IS 2PM EASTERN TIME WHICH IS 12:00 CST (NOON) LOCAL TIME.

ADDENDUM:

Spec Section 26 24 17,2.2.8: Add ACE Manufacturing to the list of acceptable manufacturers.

Drawing 20134373-00-601: On loop N the line should be removed between N9 and N10 and added between N1 and N2. This change will then match the diagram for Panel O.

QUESTIONS & ANSWERS

1) Review Tree Removal procedures

- Small brush to ground level and chipped onto the trench area. 125 mm or larger can be cut to 300 mm height
- Spruce trees larger than 125 mm can be used for firewood and hauled to Beartrap Area which is 5 kms from the campground.
- Black Poplar can be hauled to "Staging Area" 1 km from the campground

2) Is there provision for tying into existing panels
Yes please review drawings and follow as per drawings

3) Are there sewer lines and other underground utilities in the area.
There are underground utilities in the area as well as steel culverts fo drainage. Parks Canada utilities will be marke dby Parks Canada. Sask Power and telephone utilities can be notified through "Sask First" and located.

4) Underground utilities that are damaged by the contractor will be the contractors responsibility unless an error by Parks Canada Staff occurred that did not locate the utility properly. Utilities that were not marked on request will be at Parks Canada cost.

5) What type of Electric Breakers are there
The existing breakers are bolt-in type Federal Pioneer and Cutler Hammer.

6) How many new Panels?
All loops are into existing panels except Loop K and Loops A-B.

7) What are largest sized wire

Largest wire is #500 but mainly #350.

8) Are there specific tree removal companies that Parks Canada Agency wants for brush and tree removal?

No

9) If the contractor has to "de-water" or pump water how is that cost going to be covered.

Currently no "de-watering" is expected, if work gets delayed until spring, "de-watering" required after June 1 will be reimbursed.

10) How soon can contractors start to work

As soon as contract is signed, insurance and bonding is in place.

TOUTES LES AUTRES CONDITIONS INCLUSES DANS LES INSTRUCTIONS DE TRAVAIL DEMEURENT LES MÊMES / ALL OTHER CONDITIONS INCLUDED IN THE WORK INSTRUCTIONS REMAIN THE SAME.

Par la présente nous reconnaissons avoir reçu la version modifiée des instructions et nous attestons avoir modifié notre soumission en conséquence.

We hereby acknowledge receipt of the amendment instructions and confirm that provisions therefore have been made in our tender.

Pour être prise en considération, toute soumission devra être accompagnée d'un exemplaire signé de la présente modification. Si votre soumission a déjà été envoyée, veuillez signer et envoyer cette modification par télécopieur/courriel avec toutes révisions faites à votre prix de soumission, à nos bureaux avant la date limite. Télécopieur: 418-648-5392

Signed copy of this amendment must accompany each tender in order that the tender be considered. If your submission has already been sent, please sign and send this amendment by fax / email with any revisions made to your bid price, at our office before the deadline. Fax: 418-648-5392.

Signé - Signed	Titre - Title	Date
Société - Company		