



# NOTES

1. Bedding to be taken to a minimum of 300 mm above culvert.
2. Pipe bed to be carefully shaped to receive lowest segment of pipe to a depth equal to 10% of pipe diameter.
3. Compaction of bedding material – ~~95%~~ <sup>100%</sup> in 150mm layers.
4. Bedding material to be as specified in the Contract.
5. Depth of bedding material below culvert will be D/10 or a minimum compacted thickness of 200mm.

Note: Granular Cover Over Culvert 300mm Minimum

<div> <div> <div></div> <div>Public Works and Government Services Canada</div> </div> <div> <div></div> <div>Travaux publics et Services gouvernementaux Canada</div> </div> </div> <div> <div>Architectural and Engineering Services for Parks Canada</div> <div>Services d'architecture et de génie pour Parcs Canada</div> </div>		<div> <div>TITLE/TITRE</div> <div>INSTALLATION OF PIPE AND PIPE ARCHES</div> </div>	
<div> <div>DRAWN BY/DESSINE PAR</div> <div>BS</div> </div>		<div> <div>DATE</div> <div>APRIL/96</div> </div>	
<div> <div>CHECKED BY/VERIFIE PAR</div> <div>BS</div> </div>		<div> <div>REFERENCE No./No. DE REFERENCE</div> <div>1301</div> </div>	