

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Public Works Government Services Canada- Bid**  
**Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 405**  
**Saint John**  
**New Brunswick**  
**E2L 2B9**

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
**Public Works Government Services Canada- Bid**  
**Receiving / Réception des soumissions**  
**189 Prince William Street**  
**Room 405**  
**Saint John**  
**New Bruns**  
**E2L 2B9**

<b>Title - Sujet</b> ESDC Woodstock Refit	
<b>Solicitation No. - N° de l'invitation</b> EC015-150830/A	<b>Amendment No. - N° modif.</b> 006
<b>Client Reference No. - N° de référence du client</b> EC015-150830	<b>Date</b> 2014-09-10
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWB-020-3460	
<b>File No. - N° de dossier</b> PWB-4-37052 (020)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2014-09-16</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Atlantic Daylight Saving Time ADT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Donovan, Janine PWB	<b>Buyer Id - Id de l'acheteur</b> pwb020
<b>Telephone No. - N° de téléphone</b> (506) 636-5347 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

This Tender Amendment No. Six (6) is raised to include the following Addendum No. Six (6).

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

**All other terms and conditions remain the same.**

Addendum No. 6

## **1. QUESTIONS AND ANSWERS**

Q22. On drawing A1 - Room 016 - Note reads: Blocking required for white board and project screen. Are the white board and projection screen in this contract? If so, please provide specification.

A22. On drawing A1, Basement Level Construction Plan, the note for the wall between rooms #014 and #016 should have read "Blocking required for white board & project screen. White board & projection screen to be supplied by others." In other words, The Contractor is only responsible for the supply of the blocking.

Q23. On drawing E4, on the existing conduit & cable tray layout diagram, at the site visit, I looked and did not see the existing cable tray shown on the diagram of the 4" conduits.

A23. It is the Contractor's responsibility to determine the routing of existing conduits from the new ESDC space to the existing telephone backboard located in the basement electrical room. The Contractor shall supply and install conduit(s) (c/w pull string) from the new Telecommunication Room to the existing telephone backboard location. Coordinate with Shared Services Canada the number and size of conduits required. The Contractor shall also coordinate with Shared Services Canada any requirements to provide conduits (if needed) between the basement and the 2nd floor Communications Room.

## **2. SOLICITATION AMENDMENT NO. 5**

In Solicitation Amendment No. 5, **REMOVE** A2 and **REPLACE WITH** the following:

On drawing A6, Door Schedule, the cylindrical column should have been checked instead of the non-cylindrical column for doors #014a and #016a. In other words, all classroom function hardware is to be cylindrical function locks.