

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet ESDC Woodstock Refit	
Solicitation No. - N° de l'invitation EC015-150830/A	Amendment No. - N° modif. 007
Client Reference No. - N° de référence du client EC015-150830	Date 2014-09-11
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3460	
File No. - N° de dossier PWB-4-37052 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-09-16	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Cette modification de l'invitation numéro sept (7) est soumise et comprend la modification numéro sept (7) suivante.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des document de contrat.

Toutes autres conditions ne changent pas.

Addenda no. 7

1. **MODIFICATION DE L'INVITATION NO. 6**

In addition to the answer provided to question #23 contained in Amendment/Addendum #6, please refer to the following work overview provided by Shared Services Canada (SSC). Please keep in mind that this overview is for the Cabling Contractor which is hired by SSC. The General Contractor referenced below would be defined as the Contractor on this project. Consequently, any items below mentioning the General Contractor would apply as well as any work required to complement the Cabling Contractor based on the construction drawings of this project.

1. Supply and installation of new certified Category 6 structured wiring cabling system to accommodate a universal voice and data infrastructure, including all labor and materials required to complete the certified Category 6 cabling system. The Universal system will be referred to as Communication cables.
2. Install necessary demarcation extension, 50 cable pairs and cross connects from the Building Entrance/Demarc point to the new Basement Telecommunications Room, to allow the voice infrastructure to be patched from the Telco's IDC demarcation point through to the Category 6 structured wiring system.
3. Provide a horizontal telecommunication support infrastructure pathway system (cable tray to be installed by General Contractor, necessary J-hooks to be installed by GMCS Bell Contractor).
4. Set up one Telecommunications wiring closet on the basement level to be referred to as Telecommunications Room.
5. Supply and install one equipment rack and required number of patch panels, cable management, shelves and patch cables in the Telecommunications Room.
6. Supply and install 2 (two) 100mm, continuous EMT backbone conduits from the Building Entrance Facility, or the main Telecommunications Equipment Room, through to the Basement Telecommunications Room, C/W end bushings and pull cords for copper and fibre backbone. Fibre will not run in the same conduit as copper.