



Q&A #1

Date: September 16, 2014

Project: Addition of Snow Guards, Sherbrooke, QC

Bidders must make sure that their bids are based on the latest version of the tender documents published and take into consideration the following amendments and information, including any information provided on amendments or Q&As previously published for this project.

Bidders that do not comply with this requirement will be discarded.

Question 1: In the Feeding Area, what is the depth of the roof trusses?

Answer 1: According to the building plans, the roof trusses depth is 75 cm.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED