

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
**Public Works Government Services Canada- Bid
Receiving / Réception des soumissions**
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Springhill Inst. - Solid Waste Mgmt	
Solicitation No. - N° de l'invitation EC016-150235/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client EC016-150235	Date 2014-09-22
GETS Reference No. - N° de référence de SEAG PW-\$PWB-020-3461	
File No. - N° de dossier PWB-4-37053 (020)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-09-30	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Donovan, Janine PWB	Buyer Id - Id de l'acheteur pwb020
Telephone No. - N° de téléphone (506) 636-5347 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Tender Amendment No. Three (3) is raised to include the following Addendum No. Three (3).

The following addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 3.

1. QUESTIONS AND ANSWERS

Q1

Drawing 043944C2 detail temporary chain link shows fence fabric being 37 x 9 ga. specifications for can. spec. call for 50mm x 9 ga.

A1

Use 50mm x 9ga mesh

Q2

Drawing 043944C2, detail note 7. States posts to have polyester coating (black). Galvanized typical.

A2

No polyester coating required.

Q3

Specifications part 2.1.8 calls for 87 mm o.d. gate frames. Drawing detail shows 42mm o.d. (standard).

A3

Use standard gate frame

Q4

Specifications part 2.1.8.3 refers to top & bottom rollers & tracks. No such devices appears in drawings and details.

A4

No rollers or tracks are required.

Q5

Please confirm insulation thickness for the buried district heating lines which delivers 110C hot water

A5

Buried district energy piping specifications including the insulation requirements are provided in Section 23 21 11. Note the underground district energy piping system including, but not limited to, the carrier pipe, insulation and outer jacket, is a complete factory assembled system.

2. APPROVAL OF ALTERNATE MATERIALS

1. **Reference Specification Section 23 05 48 – Vibration Isolation**
 - .1 Section 2.9.4, Add “Mason”
2. **Reference Specification Section 23 33 15 – Dampers Operating**
 - .1 Section 2.1.7.14: Add “Ventex/Alumavent”
3. **Reference Specification Section 23 33 16 – Dampers – Fire & Smoke**
 - .1 Section 2.1.12, Add “Ventex/Alumavent”
4. **Reference Specification Section 23 83 16 – Radiant Heating Hydronic System**
 - .1 Section 2.1.1, Add “Uponor”
 - .2 Section 2.3, Add “F1960 Fittings”
 - .3 Section 2.3.2, Add “Engineered Polymer fittings with F1960 rated connections”
 - .4 Section 2.4.1, Add “Engineered Polymer Manifolds”