

PART 1 GENERAL

1.01 RELATED REQUIREMENTS

- .1 Section 02 41 13 – Selective Site Demolition.
- .2 Section 06 03 40 – Historic - Wood Repair.
- .3 Section 07 92 00 – Joint Sealants.
- .4 Section 08 03 52.71 – Historic - Wood Window Rehabilitation.
- .5 Section 08 03 52.81 – Historic - Wood Window Replacement.
- .6 Section 08 03 80 – Historic - Glazing.
- .7 Section 09 03 91 – Historic - Painting.

1.02 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.

1.03 INSTALLATION AND REMOVAL

- .1 Provide temporary utilities controls in order to execute work expeditiously.
- .2 Remove from site all such work after use.

1.04 WATER SUPPLY

- .1 Departmental Representative will provide continuous supply of potable water for construction use.
- .2 Departmental Representative will pay for utility charges at prevailing rates.

1.05 TEMPORARY HEATING AND VENTILATION

- .1 Provide temporary heating required during construction period, including attendance and maintenance.
- .2 Construction heaters used inside building must be non-flameless type.
- .3 Provide temporary heat and ventilation in enclosed areas as required to:
 - .1 Facilitate progress of Work.
 - .2 Protect Work and products against dampness and cold.
 - .3 Prevent moisture condensation on surfaces.
 - .4 Provide ambient temperatures and humidity levels for storage, installation and curing of materials.
 - .5 Provide adequate ventilation to meet health regulations for safe working environment.
- .4 Maintain temperatures in areas where construction is in progress.
- .5 Ventilating:

- .1 Prevent accumulations of dust, fumes, mists, vapours or gases in areas occupied during construction.
- .2 Provide local exhaust ventilation to prevent harmful accumulation of hazardous substances into atmosphere of occupied areas.
- .3 Dispose of exhaust materials in manner that will not result in harmful exposure to persons.
- .4 Ventilate storage spaces containing hazardous or volatile materials.
- .5 Ventilate temporary sanitary facilities.
- .6 Continue operation of ventilation and exhaust system for time after cessation of work process to assure removal of harmful contaminants.
- .6 Maintain strict supervision of operation of temporary heating and ventilating equipment to:
 - .1 Conform with applicable codes and standards.
 - .2 Enforce safe practices.
 - .3 Prevent abuse of services.
 - .4 Prevent damage to finishes.
 - .5 Vent direct-fired combustion units to outside.
- .7 Be responsible for damage to Work due to failure in providing adequate heat and protection during construction.

1.06 TEMPORARY POWER AND LIGHT

- .1 Departmental Representative to provide and pay for temporary power during construction for temporary lighting and operating of power tools, to a maximum supply of 120 volts 15 amps.
- .2 Provide and maintain temporary lighting throughout project.
- .3 Maximum power supply of 3000 amps, at 12 V, single phase, 60 Hz is available and will be provided for power tools and temporary lighting at no cost. Connect to existing power supply in accordance with Canadian Electrical Code.
- .4 Electrical power and lighting systems installed under this Contract may be used for construction requirements only with prior approval of Departmental Representative provided that guarantees are not affected. Make good damage to electrical system caused by use under this Contract. Replace lamps which have been used for more than 3 months.

1.07 FIRE PROTECTION

- .1 Provide and maintain temporary fire protection equipment during performance of Work required by governing codes, regulations and bylaws.
- .2 Burning rubbish and construction waste materials is not permitted on site.

PART 2 PRODUCTS

2.01 NOT USED

- .1 Not Used.

PART 3 EXECUTION

3.01 NOT USED

.1 Not Used.

END OF SECTION