

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet 3rd Floor Retrofit and Fit-Up	
Solicitation No. - N° de l'invitation EZ899-150716/A	Amendment No. - N° modif. 009
Client Reference No. - N° de référence du client	Date 2014-09-26
GETS Reference No. - N° de référence de SEAG PW-\$PWY-004-7305	
File No. - N° de dossier PWY-4-37094 (004)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-10-02	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Mestry, Ruth (PWY)	Buyer Id - Id de l'acheteur pwy004
Telephone No. - N° de téléphone (604) 775-9385 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC - Harry Stevens Building, Vancouver, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EZ899-150716/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

009

File No. - N° du dossier

PWY-4-37094

Buyer ID - Id de l'acheteur

pw004

CCC No./N° CCC - FMS No/ N° VME

Please find addendum #4 attached, all other terms and conditions remain unchanged.

Date: September 26, 2014

The following changes/clarifications in the tender documents are effective immediately. This Addendum will form part of the Contract documents.

For direct answers to bidders' direct questions, see section 3.0 of this Addendum 2.

1.0 SPECIFICATIONS

1.1 Reference Addendum 2 and Sections 02 82 00.02 and 02 82 00.03 Asbestos Abatement:

- .1 CLARIFICATION: The asbestos abatement work is in Addendum 2 Section 02 82 00.02 Asbestos Abatement – Intermediate Precautions, dated September 11, 2014. Therefore, DELETE original bid-issued Sections 02 82 00.02 and 02 82 00.03
- .2 CLARIFICATION re Section 02 82 00.02, item 1.1.1.4.1: The existing HVAC ductwork will receive seven (7) capped-off locations and fifteen (15) new connection locations.
- .3 In item 3.3 Air Monitoring .1 & .4, DELETE “Departmental Representative”. ADD “Contractor”. Contractor to include for air monitoring cost, and report results daily for Owner’s use in informing staff.

1.2 Reference Addendum 2 item 2.1 re Drawing P101-TI:

- .1 ADD: Where Parkade sprinkler heads are to be replaced and sprinkler lines to be seismically restrained, reinstate disturbed sprayed thermal insulation where seismic brackets will connect to the concrete structure.
- .2 CLARIFICATION: Pressure test shall be provided in compliance with NFPA13 for all wet and dry sprinkler systems as per mechanical drawings.

1.3 Reference Addendum 2 item 2.3 and drawing E200-TI:

- .1 CLARIFICATION: the twenty-five (25) boxed fluorescent fixtures presently stored in the 3rd floor west space are for use in this contract.

1.4 Reference Section 27 10 05 Structured Cabling for Communication Systems:

- .1 REVISE item 1.1.3 to read as follows. “The structured cabling (SC) works for this project shall be done by Bell Canada and will be paid by the Departmental Representative. However, this contractor shall coordinate with Bell Canada and cover all insurances, safety, etc., as if the SC contract is a sub-contract of this contract.”
- .2 DELETE item 1.7 Approvals

2.0 **DRAWINGS**

2.1 Reference Drawing E300-TI, - at 3rd floor west exit doors:

- .1 CLARIFICATION: At the three (3) exit doors, electronic hardware components such as card readers are existing-to-remain except: Provide two (2) keypads in this contract as indicated (identified by asterisk on the drawing).

3.0 **Direct Answers to Bidders' Direct Questions:**

Misc. Questions #7	Replies
<i>7.1 In the architectural specifications it outlines painting of multiple substrates including concrete, clay masonry and asphalt. Are these general instructions and do they not apply to this project?</i>	7.1 Concrete, clay masonry and asphalt do not apply to this project.
<i>7.2 Do we have to texture the exterior walls and will there be a crew to do asbestos abatement and remove wall anchors etc from these walls?</i>	7.2 Plastered surfaces are to be patched, not wall re-textured. Asbestos abatement and patching is included in Addendum 2, Section 02 82 00.02, dated September 11, 2014.
<i>7.3 Is there touch up paint on flashing?</i>	7.3 No.
<i>7.4 Is company Action Data Ltd identified as Structured Cabling and Communications System Contractor by the Department Representative?</i>	7.4 No. See item 1.4 above re Bell Canada.
<i>7.5 Is company BMS Integrated Services identified as Access Control System Contractor by the Department Representative?</i>	7.5 No. Owner has identified Fusion Security Inc. as Access Control System Contractor.

End of Addendum No. 4