



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

INVITATION TO TENDER

APPEL D'OFFRES

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Historic Buildings Roofing Fort Walsh National Historic Site		
Solicitation No. - No. de l'invitation 5P420-14-5113/A		Date: September 26, 2014
GETS Reference No. - No de reference de SEAG PW-14-00651735		Amendment No. - N° de la modif. 003
Solicitation Closes:		
at - à 02:00 PM	on - le September 30, 2014	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/>	Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à : Nathaniel Pahl		
Telephone No. - No de téléphone (403) 292-4572		Fax No. - No de FAX: (403) 292-4475
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein - Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

Amendment 3

This amendment is issued to answer a question asked by a bidder.

- Q1.** The cedar shingles you have on site do not match you specification 01 11 00 1.02. You have a standard #2 grade red cedar shingles not fire rated. Your specification asks for the supply and install new fire retardant-treated western red cedar shingles, cedar shake and shingle bureau (CSSB) Certi-Guard #1 Grade, length to match stored cedar shingles.
- A1.** Yes, bidders are to supply and install new fire retardant-treated western red cedar shingles, cedar shake and shingle bureau (CSSB) Certi-Guard #1 Grade, length to match stored cedar shingles. The specs only reference that the new shingles match the stored shingles in length. The length we require is 18".

All other terms and conditions remain unchanged.