

PART 1 - GENERAL

1.1 SECTION INCLUDES .1 Materials and installation for connectors and terminations.

1.2 REFERENCES .1 Canadian Standards Association (CSA International)
.1 CSA C22.2 No. 174-M1984 (R2003), Cables and Cable Glands for Use in Hazardous Locations.
.2 CSA C22.2 No.41-M1987(R1999), Grounding and Bonding Equipment.

1.3 PRODUCT DATA .1 Submit product data.

PART 2 - PRODUCTS

2.1 CONNECTORS AND TERMINATIONS .1 Install CSA approved cable glands and conduit seals for use in hazardous locations as indicated on the drawings.

PART 3 - EXECUTION

3.1 INSTALLATION .1 Bond and ground as required to CSA C22.2 No.41.
.2 Install epoxy coating on all bonding terminations for corrosion prevention.