

PART 1 - GENERAL

1.1 ACTION AND
INFORMATIONAL
SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets and include product characteristics, performance criteria, physical size, finish and limitations.

1.2 CLOSEOUT
SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
 - .2 Operation and Maintenance Data: submit operation and maintenance data for incorporation into manual.
 - .1 Operation and maintenance manual approved by, and final copies deposited with, Departmental Representative before final inspection.
 - .2 Operation data to include:
 - .1 Control schematics for systems including environmental controls.
 - .2 Description of systems and their controls.
 - .3 Description of operation of systems at various loads together with reset schedules and seasonal variances.
 - .4 Operation instruction for systems and component.
 - .5 Description of actions to be taken in event of equipment failure.
 - .6 Valves schedule and flow diagram.
 - .7 Colour coding chart.
 - .3 Maintenance data to include:
 - .1 Servicing, maintenance, operation and trouble-shooting instructions for each item of equipment.
 - .2 Data to include schedules of tasks, frequency, tools required and task time.
 - .4 Performance data to include:
 - .1 Equipment manufacturer's performance datasheets with point of operation as left after commissioning is complete.
 - .2 Equipment performance verification test results.
-

1.2 CLOSEOUT
SUBMITTALS
(Cont'd)

- .2 Operation and Maintenance Data: (Cont'd)
 - .4 Performance data to include: (Cont'd)
 - .3 Special performance data as specified.
 - .5 Approvals:
 - .1 Submit 2 copies of draft Operation and Maintenance Manual to Departmental Representative for approval. Submission of individual data will not be accepted unless directed by Departmental Representative.
 - .2 Make changes as required and re-submit as directed by Departmental Representative.
 - .6 Additional data:
 - .1 Prepare and insert into operation and maintenance manual additional data when need for it becomes apparent during specified demonstrations and instructions.
 - .7 Site records:
 - .1 Departmental Representative will provide 1 set of reproducible mechanical drawings. Provide sets of white prints as required for each phase of work. Mark changes as work progresses and as changes occur. Include changes to existing mechanical systems, control systems and low voltage control wiring.
 - .2 Transfer information to reproducibles, revising reproducibles to show work as actually installed.
 - .3 Use different colour waterproof ink for each service.
 - .4 Make available for reference purposes and inspection.
 - .8 As-Built drawings:
 - .1 Prior to start of Testing, Adjusting and Balancing for HVAC, finalize production of as-built drawings.
 - .2 Identify each drawing in lower right hand corner in letters at least 12 mm high as follows: "AS BUILT DRAWINGS: THIS DRAWING HAS BEEN REVISED TO SHOW MECHANICAL SYSTEMS AS INSTALLED" (Signature of Contractor) (Date).
 - .3 Submit to Departmental Representative for approval and make corrections as directed.
 - .4 Perform testing, adjusting and balancing for HVAC using as-built drawings.

- | | |
|---|---|
| <u>1.2 CLOSEOUT
SUBMITTALS
(Cont'd)</u> | <ul style="list-style-type: none">.2 Operation and Maintenance Data: (Cont'd)<ul style="list-style-type: none">.8 As-Built drawings: (Cont'd)<ul style="list-style-type: none">.5 Submit completed reproducible as-built drawings with Operating and Maintenance Manuals..9 Submit copies of as-built drawings for inclusion in final TAB report. |
| <u>1.3 MAINTENANCE
MATERIAL SUBMITTALS</u> | <ul style="list-style-type: none">.1 Submit in accordance with Section 01 78 00 - Closeout Submittals..2 Furnish spare parts as follows:<ul style="list-style-type: none">.1 One set of packing for each pump..2 One casing joint gasket for each size pump..3 One head gasket set for each heat exchanger..4 One glass for each gauge glass..5 One filter cartridge or set of filter media for each filter or filter bank in addition to final operating set..3 Provide one set of special tools required to service equipment as recommended by manufacturers. |
| <u>1.4 DELIVERY,
STORAGE AND
HANDLING</u> | <ul style="list-style-type: none">.1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions..2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address..3 Storage and Handling Requirements:<ul style="list-style-type: none">.1 Store materials off ground indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area..2 Store and protect products from nicks, scratches, and blemishes..3 Replace defective or damaged materials with new. |
-

PART 2 - PRODUCTS

PART 3 - EXECUTION

- 3.1 EXAMINATION .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for installation in accordance with manufacturer's written instructions.
.1 Visually inspect substrate.
.2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
.3 Proceed with installation only after unacceptable conditions have been remedied.
- 3.2 PAINTING .1 Do painting in accordance with Section
REPAIRS AND 09 91 23 - Interior Painting.
RESTORATION .2 Prime and touch up marred finished paintwork to match original.
.3 Restore to new condition, finishes which have been damaged.
- 3.3 SYSTEM CLEANING .1 Clean interior and exterior of all systems including strainers. Vacuum interior of ductwork and air handling units.
- 3.4 DEMONSTRATION .1 Departmental Representative will use equipment and systems for test purposes prior to acceptance. Supply labour, material, and instruments required for testing.
.2 Supply tools, equipment and personnel to demonstrate and instruct operating and maintenance personnel in operating, controlling, adjusting, trouble-shooting and servicing of all systems and equipment during regular work hours, prior to acceptance.
.3 Use operation and maintenance manual, as-built drawings, and audio visual aids as part of instruction materials.
-

- .4 Instruction duration time requirements as appropriate for systems being used.
- .5 Departmental Representative may record these demonstrations on video tape for future reference.

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

- .1 Protect equipment and systems openings from dirt, dust, and other foreign materials with materials appropriate to system.