

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Bowden Dedicated Annex Rd	
Solicitation No. - N° de l'invitation EW038-151025/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client PWGSC-EW038-151025	Date 2014-10-01
GETS Reference No. - N° de référence de SEAG PW-\$PWU-009-10257	
File No. - N° de dossier PWU-4-37124 (009)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-10-06	Time Zone Fuseau horaire Mountain Daylight Saving Time MDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Bogus (RPC), Katherine	Buyer Id - Id de l'acheteur pwu009
Telephone No. - N° de téléphone (780) 497-3547 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EW038-151025/A

Client Ref. No. - N° de réf. du client

PWGSC-EW038-151025

Amd. No. - N° de la modif.

006

File No. - N° du dossier

PWU-4-37124

Buyer ID - Id de l'acheteur

pwu009

CCC No./N° CCC - FMS No/ N° VME

Public Works and Government
Services Canada
Real Property Contracting

Project Name: Dedicated Annex Road, Bowden Institution, Bowden, Alberta
Project Number: R.064418.001
Date: October 1, 2014

This addendum forms part of the tender documents and modifies them as here-in stated. The following sections of the drawings and specifications have been modified.

Question:

"Will you confirm that the electrical conduit note is correct. It calls for HDPE conduit from the admin building to the gate and PVC conduit under the road. We think that this is an error and it should be the reverse. HDPE under the road and PVC for the rest."

Answer:

-HDPE conduit was specified with the intent to reduce cable pulling effort (through smooth wall, joint-less conduit) and to make field installation of the conduit quicker (as the conduit is continuous length from a reel of material).

-All conduit under road crossings shall be PVC DB2-type conduit as specified. This is a common practice for installation of shallow utilities.