



Addendum 1

Project Title: Brick Replacement to Exterior Façades
Building 50
Central Experimental Farm (CEF), Ottawa (Ontario)

Solicitation No: 14-1191

October 3, 2014

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents

Q & A

Q1. Elevations show this building to be a cavity wall type setup with inner wall being concrete block, insulation and brick on the veneer. The infill for the doors is to be brick. Would it make more sense to infill with concrete block in order to match existing?

A1. The infill for the door openings have already been boarded up using steel studs and mineral wool insulation. Only the exterior cavity shall be clad with brick veneer.

Q2. Also, should there be insulation and vapour barrier at the infill doors to match existing?

A2. Insulation and vapour barriers already exist. They have been installed during the previous demolition project using steel studs and mineral wool insulation.

Q3. Are the brick replacement and repointing repairs located in one area or all around the building?

A3. All brick replacements and repointing repairs are located within the extent of work area noted on Drawing A300.

INVITATION TO TENDER

1. **At Cover Page (Page 1):**

Delete: Monday October 6

Replace with: Thursday October 9

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME