



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

**Parks Canada Agency
P.O. Box 220
Mckay Compound, Stores Building
6300 Highway 93S
Radium, BC V0A 1M0**

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same

Ce document est par la présente revise; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Lake Louise, Yoho, Kootenay Field Unit
P.O. Box 220
Radium, BC V0A 1M0

Title-Sujet Supply & Install Windows at #202 Saddleback in Lake Louise, AB		Date October 02, 2014
Solicitation No. - No. de l'invitation 5P424-14-0229/A	Amendment No. - No modif. 002	
GETS Reference No. - No de reference de SEAG N/A		
Solicitation Closes L'invitation prend fin - at - á 02:00 PM on - le October 07, 2014		Time Zone Fuseau horaire - Mountain Daylight Saving Time (HAR)
F.O.B. - F.A.B.		
Address Inquiries to: - Adresser toute demande de renseignements à :		
Eloise Meredith		eloise.meredith@pc.gc.ca
Telephone No. - No de téléphone (250) 347-6622	Fax No. - No de FAX: (250) 347-6621	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Lake Louise, Yoho, Kootenay Field Unit #202 Saddleback Crescent, Lake Louise, AB		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur		
Signature		Date

This amendment is raised to answer questions and correct the Specifications.

Questions

Question 1. Who has the responsibility of moving furniture and removing and reinstalling blinds or any other window accessories?

Contractor will be responsible for moving furniture and removing / reinstalling window accessories.

Question 2. Must we include an amount in our tender for landscape repair if anything gets damaged during the work?

Contractor will be responsible for repairing any damage to landscaping they cause.

Question 3. Is there provided space where we will be able to set up containers, a construction trailer, toilet, equipment and other material?

Yes.

Question 4. Do we want to change the window color to brown outside and white inside to match existing windows?

No.

Question 5. Insulating around nail-in flange style windows will be difficult. Can box only inserts be used instead of nail-in flange style windows?

No box only inserts are not acceptable. Nail in flange style windows are to be used.

Question 6. Do we do the same exterior finishing for both the buildings with vertical beige siding as well as the building with bleu cedar shingles?

Yes

Question 7. What is the wall thickness (jamb ext.)?

Nail-in flange style windows are to be used so jam extensions are not required and minimal interior trim replacement is to be done other than sealing. (See ITT amendment #1)

Question 8. For the exterior finishing do we install smartboard and drip cap?

Drip cap is to be installed and primed/painted cedar casing is to be used for exterior finishing. (See ITT amendment #1)

Question 9. In the specifications on page 9/12 section PVC windows there is a mention of brickmould, is this required?

The SOW has been amended to change the window style to nail-in flange without brickmould. (see ITT amendment #1)

Question 10. Must we remove the laminate window sill shelving and install new ones? If so, we will need the depth dimensions of these.

Interior sills do not need to be removed. The SOW has been amended to change the window style to nail-in flange without brickmould. (see ITT amendment #1)

Question 11. In the specs it is mentioned that there will be drywall and paint touch ups, do we consider the window jamb only or wall surfaces as well?

Disturbance of interior walls will be minimal when nail-in flange style windows are installed. However repair of interior walls and window jam damage caused by contractor is required. (see ITT amendment #1)

Amend Specifications

REMOVE

2.02 MATERIALS

PVC Windows:

Frame: PVC Profiles;

Sash: PVC Profiles

Screen: Fiberglass wire mesh on a Aluminum Frame

Opening Devices: Sliders and awnings as per Manufactures Standards

Including: End Strips, Chairs, Anchors, Splice, locking latch

Color: Beige frame with beige brickmold

New windows to be nail-in flange style with no brickmould

Exterior caulking, exterior commercial grade, color to match exterior color

Interior caulking, interior commercial grade, conceal sealant within units.

REPLACE WITH

2.02 MATERIALS

PVC Windows:

Frame: PVC Profiles;

Sash: PVC Profiles

Screen: Fiberglass wire mesh on a Aluminum Frame

Opening Devices: Sliders and awnings as per Manufactures Standards

Including: End Strips, Chairs, Anchors, Splice, locking latch

Color: Beige

New windows to be nail-in flange style with no brickmould

Exterior caulking, exterior commercial grade, color to match exterior color

Interior caulking, interior commercial grade, conceal sealant within units.

All other terms and conditions remain the same.