

PART 1 - GENERAL

1.1 SUMMARY

- .1 Section Includes:
 - .1 General requirements that are common to NMS sections found in Division 26 - Electrical, & 28 - Electronic Safety and Security.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA)
 - .1 CSA C22.1-2012, Canadian Electrical Code, Part 1 (21st Edition), Safety Standard for Electrical Installations.
 - .2 CAN3-C235-83(R2006), Preferred Voltage Levels for AC Systems, 0 to 50,000 V.
- .2 Electrical and Electronic Manufacturer's Association of Canada (EEMAC)
 - .1 EEMAC 2Y-1-1958, Light Gray Colour for Indoor Switch Gear.
- .3 Health Canada / Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .4 Authority Having Jurisdiction (AHJ) requirements and local applicable codes and regulations.

1.3 DESIGN REQUIREMENTS

- .1 Operating voltages: to CAN3-C235.
- .2 Motors, electric heating, control and distribution devices and equipment to operate satisfactorily at 60 Hz within normal operating limits established by above standard.
 - .1 Equipment to operate in extreme operating conditions established in above standard without damage to equipment.
- .3 Language operating requirements: provide identification nameplates for control items in English and French.

1.4 SUBMITTALS

- .1 Submittals: in accordance with Section 01 11 01 and 01 33 00.
- .2 Product Data: submit WHMIS MSDS.

- .3 Shop drawings:
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of Saskatchewan within 3 weeks of Award of Contract.
 - .2 Submit copies of 215 x 280 mm minimum size drawings and product data to Consultant.
 - .3 If changes are required, notify Departmental Representative and Consultant of these changes before they are made.
- .4 Quality Control: in accordance with Section 01 11 01 and 01 45 00.
 - .1 Provide CSA certified equipment and material.
 - .2 Where CSA certified equipment and material is not available, submit such equipment and material to AHJ for special approval before delivery to site.
 - .3 Submit test results of installed electrical systems and instrumentation.
 - .4 Permits and fees: in accordance with General Conditions of contract. Pay associated fees. Departmental Representative will provide drawings and specifications required by Electrical Inspection Department and Supply Authority at no cost.
 - .5 Submit, upon completion of Work, load balance report as described in PART 3 - Load Balance.
 - .6 Submit certificate of acceptance from authority having jurisdiction upon completion of Work to Departmental Representative.

1.5 QUALITY ASSURANCE

- .1 Quality Assurance: in accordance with Section 01 11 01 and 01 45 00.
- .2 Qualifications: electrical Work to be carried out by qualified, licensed electricians [who hold valid Electrical Contractor license or apprentices in accordance with authorities having jurisdiction as per the conditions of Provincial Act respecting manpower vocational training and qualification].
 - .1 Employees registered in provincial apprentices program: permitted, under direct supervision of qualified licensed electrician, to perform specific tasks.
 - .2 Permitted activities: determined based on training level attained and demonstration of ability to perform specific duties.
- .3 Site Meetings:
 - .1 In accordance with Section 01 32 17 and Section 01 32 18.
- .4 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 29.06.

<u>1.6 DELIVERY, STORAGE AND HANDLING</u>	.1	Material Delivery Schedule: provide Departmental Representative with schedule within 2 weeks after award of Contract.
	.2	Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 11 01 and 01 74 20.
<u>1.7 SYSTEM STARTUP</u>	.1	Instruct Departmental Representative and Operating personnel in operation, care and maintenance of systems, system equipment and components.
<u>PART 2 - PRODUCTS</u>		
<u>2.1 SUSTAINABLE REQUIREMENTS</u>	.1	If applicable, Materials and products in accordance with Section 01 47 15.
<u>2.2 MATERIALS AND EQUIPMENT</u>	.1	Provide material and equipment in accordance with Section 01 11 01 and 01 61 00.
	.2	Material and equipment to be CSA certified. Where CSA certified material and equipment are not available, obtain special approval from authority having jurisdiction before delivery to site and submit such approval as described in PART 1 - Submittals.
	.3	Factory assemble control panels and component assemblies.
<u>2.3 ELECTRIC MOTORS, EQUIPMENT AND CONTROLS</u>	.1	Verify installation and co-ordination responsibilities related to motors, equipment and controls, as indicated.
	.2	Control wiring and conduit: in accordance with Section 26 29 03 except for conduit, wiring and connections below 50 V which are related to control systems specified in mechanical sections and as shown on mechanical drawings.
<u>2.4 WARNING SIGNS</u>	.1	Warning Signs: in accordance with requirements of authority having jurisdiction, and Departmental Representative.
	.2	Porcelain enamel signs, minimum size 175 x 250 mm.

2.5 WIRING
TERMINATIONS

- .1 Ensure lugs, terminals, screws used for termination of wiring are suitable for either copper or aluminum conductors.

2.6 EQUIPMENT
IDENTIFICATION

- .1 Identify electrical equipment with nameplates and labels as follows:
 - .1 Nameplates: plastic laminate 3mm thick plastic engraving sheet, black face, white core, lettering accurately aligned and engraved into core mechanically attached with self-tapping screws.
 - .2 Sizes as follows:

NAMEPLATE SIZES

Size 1	10 x 50 mm	1 line	3 mm high letters
Size 2	12 x 70 mm	1 line	5 mm high letters
Size 3	12 x 70 mm	2 lines	3 mm high letters
Size 4	20 x 90 mm	1 line	8 mm high letters
Size 5	20 x 90 mm	2 lines	5 mm high letters
Size 6	25 x 100 mm	1 line	12 mm high letters
Size 7	25 x 100 mm	2 lines	6 mm high letters

- .2 Labels: embossed plastic labels with 6 mm high letters unless specified otherwise.
- .3 Wording on nameplates and labels to be approved by Departmental Representative prior to manufacture.
- .4 Allow for minimum of twenty-five (25) letters per nameplate and label.
- .5 Nameplates for terminal cabinets and junction boxes to indicate system and/or voltage characteristics.
- .6 Identify equipment with Size 3 labels as directed by Departmental Representative.
- .7 Disconnects, starters and contactors: indicate equipment being controlled and voltage.
- .8 Terminal cabinets and pull boxes: indicate system and voltage.
- .9 Transformers: indicate capacity, primary and secondary voltages.
- .1 Identify wiring with permanent indelible identifying

2.7 WIRING

IDENTIFICATION

markings, coloured plastic tapes, on both ends of phase conductors of feeders and branch circuit wiring.

- .2 Maintain phase sequence and colour coding throughout.
- .3 Colour coding: to CSA-C22.1.
- .4 Use colour coded wires in communication cables, matched throughout system.

2.8 CONDUIT AND CABLE

IDENTIFICATION

- .1 Colour code conduits, boxes and metallic sheathed cables.
- .2 Code with plastic tape or paint at points where conduit or cable enters wall, ceiling, or floor, and at 15m intervals.
- .3 Colours: 25 mm wide prime colour and 20mm wide auxiliary colour.

	Prime	Auxiliary
up to 250 V	Yellow	
up to 600 V	Yellow	Green
up to 5 kV	Yellow	Blue
up to 15 kV	Yellow	Red
Telephone	Green	
Other	Green	Blue
Communication Systems		
Fire Alarm	Red	
Emergency	Red	Blue
Voice		
Other	Red	Yellow
Security Systems		

2.9 FINISHES

- .1 Shop finish metal enclosure surfaces by application of rust resistant primer inside and outside, and at least two coats of finish enamel.
- .2 Paint indoor switchgear and distribution enclosures light gray to EEMAC 2Y-1.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Do complete installation in accordance with CSA-C22.1 except where specified otherwise.

3.2 NAMEPLATES AND
LABELS

- .1 Ensure manufacturer's nameplates, CSA labels and identification nameplates are visible and legible after equipment is installed.

3.3 CONDUIT AND
CABLE INSTALLATION

- .1 Install conduit and sleeves prior to pouring of concrete.
 - .1 Sleeves through concrete: plastic, sized for free passage of conduit, and protruding 50mm.
- .2 If plastic sleeves are used in fire rated walls or floors, remove before conduit installation.
- .3 Install cables, conduits and fittings to be embedded or plastered over, neatly and close to building structure so furring can be kept to minimum.

3.4 LOCATION OF
OUTLETS

- .1 Locate outlets in accordance with Section 26 05 32.
- .2 Do not install outlets back-to-back in wall; allow minimum 150 mm horizontal clearance between boxes.
- .3 Change location of outlets at no extra cost or credit, providing distance does not exceed 3000mm, and information is given before installation.
- .4 Locate light switches on latch side of doors.
 - .1 Locate disconnect devices in mechanical and elevator machine rooms on latch side of floor.

3.5 MOUNTING
HEIGHTS

- .1 Mounting height of equipment is from finished floor to centreline of equipment unless specified or indicated otherwise.
- .2 If mounting height of equipment is not specified or indicated, verify before proceeding with installation.
- .3 Install electrical equipment at following heights unless indicated otherwise.
 - .1 Local switches: 1400mm, maximum 1200 mm for accessible space.
 - .2 Wall receptacles:
 - .1 General: 300 mm, minimum 400 mm for accessible space.
 - .2 Above top of continuous baseboard heater: 200mm.
 - .3 Above top of counters or counter splash backs: 175mm.
 - .4 In mechanical rooms: 1400mm.
- .3 Panelboards: as required by Code or as indicated.
- .4 Telephone and interphone outlets: 300 mm.

- .5 Wall mounted telephone and interphone outlets for non-accessible locations: 1500mm.
- .6 Fire alarm stations: 150 mm maximum 1200mm for accessible space.
- .7 Fire alarm bells: 2100 mm.

3.6 CO-ORDINATION OF PROTECTIVE DEVICES

- .1 Ensure circuit protective devices such as overcurrent trips, relays and fuses are installed to required values and settings.

3.7 FIELD QUALITY CONTROL

- .1 Load Balance:
 - .1 Measure phase current to panelboards with normal loads (lighting) operating at time of acceptance; adjust branch circuit connections as required to obtain best balance of current between phases and record changes.
 - .2 Measure phase voltages at loads and adjust transformer taps to within 2% of rated voltage of equipment.
 - .3 Provide upon completion of work, load balance report as directed in PART 1 - Submittals: phase and neutral currents on panelboards, dry-core transformers and motor control centres, operating under normal load, as well as hour and date on which each load was measured, and voltage at time of test.
- .2 Conduct following tests in accordance with Section 01 11 01 and 01 45 00:
 - .1 Power distribution system including phasing, voltage, grounding and load balancing.
 - .2 Circuits originating from branch distribution panels.
 - .3 Lighting and its control.
 - .4 Motors, heaters and associated control equipment including sequenced operation of systems where applicable.
 - .5 Systems: fire alarm system, communications.
 - .6 Insulation resistance testing:
 - .1 Megger circuits, feeders and equipment up to 350 V with a 500 V instrument.
 - .2 Megger 350-600 V circuits, feeders and equipment with a 1000 V instrument.
 - .3 Check resistance to ground before energizing.
- .3 Carry out tests in presence of Departmental Representative.

- .4 Provide instruments, meters, equipment and personnel required to conduct tests during and at conclusion of project.

3.8 CLEANING

- .1 Clean and touch up surfaces of shop-painted equipment scratched or marred during shipment or installation, to match original paint.
- .2 Clean and prime exposed non-galvanized hangers, racks and fastenings to prevent rusting.

END OF SECTION

PART 1 - GENERAL

1.1 RELATED REQUIREMENTS

- .1 Not Applicable.

1.2 REFERENCES

- .1 CSA International
 - .1 CAN/CSA-C22.2 No.18-[98(R2003)], Outlet Boxes, Conduit Boxes and Fittings.
 - .2 CAN/CSA-C22.2 No.65-[03(R2008)], Wire Connectors (Tri-National Standard with UL 486A-486B and NMX-J-543-ANCE-03).
- .2 Electrical and Electronic Manufacturers' Association of Canada (EEMAC)
 - .1 EEMAC 1Y-2-[1961], Bushing Stud Connectors and Aluminum Adapters (1200 Ampere Maximum Rating).
- .3 National Electrical Manufacturers Association (NEMA)

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for wire and box connectors and include product characteristics, performance criteria, physical size, finish and limitations.

1.4 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00.
- .2 Operation and Maintenance Data: submit operation and maintenance data for wire and box connectors for incorporation into manual.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.

- .2 Store and protect wire and box connectors from nicks, scratches, and blemishes.
- .3 Replace defective or damaged materials with new.

PART 2 - PRODUCTS

2.1 MATERIALS

- .1 Pressure type wire connectors to: CAN/CSA-C22.2 No.65, with current carrying parts of copper sized to fit conductors as required.
- .2 Fixture type splicing connectors to: CAN/CSA-C22.2 No.65, with current carrying parts of copper sized to fit copper conductors 10 AWG or less.
- .3 Bushing stud connectors: to EEMAC 1Y-2 to consist of:
 - .1 Connector body and stud clamp for round copper conductors.
 - .2 Clamp for round copper conductors.
 - .3 Stud clamp bolts.
 - .4 Bolts for copper conductors.
 - .5 Sized for conductors as indicated.
- .4 Clamps or connectors for armoured cable, TECK cable, flexible conduit, non-metallic sheathed cable as required to: CAN/CSA-C22.2 No.18.

PART 3 - EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for wire and box connectors' installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied.

3.2 INSTALLATION

- .1 Remove insulation carefully from ends of conductors and cables and:
 - .1 Apply coat of zinc joint compound on aluminum conductors prior to installation of connectors.
 - .2 Install mechanical pressure type connectors and tighten screws with appropriate compression tool recommended by manufacturer. Installation shall

meet secureness tests in accordance with
CAN/CSA-C22.2 No.65.

- .3 Install fixture type connectors and tighten to
CAN/CSA-C22.2 No.65. Replace insulating cap.
- .4 Install bushing stud connectors in accordance
with EEMAC 1Y-2.

3.3 CLEANING

- .1 Progress Cleaning: clean in accordance with Section
01 74 11.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus
materials, rubbish, tools and equipment in accordance
with Section 01 74 11.
- .3 Waste Management: separate waste materials for reuse
and recycling in accordance with Section 01 74 20 and
01 35 21.
 - .1 Remove recycling containers and bins from site
and dispose of materials at appropriate
facility.

END OF SECTION

PART 1 - GENERAL

- | | | |
|---|----|---|
| <u>1.1 PRODUCT DATA</u> | .1 | Provide product data in accordance with Section 01 33 00. |
| <u>1.2 DELIVERY, STORAGE AND HANDLING</u> | .1 | Packaging Waste Management: remove for reuse of pallets, crates, paddling, and packaging materials in accordance with Section 01 74 20. |

PART 2 - PRODUCTS

- | | | |
|---------------------------|----|---|
| <u>2.1 BUILDING WIRES</u> | .1 | Conductors: stranded for 10AWG and larger. Minimum size: 12 AWG. |
| | .2 | Copper conductors: size as indicated, with 600 V insulation of cross-linked thermosetting polyethylene material rated RW90 XLPE, RWU90 XLPE, Jacketted as required for application. |
| <u>2.2 TECK 90 CABLE</u> | .1 | Cable: in accordance with Section 26 05 00. |
| | .2 | Conductors: <ul style="list-style-type: none"> .1 Grounding conductor: copper. .2 Circuit conductors: copper. |
| | .3 | Insulation: <ul style="list-style-type: none"> .1 Cross-linked polyethylene XLPE, .2 Rating: , 600V. |
| | .4 | Inner jacket: polyvinyl chloride material. |
| | .5 | Armour: interlocking aluminum. |
| | .6 | Overall covering: thermoplastic polyvinyl chloride, compliant to applicable Building Code classification for this project. |
| | .8 | Connectors: <ul style="list-style-type: none"> .1 Watertight, explosion-proof as need; approved for TECK cable. |

2.3 MINERAL-INSULATED CABLES .1 Not Applicable.

2.4 ARMOURED CABLES .1 Not Applicable.

2.5 ALUMINUM SHEATHED CABLE

.1 Conductors: copper, size as indicated.

.2 Insulation: cross linked polyethylene type RA90 rated 600V.

.3 Sheath: aluminum applied to form continuous corrugated sheath.

.4 Outer jacket: thermoplastic applied over sheath and to be compliant to applicable Building Code classification for this project, wet, and/or corrosive locations.

2.6 CONTROL CABLES

.1 Type: LVT: 2 soft annealed copper conductors, sized as indicated:

.1 Insulation: thermoplastic.

.2 Sheath : thermoplastic jacket, and armour of closely wound aluminum wire.

.2 Type: low energy 300 V control cable: stranded annealed copper conductors sized as indicated LVT: 2 soft annealed copper conductors, sized as indicated:

.1 Insulation: polyethylene.

.2 Shielding: braid over each over conductors.

.3 Overall covering: polyethylene jackets.

.3 Type: 600 V stranded conductors, sizes as indicated:

.1 Insulation: R90, cross-linked polyethylene type.

.2 Shielding: braid over conductors.

.3 Overall covering: PVC.

2.7 NON-METALLIC SHEATHED CABLE .1 Not Applicable.

PART 3 - EXECUTION

<u>3.1 FIELD QUALITY CONTROL</u>	.1	Perform tests in accordance with Section 26 05 00.
	.2	Perform tests using method appropriate to site conditions and to approval of Departmental Representative and local authority having jurisdiction over installation.
	.3	Perform tests before energizing electrical system.
<u>3.2 GENERAL CABLE INSTALLATION</u>	.1	Terminate cables in accordance with Section 26 05 20.
	.2	Cable Colour Coding: to Section 26 05 00.
	.3	Conductor length for parallel feeders to be identical.
	.4	Lace or clip groups of feeder cables at distribution centres, pull boxes, and termination points.
	.5	Wiring in walls: typically drop or loop vertically from above to better facilitate future renovations. Generally wiring from below and horizontal wiring in walls to be avoided unless indicated.
	.6	Branch circuit wiring for surge suppression receptacles and permanently wired computer and electronic equipment to be 2-wire circuits only, i.e. common neutrals not permitted.
	.7	Provide numbered wire collars for control wiring. Numbers to correspond to control shop drawing legend. Obtain wiring diagram for control wiring.
<u>3.3 INSTALLATION OF BUILDING WIRES</u>	.1	Install wiring as follows:
	.1	In conduit systems in accordance with Section 26 05 34.
	.2	In surface and lighting fixture raceways in accordance with Section 26.
	.3	In wireways and auxiliary gutters in accordance with Section 26.
<u>3.4 INSTALLATION OF TECK90 CABLE (0-1000 V)</u>	.1	Group cables wherever possible on channels.
	.2	Install cable exposed in mechanical/electrical/service rooms, concealed elsewhere, securely supported hangers.

<u>3.5 INSTALLATION OF MINERAL-INSULATED CABLES</u>	.1	Not Applicable.
---	----	-----------------

<u>3.6 INSTALLATION OF ARMOURED CABLES</u>	.1	Group cables wherever possible on channels.
--	----	---

<u>3.7 INSTALLATION OF ALUMINUM SHEATHED CABLE</u>	.1	Group cables wherever possible on channels.
--	----	---

<u>3.8 INSTALLATION OF CONTROL CABLES</u>	.1	Install control cables in conduit.
	.2	Ground control cable shield.

<u>3.9 INSTALLATION OF NON-METALLIC SHEATHED CABLE</u>	.1	Not Applicable.
--	----	-----------------

END OF SECTION

PART 1 - GENERAL

1.1 REFERENCES

- .1 CSA International
 - .1 CAN/CSA-B72-M87(R2008), Installation Code for Lightning Protection Systems.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00.
- .2 Shop Drawings:
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of Saskatchewan, Canada.
 - .2 Indicate materials and methods of attachment of conductors to air terminals, sky wire, and electrodes.

1.3 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials indoors and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect lighting protection from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.

PART 2 - PRODUCTS

2.1 MATERIALS

- .1 Lightning Rods: copper solid rod.
- .2 Conductor: copper stranded.
- .3 Fastenings and attachment straps: copper.
- .4 Ground electrodes: Not Applicable.
- .6 Use copper conductors, terminals, connectors and fastenings.

- .7 Connections: copper connections formed by permanent mechanical connectors or inspectable wrought copper compression connectors to IEEE 837.

2.2 DESCRIPTION

- .1 System to consist of metallic air terminals, lightning conductors connecting air terminals to existing lightning protection system.

2.3 REGULATORY REQUIREMENTS

- .1 System subject to: approval by authority having jurisdiction.

PART 3 - EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify conditions of substrates previously installed under other Sections or Contracts are acceptable for lightning protection installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 INSTALLATION

- .1 Install lightning protection to CAN/CSA-B72.
- .2 Bond discharge conductors to service mast or other non-current-carrying electrical parts.
- .3 Submit certificate of installation to Departmental Representative.

3.3 INSPECTION

- .1 Obtain inspection certificate from Departmental Representative for discharge conductor passing through any fire supporting membrane.

3.4 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11.
 - .1 Leave Work area clean at end of each day.

- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 20 and 01 35 21.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

3.5 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by lightning protection installation.

END OF SECTION