






NOTE:
1. 12-53mmC (6 FOR POWER & 6 COMMUNICATION) IN CONCRETE ENCASED DUCTBANK. REFER TO DRAWING LTWMF-E-81 FOR DETAIL 3.
2. COMPLETED UNDER CONTRACT B.
3. CONTRACT B TO EXTEND DUCT BANK AS SHOWN, UNDER THE ROADWAY, AND CAP DUCTS 4000MM FROM THE EDGE OF THE ROAD.



AECL Project No. 4502-508120

 Public Works and
Government Services Canada
Travaux publics et
Services gouvernementaux Canada



04		
03		
02	TENDER ADDENDUM No. 1	2014/10/01
01	ISSUED FOR TENDER	2013/06/28
revision		date

Do not scale drawings.
Verify all dimensions and conditions on site and immediately
notify the Departmental Representative of all discrepancies.

AECOM

This drawing has been prepared for the use of AECOM's client and may not be used, reproduced or
relied upon by third parties, except as agreed by AECOM and its client, as required by law or for use
by governmental reviewing agencies. AECOM accepts no responsibility, and denies any liability
whatsoever, to any party that modifies this drawing without AECOM's express written consent.
Do not scale this document. All measurements must be obtained from stated dimensions.

project title
titre du projet
**PORT GRANBY, ONTARIO
PORT HOPE AREA INITIATIVE**

PROJECT GRANBY PROJECT
LTWMF CONSTRUCTION AND
PGWMF REMEDIATION

drawing title
titre du dessin
**ELECTRICAL LTWMF SITE PLAN
SHEET 2 OF 2**

drawn by dessiné par	RB	
designed by conc par	JL	
approved by approuvé par	EM/CH	
bid offre	J.A., P.ENG.	project manager administrateur de projets
project date date du projet	2013-07-15	
project no. no. du projet	R.023276.217	
drawing no. dessiné no.	LTWMF-E-11	