


- NOTE**
1. ALL ELECTRICAL CIRCUIT SHALL BE FED FROM LP-5.
  2. REFER TO DRAWING LTWMF-E-03 FOR DETAIL OF LIGHTING FIXTURES
  3. COORDINATE EXACT LOCATIONS OF LOCAL CONTROL PANELS AND POWER PANELS ON SITE PRIOR TO INSTALLATION

Public Works and  
Government Services Canada  
Travaux publics et  
Services gouvernementaux Canada



04		
03		
02	TENDER ADDENDUM No. 1	2014/10/01
01	ISSUED FOR TENDER	2013/06/28
revision		date

Do not scale drawings.  
Verify all dimensions and conditions on site and immediately  
notify the Departmental Representative of all discrepancies.

**AECOM**

This drawing has been prepared for the use of AECOM's client and may not be used, reproduced or  
relied upon by third parties, except as agreed by AECOM and its client, as required by law or for use  
by governmental reviewing agencies. AECOM accepts no responsibility, and denies any liability  
whatsoever, to any party that modifies this drawing without AECOM's express written consent.  
Do not scale this document. All measurements must be obtained from stated dimensions.

project title  
titre du projet  
**PORT GRANBY, ONTARIO  
PORT HOPE AREA INITIATIVE**

project title  
titre du dessin  
**PORT GRANBY PROJECT  
LTWMF CONSTRUCTION AND  
PGWMF REMEDIATION**

drawing title  
titre du dessin  
**LEACHATE REMOVAL  
PUMP STATION CELL 2  
ELECTRICAL LAYOUT**

drawn by  
dessiné par  
**AJS**

designed by  
conçu par  
**JL**

approved by  
approuvé par  
**YC/CH**

bid  
offre  
**J.A., P.ENG.** project manager  
administrateur de projets

project date  
date du projet  
**2013-07-15**

project no.  
no. du projet  
**R.023276.217**

drawing no.  
dessiné no.  
**LTWMF-E-31**