



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency**  
**P.O. Box 900**  
**100 Hawk Avenue**  
**Banff, Alberta T1L 1K2**  
**Bid Fax: (403) 762-5057**

AMENDMENT TO

INVITATION TO TENDER

APPEL D'OFFRES

**Tender To: Parks Canada Agency**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefore.

**Soumission aux: l'Agence Parcs Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Issuing Office - Bureau de distribution

Parks Canada Agency  
 Banff Field Unit  
 P.O. Box 900  
 Banff Alberta T1L 1K2

Title-Sujet <b>Rocky Mountain House Bank Stabilization</b>		Date <b>October 2, 2014</b>
Solicitation No. - No. de l'invitation <b>5P421-15-0207</b>		Amendment No. <b>003</b>
Solicitation Closes L'invitation prend fin –  at – á <b>02:00 PM</b> on – le <b>October 7, 2014</b>		Time Zone Fuseau horaire -  <b>Mountain Time</b>
F.O.B. - F.A.B. <b>Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/></b>		
Address Inquiries to: - Adresser toute demande de renseignements à : <b>Rose Marino</b>		
Telephone No. - No de téléphone <b>(403) 760-1319</b>	Fax No. – No de FAX: <b>(403) 762-5057</b>	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:  <b>Rocky Mountain House National Historic Site</b> <b>Site 1247, Comp 6, R.R. #4</b> <b>Rocky Mountain House, Alberta</b> <b>T4T 2A4</b>		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur		
Signature		Date

### **Amendment 003**

This amendment is raised to make the following changes and additions to the tender document:

#### **1) Questions and Answers**

Q1. Will the substantial completion date of November 21, 2014 be extended.

A1. Not at this time, the contractor is expected to make all reasonable efforts with resources, equipment, and labour to meet the substantial completion date as specified.

Q2. The work area at 0+050 to 0+280. In order to place the riprap as specified there will be a need to bench out from the existing bank with the rip rap and then place the benched rip rap on the slope as specified. The flat bench could be as wide as 3.0 meters out from the toe of the existing slope.

Will Parks accept a reasonable amount of lost riprap that may not be retrieved from the river when the bench is placed on the slope as specified This quantity may be as high as 15 – 20- %.

A2. If a situation occurs where riprap is anticipated to be lost by the contractor, they must coordinate with the Departmental Representative. The project has been design not to incur any loss of rip rap in the river.

Q3. Are we able to remove a couple of smaller trees from the path leading down to area 0+050 to 0+280.

A3. Tree removal may be allowed upon the pre-approval of the Departmental Representative.

Q4. What are the days with restricted hours and what are those hours?

A4. Fright Night will be on October 10, 11, 17, and 18, 2014

Q5. Can we work Sundays if not restricted?

A5. Yes

Q6. What is the thickness of the rip rap? 1.2 or 1.5?

A6. The minimum thickness of the rip rap is 1.5 times the nominal rip rap class diameter

Q7. Can we get clarification of the filter cloth placement for the class 3 rock.

A7. For the proposes of this project only Non-woven Geotextile Filter Fabric Class 1M, 1 and 2 will be required in all areas.

---

Date: September 16, 2014

**2) REMOVE: APPENDIX 1 - COMBINED PRICE FORM (1 page)****INSERT:****APPENDIX 1 - COMBINED PRICE FORM (1 page)**

- 1) The prices per unit shall govern in establishing the Total Extended Amount. Any arithmetical errors in this Appendix will be corrected by Canada.
- 2) Canada may reject the bid if any of the prices submitted do not reasonably reflect the cost of performing the part of the work to which that price applies.

**LUMP SUM**

The Lump Sum Amount designates Work to which a Lump Sum Arrangement applies.

- (a) Work included in the Lump Sum Amount represents all work not included in the unit price table.

<b>LUMP SUM AMOUNT (LSA)</b> Excluding GST / HST
---

**UNIT PRICE TABLE**

The Unit Price Table designates Work to which a Unit Price Arrangement applies.

- (a) Work included in each item is as described in the referenced specification section.
- (b) The Price per Unit shall not include any amounts for Work that is not included in that unit price Item.

Item No	Class of Labour, Plant or Material	Unit of Measurement	Estimated Quantity (EQ)	Price per Unit GST/HST extra (PU)	Extended amount (EQ x PU) GST/HST extra
1	Haul and Place Class 2 Rip Rap	m <sup>3</sup>	6650		
2	Haul and Place Class 3 Rip Rap	m <sup>3</sup>	300		
3	Hydraulic Seeding	m <sup>2</sup>	13000		
4	Terraseeding™	m <sup>2</sup>	5000		
5	Live Stakes	Each	2334		
6	Shrubs	Each	840		
7	Trees	Each	210		
8	Temporary Haul Road	m	100		
<b>TOTAL EXTENDED AMOUNT (TEA)</b> Excluding GST / HST					

**TOTAL BID AMOUNT**

<b>TOTAL BID AMOUNT (LSA + TEA)</b> Excluding GST / HST
--

Date: September 16, 2014

---

**Unit Price Table Item # 5, 6, 7, - See Attached Appendix C –  
Re-vegetation Criteria for Rocky Mountain House National Historic Site-Rip Rap Works 2014**

**Unit Price Table Item # 8 - Temporary Haul Road**

Where ground conditions do not allow for hauling of rock trucks and other required equipment the contractor shall, under the direction of the Departmental Representative, supply all necessary labour, equipment, and material to install and remove a Temporary Haul Road as below:

- Unit of measurement: Lineal meter
  - Width: 4.5 m
  - Depth: 0.3 m
  - Place on top of bearing surface Non-woven Geotextile Filter Fabric Class 1M, 1 and 2
  - On top of Non-woven Geotextile Filter Fabric place 300 mm of Pit Run
-

Date: September 16, 2014

---

**3) REMOVE:**

Specification: Section 31 37 00 Rock Rip Rap – pages 1 to 6

**INSERT:**

Attached: Specification: REVISED 2014-09-26 Section 31 37 00 Rock Rip Rap – pages 1 to 6

---

**4) REMOVE: Appendix B – Mitigation Measures**

**INSERT: Appendix B – Basic Impact Analysis**

---

**5) Insert: Appendix D –  
Alberta Environment and Sustainable Resource Development  
Approval and Amendment**

All others terms, clauses and conditions remain unchanged.