



**RETURN BIDS TO:
 RETOURNER LES SOUMISSIONS A:
 Bid Receiving/Réception des
 sousmissions**

**RCMP / GRC
 Procurement & Contracting services
 c/o Commissionaires, F Division
 6101 Dewdney Avenue
 Regina, SK S4P 3K7**

**Facsimile Number for Amendments:
 (306) 780-3466**

**SOLICITATION AMENDMENT
 MODIFICATION DE L'INVITATION**

**The referenced document is hereby
 revised; unless otherwise indicated, all
 other terms and conditions remain the
 same.**

**Ce document est par la présente révisé;
 sauf indication contraire, les modalités
 de l'invitation demeurent les memes.**

Comments - Commentaries

**Vendor/Firm Name and Address
 Raison sociale et adresse du
 fournisseur/de l'entrepreneur**

Facsimile No. - No de télécopieur:

Telephone No. - no de téléphone:

Title-Sujet Disconnect, Transport, Position, Service Connections, and Site Construction for Transportable Cells, Lumsden to Deschambault Lake, SK	
Solicitation No. - No. de l'invitation M5000-5-2331/A	Date 03 October 2014
Amendment No. - No modif. 01	
Client Reference No. - No. De Référence du Client 206921	
GETS Reference No. - No. de Référence de SEAG PW-14-00654482	
Solicitation Closes -L'invitation prend fin at - à 2 :00 pm Central Standard Time on - le 09 October 2014	
F.O.B. - F.A.B. Destination	
Address Enquiries to: - Adresser toutes questions à: Bonny Manz, Senior Contracting Officer	
Telephone No. - No de téléphone (306) 780-3352	Fax No. - N° de FAX: (306) 780-3466
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Royal Canadian Mounted Police Deschambault Lake, SK	
This document does not contain a PERSONNEL SECURITY Clearance requirements	
Delivery Required - Livraison exigée:	Delivery Offered - Livraison proposée
Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur	



The purpose of this amendment is to add a drawing, attached separately; and make the following change:

Drawing A-01

DELETE: Note regarding overhead power service.

INSERT:

400 amp underground service to existing exterior mounted WP Splitter will be supplied by Sask Power, paid for by RCMP. Contractor is required to prepare the service route to final grade, clear of debris and obstacles, and provide trench and backfill for Sask Power installation of service. Proposed route is as per attached routing sketch. Backfill through roadways & driveways to be compacted to 100% proctor density, remainder of trench to 95%. Coordinate complete installation of service with Sask Power.