

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Réception des soumissions - TPSGC / Bid Receiving
- PWGSC
1550, Avenue d'Estimauville
1550, D'Estimauville Avenue
Québec
Québec
G1J 0C7

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
TPSGC-PWGSC
601-1550, Avenue d'Estimauville
Québec
Québec
G1J 0C7

Title - Sujet Havre St-Georges-de-Malbay	
Solicitation No. - N° de l'invitation F3731-140109/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client F3731-14-0109	Date 2014-10-07
GETS Reference No. - N° de référence de SEAG PW-\$QCM-008-16121	
File No. - N° de dossier QCM-4-37163 (008)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-10-17	Time Zone Fuseau horaire Heure Avancée de l'Est HAE
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Rochette, Jean	Buyer Id - Id de l'acheteur qcm008
Telephone No. - N° de téléphone (418) 649-2834 ()	FAX No. - N° de FAX (418) 648-2209
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

F3731-140109/A

Client Ref. No. - N° de réf. du client

F3731-14-0109

Amd. No. - N° de la modif.

001

File No. - N° du dossier

QCM-4-37163

Buyer ID - Id de l'acheteur

qcm008

CCC No./N° CCC - FMS No/ N° VME

Page left blank on purpose.

Title : ST-GEORGES-DE-MALBAY HARBOUR WAVE PROTECTION IMPROVEMENT WORK

Included in the present amendment :

1. Questions and answers 1 to 10

QUESTIONS AND ANSWERS :

Question 1 : Is it possible to send us the construction details of the new aluminum 10m gangway? If not, is it possible to send us the drawings of the existing gangway as a reference to determine a price?

Answer 1 : Gangway is subject to a performance specification and must be designed to meet the indications of specifications in Section 35 51 23 –Floating docks. There are no drawings available.

Question 2 : For the new timber crib, do we provide wheelguards? If so, please send us a review of drawing M02-03.

Answer 2 : No

Question 3 : What is the weight of the existing steel floating docks and existing and new wooden floating docks?

Answer 3 : About 5000 lbs for the wooden floating docks and about 10,000 lbs for steel floating docks.

Question 4 : Is it possible to send us electrical drawings of the existing, underground conduits, etc. ...? Is the existing concrete base for new winch location includes conduits for the electrical cables? Is there any electrical installation drawings?

Answer 4 : Empty conduits are already placed in the ground and on the concrete base to supply electrical power from the electrical shed. No there is no electrical drawings to illustrate the work.

Question 5 : Please specify the required positions for the installation of geotextile as part of this work? To simplify things, add an item per square meter for the geotextile?

Answer 5 : Unlike what is shown for strong arms anchor blocks on sheet 6/8, there is no geotextile in the project.

Question 6 : In Section 01 11 55 of specifications, it is required to supply, install and maintain a balance on loading site materials. Is it really necessary to provide a balance on work site if the producer of stone directly weigh trucks at the quarry before sending it at Work Site?

Answer 6 : Stone imported on the site shall be weighed as it is paid per metric tonne. Recovered material from demolition do not needs to be weighed because reuse is paid in a lump sum item.

Question 7 : How many contaminated soil can be expected to dispose? Maybe create a unitary item for disposal of contaminated materials because the quantity is unknown.

Answer 7 : There is no contaminated soil, only treated (creosote and CCA) wood to dispose, about 620 mt.

Question 8 : The steel cables for floating docks have to be galvanized? Is the brand 'CROSBY' is required for the accessories?

Answer 8 : The steel cables must be galvanized. For accessories, it must be ensured that the components have dimensions that are compatible for assembly, but equivalent products can be used.

Question 9 : Specify the thickness of the gangway plate T6? Confirm that holes are required at all 250mm in the direction of the dimension 2100mm. What is the distance from the edge of the plate to these two sets of holes?

Answer 9 : T6 plate is 6mm. Yes 250mm for both 2 100 sides. The holes may be placed at 75mm from the edge of the plate.

Question 10 : Is it possible to send us the details and number of existing fenders to recover from wharf demolition?

Answer 10 : The existing wharf to demolish is an old timber crib highly degraded and without fendering system. The only rubber fenders to recover are those of some steel floating docks that must be removed to install the strong arm's fastening system.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.