

ADDENDUM NO. 1

NEW COMPUTER BASED TRAINING ROOM

DATA TAXATION BUILDING

ST. JOHN'S NL.

SOLICITATION #: EA002-151088/A

**THE FOLLOWING AMENDMENT TO THE BID DOCUMENTS IS EFFECTIVE
IMMEDIATELY. THE ADDENDUM SHALL FORM A PART OF THE CONTRACT
DOCUMENTS.**

Item 1. Change's to Drawing A-6 – Finishes Plan and Door & FrameSchedule

.1 Reference: 2/A6 Door Types

**In Door Type A Elevation: Size of the Vision Lite is sized as: bottom of lite at
900 mm above the floor and top of lite to match vision lite in Door 130."**

**.2 In Door and Frame Schedule: Change Fire
Resistance Rating of Door 130A from "1 Hr." to 1.5 Hr."**

**By submission of its bid, the Bidder confirms that it has read and understands
the requirements expressed in all addenda and has included all costs of these
requirements in its Total Bid Amount.**
