



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

**Parks Canada Agency –Central Registry
111 Water Street East
Cornwall, Ontario K6H 6S3**

Bid Fax: 877-558-2349

AMENDMENT #1
TO:

INVITATION TO TENDER

APPEL D'OFFRES

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Contracting Operations
111 Water Street East
Cornwall, Ontario K6H 6S3

Title-Sujet Multi-Purpose Building Renovation, Fundy NP		Date October 8, 2014
Solicitation No. - No. de l'invitation 10140810		
GETS Reference No. – No de reference de SEAG		
Solicitation Closes L'invitation prend fin – at – à 02:00 PM on – le 2014-10-16	Time Zone Fuseau horaire - Eastern Daylight Saving Time (EDT)	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Annie Roy		
Telephone No. - No de téléphone 613-938-5752	Fax No. – No de FAX: 1-866-246-6893	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Fundy National Park PO Box 1001 Alma, NB E4H 1B4		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur : Telephone No. - No de telephone: _____ Facsimile No. - N° de télécopieur: _____		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur _____ Name / Nom Title / Titre _____ Signature Date		

AMENDMENT #1

THE PURPOSE OF THIS AMENDMENT IS TO GIVE EFFECT TO THE FOLLOWING:

THE FOLLOWING CHANGES TO THE PLANS AND SPECIFICATIONS ARE TO BE INCORPORATED AND BECOME PART OF THE CONTRACT DOCUMENTS.

ARCHITECTURAL

SPECIFICATION

Item 1 Specification Section 10 21 13/Phenolic Toilet compartments
Add the following as acceptable product:

Metpar Corporation PH-FP-500

Item 2 Specification Section 10 28 13/Toilet Accessories
Add the following as acceptable products:

<u>Item</u>	<u>Bradley</u>
2.1.1	5224
2.1.2	4722-15
2.1.3	6563
2.1.4	2442
2.1.5	780-2 (460mm X 910mm)
2.1.6	8322-001

STRUCTURAL

Item 3 Scheduling of structural reinforcing of existing roof truss system:
The reinforcing of the existing roof truss system, as well as the installation of the new structural steel support framing, are to be completed, and temporary shoring and supports removed, before beginning the installation of the new roofing.

Signed copy of this amendment should accompany each tender. If your tender has already been submitted please sign and fax the amendment along with any revisions to tender price, to this office before the close of Tender.

Fax: 1-877-558-2349

MECHANICAL

Item 4 Specification Section 22 42 03/Plumbing Fixtures and Trims.
Acceptable alternatives for plumbing items shall be as follows:

Item P1, water closet, Zurn is acceptable if it can meet a 1000 MAP test.

Item P2, urinal, Zurn is acceptable.

Item P3, lavatory, Zurn is acceptable.

Item P4, mop basin, Stern Williams is acceptable for basin, Zurn is acceptable for faucet.

Strainer, Zurn is acceptable.

Expansion tank, Amtrol is acceptable.

Item 5 **Question:** Plumbing Fixture Schedule on plan M-201 shows back-spud fixtures P-1 and P-2 matched to top-spud flush valves; which model #s are correct, the fixtures or the trims, and which need to be changed?

Answer: Fixtures P1 and P2 are back spud fixtures; however the model numbers have been discontinued. The supply shall be back spud as well. Use American Standard 3351 001 with Delta 1600t6102 for item P1, and use American Standard 6515 001 with Delta 1600T6404 for item P2.

Signed copy of this amendment should accompany each tender. If your tender has already been submitted please sign and fax the amendment along with any revisions to tender price, to this office before the close of Tender.

Fax: 1-877-558-2349

Item 6

Contractor site visit, Fundy October 3, 2014

List of attendees:

<u>Representative Name</u>	<u>Company Name</u>
Bob MacDonald	Stantec Consulting Ltd.
Robert Vale	Valron
Alex Dupuis	Gretzky Construction
Joe Jones	Gretzky Construction
Gretzky Dupuis	Gretzky Construction
Kevin Roy	King Construction Ltd
Gary Arsenault	Gretzky Construction
Jason MacLeod	Rod MacLeod Construction
Peter Milan	Heron Enterprises
Pat Kelly	Castle Rock
Matt Landry	BSM Services
Jason Allain	Prism Construction
Rob McRae	Master Mech
Doug Stevens	Rice Contracting
Rene LeBlanc	Edgeline Construction
Martin Theriault	Bay Construction & Management
Euclide Cormier	Conair Ventilation
Kurt Phinney	Avondale Construction
Myles MacCallum	Myview Construction
Garth MacCallum	Myview Construction
Stephen Flood	John Flood & Sons 1961 Ltd

For additional questions/items discussed on site not covered in this Addendum, please forward in writing to the Tendering Authority.

ALL OTHER TERMS AND CONDITIONS OF THE ITT REMAIN UNCHANGED.

Signed copy of this amendment should accompany each tender. If your tender has already been submitted please sign and fax the amendment along with any revisions to tender price, to this office before the close of Tender.

Fax: 1-877-558-2349