

**Part 1 General****1.1 REFERENCES**

- .1 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
  - .1 Material Safety Data Sheets (MSDS).
- .2 National Fire Protection Association (NFPA)
  - .1 NFPA 10.2010, Standard for Portable Fire Extinguishers.

**1.2 SUBMITTALS**

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Submit manufacturer's printed product literature and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
  - .2 Submit two copies WHMIS MSDS - Material Safety Data Sheets in accordance with Section 02 81 01 - Hazardous Materials.
- .3 Provide shop drawings.
- .4 Quality control submittals: submit following in accordance with Section 01 45 00 - Quality Control.
  - .1 Manufacturer's Instructions: submit manufacturer's installation instructions and special handling criteria.

**1.3 DELIVERY, STORAGE AND HANDLING**

- .1 Packing, shipping, handling and unloading:
  - .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Waste Management and Disposal:
  - .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

**Part 2 Products****2.1 MULTI-PURPOSE DRY CHEMICAL EXTINGUISHERS**

- .1 Stored pressure rechargeable type with hose and shut-off nozzle, ULC labelled for A, B and C class protection.
  - .1 Sizes 4.5kg or as indicated.

**2.2 EXTINGUISHER BRACKETS**

- .1 Type recommended by extinguisher manufacturer.

**2.3 IDENTIFICATION**

- .1 Identify extinguishers in accordance with recommendations of ANSI/NFPA 10.
- .2 Attach bilingual or label to extinguishers, indicating month and year of installation. Provide space for service dates.

**Part 3                    Execution**

**3.1                        MANUFACTURER'S INSTRUCTIONS**

- .1                    Compliance: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

**3.2                        INSTALLATION**

- .1                    Install or mount extinguishers in cabinets or on brackets as indicated.

**3.3                        FIELD QUALITY CONTROL**

- .1                    Manufacturer's Field Services:
  - .1                    Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.

**END OF SECTION**