04 11

0 10 20 30 40 50 60 70 80 90 100 110 120 130 140 150 160 170 180 190 200 millimetres

REFER TO SS-C-03

WEST MOUND ROAD

LAKESHORE ROAD

NICHOLS ROAD

HAUL ROAD

EAST MOUND ROAD

ALL SUBDRAINS TO BE REMOVED

NOTE:
SEE LAK-C-SERIES OF DRAWINGS FOR UNDERPASS REMOVAL AND LAKESHORE ROAD RESTORATION.

REMOVE 50 mm PIPE FROM VC-6 AND INSTALL BLIND FLANGES

REMOVE 100 mm PIPE FROM VC-2 AND INSTALL BLIND FLANGES

PROPOSED 19ø HCL DRIP LINE TO REMAIN

EXISTING WTP AND LAGOON/POND TO BE DECOMMISSIONED

PROPOSED EXCLUSION ZONE SWM POND AND PUMPING STATION TO BE REMOVED

EXISTING MHDW1 TO REMAIN PLUG UPSTREAM OPENING WATERTIGHT.

UNDERPASS SEWER REMOVED

FILL DITCH
REMOVE DITCH CULVERTS

PROPOSED EGGC
SEE PGWMF-X-40

PROPOSED 19ø HCL DRIP LINE TO REMAIN

300 mm SLEEVE TO BE VERIFIED AS UNCONTAMINATED, PRESSURE GROUTED AND ABANDONED IN PLACE FOLLOWING REMOVAL OF 100 mm HDPE FORCEMAIN

EX. EAST-WEST TRANSFER -PIPE TO BE REMOVED

NOTE: PROPOSED SURFACE WATER HEADWALL TO BE REMOVED AND 300 mm PIPE TO BE PRESSURE GROUTED AND ABANDONED IN PLACE FOLLOWING REMOVAL OF UPSTREAM DIVERSION SWALE. (SEE PGWMF-X-17)

PROPOSED WEST GORGE RESERVOIR AND PUMPING STATION TO BE MODIFIED TO ULTIMATE CONFIGURATION FOLLOWING REMOVAL OF RESERVOIR.
SEE PS-D-SERIES, PGWMF-L-SERIES AND PGWMF-X SERIES OF DRAWINGS

EXISTING METER CABIN TO REMAIN

PROPOSED EAST GORGE RESERVOIR AND PUMPING STATION TO BE MODIFIED TO ULTIMATE CONFIGURATION FOLLOWING REMOVAL OF RESERVOIR.
SEE PS-D-SERIES, PGWMF-L-SERIES AND PGWMF-X SERIES OF DRAWINGS

EXCAVATE, REMOVE INFRASTRUCTURE AND DISPOSE OF MATERIALS ACCORDINGLY

PRESSURE GROUT SEWER AND ABANDON PIPE IN PLACE

NOTES:

1. DEMOLISH EX. STRUCTURE 1.20 m BELOW FINAL GRADE. BREAK BOTTOM SLAB OF STRUCTURE AND BACKFILL WITH FREE DRAINING MATERIAL TO SATISFACTION OF DEPARTMENTAL REPRESENTATIVE.
2. CONTRACTOR SHALL COMPLETE VERIFICATION TESTING ON ALL MATERIALS (PIPES, STRUCTURES, APPURTENANCES ETC.) IDENTIFIED AS REMOVAL ITEMS IN ORDER TO DETERMINE METHOD OF DISPOSAL TO SATISFACTION OF THE DEPARTMENTAL REPRESENTATIVE.
3. REMOVE EXISTING STRUCTURE IN ITS ENTIRETY AND DISPOSE OF MATERIALS ACCORDINGLY.
4. CONTRACTOR IS RESPONSIBLE FOR ADDITIONAL REMOVALS SPECIFIED ELSEWHERE IN THE CONTRACT DOCUMENTS.

3 DENOTES REFERENCE TO NOTES (SEE ABOVE)

SITE SERVICING REMOVALS AT PROJECT COMPLETION PGWMF SITE

0 10m 50m

SCALE = 1:1000

AECL Project No. 4502-508120

Public Works and Government Services Canada

Travaux publics et Services gouvernementaux Canada

key plan

LICENSED PROFESSIONAL ENGINEER M. HARRIS 100089723 8 OCT 2014 PROVINCE OF ONTARIO

revision		date
04		
03	TENDER ADDENDUM No. 2	2014/10/08
02	TENDER ADDENDUM No.1	2014/10/01
01	ISSUED FOR TENDER	2013/06/28

Do not scale drawings.
Verify all dimensions and conditions on site and immediately notify the Departmental Representative of all discrepancies.

AECOM

This drawing has been prepared for the use of AECOM's client and may not be used, reproduced or relied upon by third parties, except as agreed by AECOM and its client, as required by law or for use by governmental reviewing agencies. AECOM accepts no responsibility, and denies any liability whatsoever, to any party that modifies this drawing without AECOM's express written consent.
Do not scale this document. All measurements must be obtained from stated dimensions.

project title / titre du projet
PORT GRANBY, ONTARIO
PORT HOPE AREA INITIATIVE

PORT GRANBY PROJECT
LTWMF CONSTRUCTION AND PGWMF REMEDIATION

drawing title / titre du dessin
SITE SERVICING REMOVALS AT PROJECT COMPLETION PGWMF SITE

drawn by / dessine par: L.T./M.A.

designed by / conc par: M.H.

approved by / approuve par: M.H.

bid / offre: J.A., P.ENG. — project manager / administrateur de projets

project date / date du projet: 2013-07-15

project no. / no. du projet: R.023276.217

drawing no. / dessine no.: SS-C-07