

Q.1

Our suppliers for the air inlet/fan are experiencing difficulty procuring responses based on the term “*antiburst tablet*” as identified within the tender documents (page 14 of 27/General Notes – Item #5). Please advise me of a supplier, Engineer, Consultant or other resource that I may contact for pricing of this item.

A.1

DELETE ITEM 5 & 6 GENERAL NOTES (p 14 of 27). All heating, cooling and air circulation will be provided by Combination Unit. See Addendum #1