



| RETURN BIDS TO: RETOURNER LES SOUMISSIONS Á: | Title-Sujet Multi-Purpose Building Renovation, Fundy NP | | Date October 14, 2014 |
|---|--|-------------------------------|--------------------------|
| Parks Canada Agency –Central Registry 111 Water Street East Cornwall, Ontario K6H 6S3 | Solicitation No No. de l'invitation 10140810 GETS Reference No. – No de reference de SEAG | | |
| Bid Fax: 877-558-2349 | Solicitation Closes L'invitation prend fin – | Time Zone Fuseau horaire - | |
| <u>QUESTIONS &</u> ANSWERS #2 TO: | at – à 02:00 PM on – le 2014-10-16 | Eastern D (EDT) | aylight Saving Time |
| INVITATION TO TENDER | F.O.B F.A.B. Plant-Usine: Destination: Address Inquiries to: - Adresser toute demande de renseignements à : | | |
| APPEL D'OFFRES Tender To: Parks Canada Agency | Annie Roy Telephone No No de téléphone | Fax No. – | No de FAX: |
| We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor. | 613-938-57521-866-246-6893Destination of Goods, Services, and Construction: Destinations des biens, services et construction: | | |
| Soumission aux: l'Agence Parcs Canada Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at | Fundy National Park PO Box 1001 Alma, NB E4H 1B4 | | |
| aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci- annexée, au(x) prix indiqué(s). | Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur : | | |
| Comments - Commentaries | | | |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | Telephone No No de telephone: Facsimile No N° de télécopieur: | | |
| Issuing Office - Bureau de distribution | Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur | | |
| Parks Canada Agency Contracting Operations 111 Water Street East Cornwall, Ontario K6H 6S3 | Name / Nom | | Title / Titre |
| | Signature | | Date |



QUESTIONS & ANSWERS #2

THE FOLLOWING QUESTIONS HAVE BEEN ASKED BY POTENTIAL BIDDERS. FOR YOUR INFORMATION, BELOW ARE THE QUESTIONS AND ANSWERS:

Questions:

Item 1 Question: Can the attic insulation be blow-in instead of batt insulation if the same R value is provided?

Answer: Batt insulation as specified.

Item 2Question: Spray foam applied to the main floor wood joists
Show 200mm thickness on the drawings. Typically 100mm thickness is enough. Do you still want to
apply 200mm?

Answer: 200mm thickness as detailed.

Item 3Question: Could we get some clarification as to what kind
Sensors are expected to be supplied with the automatic dooroperatorasdescribedinthehardware section 08 71 10-2.2Door hardware .9.1.1.00<td

Answer: Delete "electronic sensors". Automatic door operators to be activated by barrier-free push button activators as specified.

Item 4 Question: Specification 08 50 00/windows, 2-1 materials. Is it possible to add "vinyl" windows as a possible alternate?

Answer: No. The required design, given location, is fiberglass. "Vinyl" windows not acceptable as a possible alternate.

Item 5 Question: Does the Appendix 2 of the Bid & Acceptance Form need to be filled out and submitted with the tender?

Answer: No. Only once the contract will be awarded to the successful bidder.

| Item 6 | Question: Do we need to apply for a building permit? And if so who with? |
|----------------|---|
| | Answer: No permit required. |
| <u>Item 7</u> | Question: Do we need to obtain park passes for the contractors on site? Answer: No. |
| Item 8 | Question: Is the parking lot at the rear of the building plowed out during the winter and available for the contractors use to park in? |
| | Answer: Yes. Back parking lot will be plowed and available to contractors. |
| <u>Item 9</u> | Question: The 200mm spray foam on underside of floor, does it need a smoke stop/coating applied? Answer: No. |
| Item 10 | Question: Is there a tentative award date for this project? |
| | Answer: Prior to October 30, 2014. |
| <u>Item 11</u> | Question: Section 10 28 13/Toilet Accessories, 2.1/component. Item 4/paper towel dispenser. Will forced air (electric) units be considered in lieu of paper towel? |

Answer: Paper towel dispenser as specified.