

PART 1 - GENERAL

1.1 SECTION INCLUDES

- .1 Materials and installation for connectors and terminations.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA International)
  - .1 CSA C22.2 No. 174-M, Cables and Cable Glands for Use in Hazardous Locations.
  - .2 CSA C22.2 No.41-M, Grounding and Bonding Equipment.

1.3 PRODUCT DATA

- .1 Submit product data.

PART 2 - PRODUCTS

2.1 CONNECTORS AND TERMINATIONS

- .1 Install CSA approved cable glands and conduit seals for use in hazardous locations as indicated on the drawings.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Bond and ground as required to CSA C22.2 No.41.
- .2 Install epoxy coating on all bonding terminations for corrosion prevention.

END OF SECTION