





[illegible]

MECHANICAL DETAILS 2 & SCHEDULES

	designed	M. TAYLOR			
	date	2014.06.10			
	drawn	J. COAKER			
	date	2014.06.10			
	approved				
	date				
Sourmission	Tender	V. WARFORD	<i>Karen Leffler</i>		
PWSSC Project Manager	Principal Author de projet	TPSCQ			
project number		R068936.001			
drawing no.		R068936.001 - M4			
no. du dessin					



PLUMBING FIXTURE SCHEDULE

TAG	DESCRIPTION	MANUFACTURER	MODEL NUMBER	COLOR/FINISH	FAUCET/FLUSH VALVE	DRAIN	HEAD	PIPE SIZES (IN.)				REMARKS
								DRAINAGE	VENT	COLD	HOT	
S-1	DOUBLE SINK	FRANKE/KINDRED	QDLA2233/8	SS	DELTA 26T3134	STAINLESS STEEL STRAINER		50	33	13	13	

VRF OUTDOOR UNIT SCHEDULE			
UNIT NUMBER	SERVICE	LOCATION	OU-1
		DATA ROOM	
		LOADING AREA	
	VOLTS/PHASE/HZ	208V/1/60	
	MOTOR POWER (kW)		
	M.C.A. (AMPS)	13	
	M.O.C.P. (AMPS)	15	
	MIN. AMBIENT OPERATING TEMPERATURE (°C)	-40	
	NOMINAL COOLING CAPACITY (kW)	1.19	
	MANUFACTURER	DAIKIN	
	MODEL NUMBER	PUY-A12NH43	
	OPTIONS/ACCESSORIES	COASTAL COIL COATING	

EXHAUST FAN SCHEDULE			
UNIT NUMBER	EF-1		
SERVICE	FRESH AIR	QUIET ROOM	
LOCATION			
FLOW RATE (L/s)	35		
E.S.P. (Pa)	100		
FAN SPEED (RPM)	1280		
MOTOR POWER (W)	48		
VOLTAGE/PHASE/Hz	110V/60		
MANUFACTURER	PENN BARRY		
MODEL NUMBER	ZEPHYRETTE (ZT)		
REMARKS	WIRE TO ROOM LIGHT SWITCH		

VRF INDOOR UNIT SCHEDULE		
	UNIT NUMBER	IL-1
	SERVICE	DATA ROOM
	INDOOR UNIT LOCATION	DATA ROOM WALL
	MAX AIR FLOW RATE (L/s)	200
	FAN SPEEDS	3
	VOLTS/PHASE/Hz	208V/1/60
	MOTOR POWER (kW)	0.03
	M.C.A. (AMPS)	1
	M.O.C.P. (AMPS)	15
	LEAVING DBT (°C)	
	NOMINAL COOLING CAPACITY (kW)	3.5
	MANUFACTURER	MITSUBISHI
	MODEL NUMBER	PKA-A12HA
	UNIT TYPE	WALL MOUNTED

