

PART 1 - GENERAL

1.1 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 11 - Cleaning.
- .3 Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .4 Section 01 78 00 - Closeout Submittals.
- .5 Section 01 91 00 - Commissioning - Mechanical and Electrical Installation.
- .6 Section 23 05 05 - Installation of Pipework.

1.2 REFERENCES

- .1 Unless otherwise indicated, all Work must be done in accordance with the latest edition of the National Building Code.
- .2 Furthermore, the works will be done in accordance with any other code or standard having jurisdiction, as per the latest edition, notably including, but not limited to:
 - .1 American National Standards Institute (ANSI)/American Society of Mechanical Engineers International (ASME).
 - .1 ANSI/ASME B16.15 2006, Cast Bronze Threaded Fittings, Classes 125 and 250.
 - .2 ANSI/ASME B16.18 2001, Cast Copper Alloy Solder Joint Pressure Fittings.
 - .3 ANSI/ASME B16.22 2001, Wrought Copper and Copper Alloy Solder Joint Pressure Fittings.
 - .4 ANSI/ASME B16.24 2001, Cast Copper Alloy Pipe Flanges and Flanged Fittings, Classes 150, 300, 400, 600, 900, 1500, and 2500.
 - .2 American Society for Testing and Materials International (ASTM).
 - .1 ASTM A182, Standard Specification for Forged or Rolled Alloy and Stainless Steel Pipe Flanges, Forged Fittings, and Valves and Parts for High-Temperature Service.
 - .2 ASTM A268/A268M, Standard Specification for Seamless and Welded Ferritic and Martensitic Stainless Steel Tubing for General Service.

-
- .3 ASTM A269, Standard Specification for Seamless and Welded Austenitic Stainless Steel Tubing for General Service.
 - .4 ASTM A307, Standard Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
 - .5 ASTM A312/A312M, Standard Specification for Seamless, Welded and Heavily Cold Worked Austenitic Stainless Steel Pipes.
 - .6 ASTM A403, Standard Specification for Wrought Austenitic Stainless Steel Piping Fittings.
 - .7 ASTM B32, Standard Specification for Solder Metal.
 - .8 ASTM B88M, Standard Specification for Seamless Copper Water Tube (Metric).
 - .9 ASTM F492, Standard Specification for Propylene and Polypropylene (PP) Plastic-Lined Ferrous Metal Pipe and Fittings.
 - .10 ASTM B283/B283M, Standard Specification for Copper and Copper-Alloy Die Forging (Hot-Pressed).
 - .3 American National Standards Institute/American Water Works Association (ANSI/AWWA).
 - .1 ANSI/AWWA C111-07, Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings.
 - .4 Canadian Standards Association (CSA International).
 - .1 CSA B242-M1980 (R1998), Groove and Shoulder Type Mechanical Pipe Couplings.
 - .5 Manufacturer's Standardization Society of the Valves, and Fittings Industry (MSS).
 - .1 MSS-SP-70-1998, Cast Iron Gate Valves, Flanged and Threaded Ends.
 - .2 MSS-SP-71-1997, Cast Iron Swing Check Valves, Flanged and Threaded Ends.
 - .3 MSS-SP-80-2003, Bronze Gate, Globe, Angle and Check Valves.
 - .6 National Sanitation Foundation (NSF).
 - .1 NSF 61, Drinking Water System Components.
-

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature and datasheets for insulation and adhesives, and include product characteristics, performance criteria, physical size, finish, and limitations.
- .3 Closeout Submittals:
 - .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.4 HEALTH AND SAFETY

- .1 Take necessary measures to ensure health and safety on construction site in accordance with Section 01 35 29.06 - Health and Safety Requirements.

1.5 DELIVERY, STORAGE, AND HANDLING

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal packaging material in appropriate on-site bins for recycling, in accordance with Waste Management Plan.
- .4 Divert unused metal materials from landfill to metal recycling facility as approved by Departmental Representative.
- .5 Fold up metal and plastic banding, flatten and place in designated area for recycling.

1.6 QUALITY ASSURANCE

- .1 All components used in the potable water distribution must follow NSF 61 Standard.
-

PART 2 - PRODUCTS

2.1 PIPING

- .1 Domestic cold water within building.
 - .1 NPS 2 ½ and above: Schedule 10, 304L stainless steel according to ASTM and NSF/ANSI-61 Standards.

2.2 FITTINGS

- .1 Stainless Steel:
 - .1 NPS 2 ½ and above: Schedule 10, welded, according to ASTM A403, grade WP-304L, and ANSI B16.9 Standards.
 - .2 Cast stainless steel flanges, Class 150, according to ASTM A182, grade F304L, and ANSI B16.5 Standards.
 - .3 Union: Class 3000, forged stainless steel, according to ASTM A182, grade F304L Standard.

2.3 JOINTS

- .1 Rubber Gaskets (1.6 mm thick): To AWWA C111/A21.11.
- .2 Bolts, Nuts, Hex Head, and Washers: To ASTM A307, Heavy Series.
- .3 Dielectric Connections between Dissimilar Metals: Dielectric fitting, complete with thermoplastic liner.

2.4 BUTTERFLY VALVES

- .1 NPS 2½ and over, flanged:
 - .1 ASME B16.50 face-to-face dimensions.
 - .2 To MSS-SP-67, Class 125/150. Ductile iron body and plated disc, stainless steel stem, EPT liner. Gear operated.
 - .1 Acceptable products: Nibco, FD-5765-0.

2.5 FLOWMETER

- .1 Approvals:
 - .1 CSA approved.
 - .2 OIML R49 (Organisation internationale de métrologie légale).
- .2 Performance:
 - .1 Flowmeter with reduced bore to improve flow profile and to keep good accuracy even if pipe layout is shorter than normally specified.
 - .2 Accuracy: $\pm 0.4\%$.
- .3 Characteristics:
 - .1 Electromagnetic.
 - .2 Carbon steel housing.
 - .3 Liner material: Elastomer.
 - .4 Ambient temperature limitation: -20 to 70°C.
 - .5 Stainless steel 316 L electrode.
 - .6 Flanged connections NPS 8, Class 150.
- .4 Flowmeter Transmitter:
 - .1 Characteristics:
 - .1 Power supply: 100-230 VAC, 60 Hz.
 - .2 4-20 mA with communication and pulse output.
 - .3 Illuminated display.
 - .4 Diagnostic message and error code as per Namur NE107 Standards.
- .5 Acceptable Products: ABB, Watermaster FER Series.

PART 3 - EXECUTION

3.1 APPLICATION

- .1 Manufacturer's Instructions: Comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION

- .1 Install in accordance with National Building Code, and local authority having jurisdiction.
- .2 Install pipe work in accordance with Section 23 05 05 - Installation of Pipework, supplemented as specified herein.
- .3 Assemble piping using fittings manufactured to ANSI Standards.
- .4 Install piping close to walls and ceilings to reduce overcrowding of space. Group piping and install parallel to walls.
- .5 Connect to fixtures and equipment in accordance with manufacturer's written instructions, unless otherwise indicated.

3.3 VALVES

- .1 Isolate equipment, fixtures, and branches with ball valves.
- .2 Balance recirculation system using lockshield globe valves. Mark settings and record on as-built drawings upon completion.

3.4 PRESSURE TESTS

- .1 Complying with requirements of Section 23 05 93 - Testing, Adjusting, and Balancing for HVAC.
- .2 Test Pressure: Greater than one time maximum system operating pressure or 860 kPa during 2 hours.

3.5 PRE-START-UP INSPECTIONS

- .1 Systems to be complete, prior to flushing, testing, and start-up.
 - .2 Verify that system can be completely drained.
-

3.6 CLEANING AND DISINFECTION

- .1 Every pipe segment and equipment must be thoroughly cleaned and disinfected and rinsed before installation.
- .2 Disinfecting Solution: Sodium hypochlorite, complying to ANSI/AWWA B300 Standard.

3.7 START-UP

- .1 Provide continuous supervision during start-up.
- .2 Establish circulation and ensure that air is eliminated.
- .3 Rectify start-up deficiencies.

3.8 PERFORMANCE VERIFICATION

- .1 Scheduling:
 - .1 Verify system performance after pressure and leakage tests and disinfection are completed, and Certificate of Completion has been issued by authority having jurisdiction.
- .2 Procedures:
 - .1 Verify that flow rate and pressure meet design criterion.
 - .2 Verify compliance with safety and health requirements.
 - .3 Confirm water quality consistent with supply standards, and ensure no residuals remain as result of flushing or cleaning.
- .3 Reports: In accordance with section 01 33 00 - Submittal Procedures.

3.9 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
- .2 Waste Management: Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

END OF SECTION
