



NOTES:

① PROVIDE AND INSTALL A NEW BREAKER 20A-1P IN THE PAN-A PANEL FOR CONNECTING THE CONTROL PANEL TANDEM FUEL PUMP.

NOT FOR CONSTRUCTION



DESSAU
4530, 50th Avenue SE
Calgary (Alberta) T2B 3K4
T 403.253.3273
F 403.266.8825

DO NOT SCALE DRAWINGS

Revision/	Description/Description	Date/Date
00	FOR TENDER	14/07/17
0B	PRELIMINARY 90%	14/05/30
0A	PRELIMINARY 50%	14/05/16

Client/client
**EDMONTON
MAXIMUM SECURITY
INSTITUTION**
**2611 MERIDIAN STREET
EDMONTON, ALBERTA**

Project title/Titre du projet
**EDMONTON, ALBERTA
2611 MERIDIAN STREET
EMSI**
**PUMPHOUSE - FLOWMETER
AND DIESEL STORAGE TANK
REPLACEMENT**

Approved by/Approuvé par
Louis-Stéphane Racicot, p. eng.

Designed by/Concepté par
Claude Duval, p. eng.

Drawn by/Dessiné par
Michel Chayer

PWGSC Project Manager/Administrateur de Projets TPSGC
Yvon Labrecque

PWGSC, Architectural and Engineering Resources Manager/
Ressources Architectural et de Directeur d'ingénierie, TPSGC

Client/client
-

Drawing title/Titre du dessin
**ÉLECTRICITY
PUMPHOUSE
NEW LAYOUT**

Project No./No. du projet	Sheet/ Feuille	Revision no./ La Révision no.
R069549.001	E01 OF 2	00