
PART 1 - GENERAL**1.1 RELATED SECTIONS**

- .1 Section 26 05 00 - Common Work Results - Electrical.

1.2 REFERENCES

- .1 American National Standards Institute (ANSI)/Institute of Electrical and Electronics Engineers (IEEE).
 - .1 ANSI/IEEE 837, Qualifying Permanent Connections Used in Substation Grounding.
- .2 Canadian Standards Association (CSA International).

PART 2 - PRODUCTS**2.1 EQUIPMENT**

- .1 Clamps for grounding of conductor: Size as required to electrically conductive underground water pipe.
 - .2 Insulated Grounding Conductors: Green, type RW90.
 - .3 Busbars Earth: Copper, size as indicated in drawing, with insulators, fasteners, and connectors.
 - .4 Accessories necessary corrosion system grounding, including:
 - .1 Bits of grounding and bonding.
 - .2 Brides protection.
 - .3 Bolted connectors.
 - .4 Connectors soldering electrical connections.
 - .5 Cavaliers, braids, and barrettes to bond.
 - .6 Connectors wire clamp.
-

PART 3 - EXECUTION

3.1 INSTALLATION GENERAL

- .1 Existing grounding shall be verified for the condition and grounding resistance before any new connection take place.
- .2 Install complete permanent, continuous grounding system including, conductors, connectors, accessories. Where EMT is used, run green ground wire in each conduit.
- .3 Install connectors in accordance with manufacturer's instructions.
- .4 Protect against damage conductors grounded posed uncovered.
- .5 Use mechanical connectors for grounding connections to equipment provided with lugs.
- .6 The welded joints are prohibited.
- .7 Install a jumper on the flexible conduits, laid carefully on the outside of the conduit and connected at each end to a tip grounded, a seamless terminal, a wire clamp or screw with Belleville washer.
- .8 Arrange grounding conductors in radial form and route all the connections directly to a single point of common ground. Avoid loopbacks.
- .9 Connect one end of the metal armor of single core box at the source and install a non-metallic inlet plate to the other end.
- .10 Ground secondary service pedestals.

3.2 SYSTEM AND CIRCUIT GROUNDING

- .1 Install system and circuit grounding connections.

3.3 EQUIPMENT GROUNDING

- .1 Install grounding connections to typical equipment included in, but not necessarily limited to following list : Service equipment, transformers, switchgear, pipes, frames of motors, motor control centers, starters, control panels, frame steel, and distribution panels.

3.4 BUS GROUNDING

- .1 Install the copper bus bars on isolated supports fixed to the wall of electrical room.
-

-
- .2 Connect the equipment of the electrical room to the ground bus bar, using individual conductors of bare copper, stranded, size 2/0 AWG.

3.5 SYSTEMS COMMUNICATION

- .1 Perform connections grounded telephone systems, public address, fire alarm, and intercom, as follows:
 - .1 Phone: Install the ground as required by the telephone company and/or the Departmental Representative.
 - .2 Sound, intercom and fire alarm: As required by the manufacturer.

3.6 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results - Electrical.
- .2 Perform ground continuity and resistance tests using method appropriate to site conditions and approved by the Departmental Representative and the competent local authorities.
- .3 Perform tests before energizing electrical system.
- .4 During the tests, disconnect indicator earth leakage.

END OF SECTION
