

PART 1 - GENERAL

1.1 REFERENCES

- .1 American Society of Mechanical Engineers (ASME).
 - .1 ASME-B16.3-2006, Malleable-Iron Threaded Fittings: Classes 150 and 300.
 - .2 ASME-B16.9-2007, Factory-Made Wrought Steel Buttwelding Fittings.
- .2 ASTM International.
 - .1 ASTM A47/A47M-99(2004), Standard Specification for Ferritic Malleable Iron Castings.
 - .2 ASTM A53/A53M-07, Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc Coated, Welded and Seamless.
 - .3 ASTM B61-08, Standard Specification for Steam or Valve Bronze Castings.
 - .4 ASTM B75M-99(2005), Standard Specification for Seamless Copper Tube Metric.
- .3 Canadian Environmental Protection Act (CEPA).
 - .1 CCME PN 1326-2008, Environmental Code of Practice for Aboveground and Underground Storage Tank Systems for Petroleum Products and Allied Petroleum Products.
- .4 Canada Green Building Council (CaGBC).
 - .1 LEED Canada-NC Version 1.0-2004, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Package For New Construction and Major Renovations (including Addendum 2007).
 - .2 LEED Canada-CI Version 1.0-2007, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Guide For Commercial Interiors.
- .5 CSA International.
 - .1 CSA-B139-09, Installation Code for Oil Burning Equipment.
 - .2 CSA-B140.0-03, Oil Burning Equipment: General Requirements.
 - .3 CSA-C282-05, Emergency Electrical Power Supply for Buildings.

- .6 Green Seal Environmental Standards (GSES).
 - .1 Standard GS-11-2008, 2nd Edition, Paints and Coatings.
- .7 Health Canada / Workplace Hazardous Materials Information System (WHMIS).
 - .1 Material Safety Data Sheets (MSDS).
- .8 Manufacturers Standardization Society of the Valve and Fitting Industry (MSS).
 - .1 MSS-SP-80-08, Bronze Gate, Globe, Angle and Check Valves.
- .9 National Association of Corrosion Engineers (NACE).
 - .1 NACE SP0169-2007, Control of External Corrosion on Underground or Submerged Metallic Piping Systems.
- .10 National Fire Code of Canada (NFCC 2005).
- .11 South Coast Air Quality Management District (SCAQMD), California State, Regulation XI. Source Specific Standards
 - .1 SCAQMD Rule 1113-A2007, Architectural Coatings.
- .12 Underwriter's Laboratories of Canada (ULC).
 - .1 CAN/ULC S603.1-03, External Corrosion Protection Systems for Steel Underground Tanks for Flammable and Combustible Liquids.
 - .2 ULC ORD-C107.12-1992, Line Leak Detection Devices for Flammable Liquid Piping.

1.2 ADMINISTRATIVE REQUIREMENTS

- .1 Pre-Installation Meeting:
 - .1 Convene pre-installation meeting one week prior to on-site installations.
 - .1 Verify project requirements.
 - .2 Review installation conditions.
 - .3 Co-ordination with other building subtrades.
 - .4 Review manufacturer's installation instructions and warranty requirements.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature, specifications and datasheets for piping, fittings and equipment and include product characteristics, performance criteria, physical size, finish, and limitations.
 - .1 Indicate on manufacturer's catalogue literature the following: Valves.
 - .3 Indicate VOC's for adhesive and solvents during application and curing.
 - .4 Test Reports:
 - .1 Submit certified test reports from approved independent testing laboratories indicating compliance with specifications for specified performance characteristics and physical properties.
 - .5 Certificates:
 - .1 Submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .6 Manufacturers' Instructions: Provide manufacturer's installation instructions.

1.4 CLOSEOUT SUBMITTALS

- .1 Submit maintenance and engineering data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.5 QUALITY ASSURANCE

- .1 Ensure piping is installed by company and individuals authorized by authority having jurisdiction.

1.6 DELIVERY, STORAGE, AND HANDLING

- .1 Deliver, store, and handle materials in accordance with Section 01 61 00 - Common Product Requirements and manufacturer's written instructions.
 - .2 Delivery and Acceptance Requirements:
 - .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
-

PART 2 - PRODUCTS

2.1 FILL VENT AND CARRIER PIPE

- .1 Materials as per CSA-B139 Standard.
- .2 Steel: To ASTM A53/A53M Standard, Schedule 40, continuous weld or electric resistance welded, screwed.
- .3 Soft copper type "K" with flared connections (for engine hook-up from day tank)

2.2 STEEL PIPE COATING

- .1 Epoxy Paint: In accordance with manufacturer's recommendations.
- .2 Primers, Paints and Coating: In accordance with manufacturer's recommendations for surface conditions.

2.3 JOINTING MATERIAL

- .1 Screwed Fittings: Teflon tape.

2.4 FITTINGS

- .1 Steel:
 - .1 Malleable iron: Screwed, banded, Class 150 to ASME-B16.3 Standard.
 - .2 Welding: Buttwelding to ASME-B16.9 Standard.
 - .3 Unions: Malleable iron, brass to iron, ground seat, screwed, to ASTM A47/A47M Standard.
 - .4 Nipples: Schedule 40, to ASTM A53/A53M Standard.

2.5 BALL VALVES

- .1 NPS 2 and under: Bronze body, screwed ends, TFE seal, hard chrome ball, 4 MPa, WOG.

2.6 SWING CHECK VALVES

- .1 NPS 2 and under, screwed: To MSS-SP-80 Standard, Class 125, 860 kPa, bronze body, bronze swing disc, screw in cap, and regrindable seat.
-

PART 3 - EXECUTION

3.1 APPLICATION

- .1 Manufacturer's Instructions: Comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 PIPING

- .1 Install piping in accordance with Section 23 05 05 - Installation of Pipework, supplemented as specified.
- .2 Install oil piping system in accordance with CSA-B139 Standard.
- .3 Slope piping down in direction of storage tank, unless otherwise indicated.
- .4 Above ground piping to be protected from physical impact due to impact.
- .5 Piping Inside Building:
 - .1 Ensure piping in solid flooring is installed to CSA-B139 Standard.
 - .2 Use approved fitting to CSA-B139 Standard for steel piping.
- .6 Fill, vent, suction and return piping outside building:
 - .1 Steel piping throughout, except at tanks where electrically isolating fittings are used.
 - .2 Grading: Slope piping at 1% minimum back to tanks.
- .7 Piping at Tanks:
 - .1 Suction: Terminate 50 mm from bottom of tank with foot valve.
 - .2 Return: Terminate 50 mm from bottom of tank with return bend.
 - .3 Comply with CSA-B139 Standard for piping for venting at tanks including venting whistle.
 - .4 Fill pipes: Install to comply with CSA-B139 Standard.
 - .1 Include liquid tight tamperproof cover.

- .8 Clearly label piping runs in legible form indicating;
 - .1 Piping product content.
 - .2 Direction of flow.

3.3 VALVES

- .1 Install valves with stems upright or horizontal unless approved otherwise by Departmental Representative.
- .2 Install ball valves at branch take-offs to isolate pieces of equipment and as indicated.
- .3 Install swing check valves on discharge of pumps and as indicated.

3.4 OVERFILL AND SPILL PROTECTION

- .1 To CSA-B139 Standard.

3.5 FIELD QUALITY CONTROL

- .1 Site Tests/Inspection:
 - .1 Test system to CSA-B139 and CSA-B140.0 Standards and authorities having jurisdiction.
 - .2 Isolate tanks from piping pressure tests.

3.6 CLEANING

- .1 Clean in accordance with Section 23 08 02 - Cleaning and Start-Up of Mechanical Piping Systems and manufacturer's written recommendations, supplemented as follows:
 - .1 Flush after pressure test with No. 2 fuel oil for a minimum of two hours. Clean strainers and filters.
 - .2 Dispose of fuel oil used for flushing out in accordance with requirements of authority having jurisdiction.
 - .3 Ensure vents from regulators, control valves are terminated in approved location and are protected against blockage and damage.
 - .4 Ensure entire installation is approved by authority having jurisdiction.

.5 Clean in accordance with Section 01 74 11 - Cleaning.

.1 Remove surplus materials, excess materials, rubbish, tools, and equipment.

END OF SECTION
