
PART 1 - GENERAL**1.1 DEMOLITION**

- .1 Remove all existing electrical equipment indicated on drawings. This equipment must be removed in due course.

1.2 EQUIPMENT EXISTING

- .1 Means all existing equipment or components existing materials relevant to the existing electrical installations at the time of signing the Contract associated with this estimate and drawings related thereto.
- .2 All existing equipment to remove:
 - .1 To be completely removed from its supply point to its point of use, unless indicated on drawing.
 - .2 The Contractor must offer all equipment removed to EMSI. These elements become the property of the Contractor if EMSI does not wish to recover them. The Contractor shall dispose of it promptly.
- .3 All existing equipment to remove and relocate:
 - .1 To be relocated to a location specified by redevelopment plans.
 - .2 Where indicated on drawings, wiring of an existing unit to remove and relocate may be reused in whole or in part if the wiring is in excellent condition. However, it must respect the existing function of the wiring by allocating the same function.

1.3 CONTINUITY OF ELECTRIC SERVICE

- .1 Ensure the full continuity of electrical services to building occupants during and after construction.
- .2 Where changes to the existing electrical installation affect areas adjacent to Work, supply and install conduits, conductors, equipment, and accessories necessary for the permanent redistribution of services.

1.4 POWER INTERRUPTION

- .1 Interruptions of power supply should be minimized and shall be implemented in close coordination with the Departmental Representative, who must be notified at least fifteen (15) working days in advance and recalled forty-eight (48) hours before Work begins.
-

- .2 Interruptions of power supply must be planned and documented. The Contractor shall submit for approval a detailed description explaining the actions and work in each step. The duration of each operation must be adequately prepared to enable the Departmental Representative to decide to proceed with the Work.
- .3 In the event of a cons order from the Departmental Representative, the Contractor shall provide the opportunity to restore power supply in operation in less than twenty (20) minutes.

PART 2 - PRODUCTS

2.1 NOT USED

- .1 Not Used.

PART 3 - EXECUTION

3.1 NOT USED

- .1 Not Used.

END OF SECTION
