



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

INVITATION TO TENDER

APPEL D'OFFRES

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Monarch Creek Culvert Replacement – Yoho National Park		
Solicitation No. - No. de l'invitation 5P420-14-5125/A	Date: October 16, 2014	
GETS Reference No. - No de reference de SEAG PW-14-00655900	Amendment No. - N° de la modif. 001	
Solicitation Closes:		
at – á 02:00 PM	on – le October 21, 2014	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Nathaniel Pahl		
Telephone No. - No de téléphone (403) 292-4572	Fax No. – No de FAX: (403) 292-4475	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein – Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone:	_____
Facsimile No. - N° de télécopieur:	_____
Signature	Date

Amendment 1

- Q1.** On the Tender notice it states November 30th but the Tender Documents seem to read December 31. Which is correct?
A1. December 31 is the correct date.
- Q2.** Will Yoho Valley Road and Campsite access road be closed for the work?
A2. Yes.
- Q3.** Is paving of the roadways required?
A3. No. The contractor is not required to pave the roadways. However, the contractor shall bring the road to the same level (grade) as the surrounding road.
- Q4.** Sec 03 30 00.01, 2.1.1 specifies Type 10 cement, while the Additional Specifications Sec 2.1.2 specify Type 50 cement. Which is correct?
A4. Type 50 is correct (i.e., sulphate resisting cement, which is mentioned in Sec 2.1.2). The specification will be revised and provided upon contract award.
- Q5.** Sec 33 42 13, 1.4.2 has Rip Rap paid by unit price, but there is not bid quantity.
A5. Possible bid quantities for Rip-Rap Class 1 were identified for each culvert in Attachment 3 of the bidder package titled "Possible Project materials requirements".
- Q6.** Sec 33 42 13, 1.4.3 has Geotextile paid by unit price, but there is not bid quantity.
A6. Possible bid quantities for Rip-Rap Class 1 were identified for each culvert in Attachment 3 of the bidder package titled "Possible Project materials requirements".
- Q7.** Additional Specifications Sec 2.1.2 specifies 250 MPa concrete. Should this be 25 MPa?
A7. Yes – this should be 25 MPa and not 250 MPa. The specification will be revised and provided upon contract award.
- Q8.** Drawings C06 and C07 show concrete seal under the footings. What is this?
A8. The concrete seal comprises a thin layer of cement equivalent to gravel bedding.

All other terms and conditions remain unchanged.