

Amendment 2 Q & A: J0317 Replace Emergency Generator Set at the Lethbridge Laboratory

Please see the following Question and Answer below:

Question 1:

What is the approximate target date to start and complete this Emergency Generator Replacement ?

Answer 1:

The engineering start date for this initiative is November 19 2014 The engineering completion date will be no later than February 2 2015. The construction start date is May 1 2015 with a completion date of October 1 2015.

Question 2:

Is a civil engineer required ?

Answer 2:

Yes, a civil / structural engineer will be required as the Genset pad and duct bank must be supported by hydraulically driven piles to bedrock. No exceptions.