

The following changes to the tender documents are effective immediately and will form part of the contract documents:

AMENDMENTS TO DRAWINGS

Drawing W-E1 – Electrical Demolition and New

Plan 1:

Clarify that the distance from the existing storage room to existing boiler room for electrical connections is approximately 30 meters south and located near building Grids E/H at Grid 3.

On EP boxes that require gasket replacement, make and manufacture not indicated on device, but appear to be 4" diameter. Contractor shall confirm on-site model, type before ordering.

END OF ADDENDUM NO. 2