



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

INVITATION TO TENDER

APPEL D'OFFRES

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Monarch Creek Culvert Replacement – Yoho National Park		
Solicitation No. - No. de l'invitation 5P420-14-5125/A	Date: October 17, 2014	
GETS Reference No. – No de reference de SEAG PW-14-00655900	Amendment No. - N° de la modif. 002	
Solicitation Closes:		
at – á 02:00 PM	on – le October 23, 2014	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Nathaniel Pahl		
Telephone No. - No de téléphone (403) 292-4572	Fax No. – No de FAX: (403) 292-4475	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein – Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone:	_____
Facsimile No. - N° de télécopieur:	_____
Signature	Date

Solicitation No. - N° de l'invitation
5P420-14-5125/A
Client Ref. No. - N° de réf. du client
5P420-14-5125

Amd. No. - N° de la modif.
002
File Name - Nom du dossier
Monarch Creek Culvert Replacement – Yoho National Park

Buyer - l'acheteur
Nathaniel Pahl

Amendment 2

This amendment is issued to answer additional questions from bidders and to extend the closing date.

The new closing date for this requirement is:

October 23, 2014
2:00 PM MDT

Questions:

Q9. What would the rebar sizing be for the rebar layout shown on DETAIL 2 of drawing C08?

A9. The rebar is 10M.

Q10. The drawings show a cast in place concrete footing but the specifications refer to a precast concrete footing. Which one is correct?

A10. The concrete footing is precast. The drawing is for the precast concrete footing construction.

All other terms and conditions remain unchanged.