

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Regional Manager/Real Property
Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Regional Manager/Real Property Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

Title - Sujet Hastings, ON - Foam Injection	
Solicitation No. - N° de l'invitation EQ754-151106/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client R.055746.001	Date 2014-10-24
GETS Reference No. - N° de référence de SEAG	
File No. - N° de dossier PWL-4-37085 (003)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-10-30	Time Zone Fuseau horaire Eastern Daylight Saving Time EDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Dhanna, Sheila	Buyer Id - Id de l'acheteur pwl003
Telephone No. - N° de téléphone (416) 512-5855 ()	FAX No. - N° de FAX (416) 512-5862
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Trent-Severn Waterway Lock 18 Bridge S Hastings, ON X1X 1X1	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EQ754-151106/A
Client Ref. No. - N° de réf. du client
R.055746.001

Amd. No. - N° de la modif.
001
File No. - N° du dossier
PWL-4-37085

Buyer ID - Id de l'acheteur
pw1003
CCC No./N° CCC - FMS No./N° VME

Question and Answers:

Q: Pertaining to the grouting portion of the project:

There is no indication of quantities nor sufficient geotechnical information to provide such information. Should baseline quantities and unit costs for excess quantities not be included, the contractor must assume 100% risk and therefore exponentially increase the costs to cover such risk. Please include a baseline quantity to work with.

A: Five core holes have been carried out on the existing pier. The depths of the weathered bedrock and anticipated highly weathered rock zone have been provided in the geotechnical report; the rock quality was also provided in the geotechnical report. The Contractor shall estimate the "baseline" quantity based on the information provided in the geotechnical report.

Q: The expansion quantities for the grout specified have two issues:

- 1) The reaction time will be very quick and therefore may not penetrate into the minute cracks and fissures as required
- 2) The expansive qualities of this particular grout has a risk of "fracking" the rock

Will alternative urethanes be allowed that have better penetration and less risk for "fracking"?

A: The Contractor shall bid based on the grout specified and measures should be provided to make sure sufficient crack filling as well as to minimize the risk of "fracking" the rock. However, alternative urethanes can be provided with associated cost as part of the bid documentation for approval by the Engineers.