

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Perimeter Fence Replacement	
<b>Solicitation No. - N° de l'invitation</b> EZ899-150873/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2014-11-05
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-015-7341	
<b>File No. - N° de dossier</b> PWY-4-37156 (015)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2014-11-12</b>	<b>Time Zone</b> Fuseau horaire Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Chan (PWY), Scarlett	<b>Buyer Id - Id de l'acheteur</b> pwy015
<b>Telephone No. - N° de téléphone</b> (604) 775-9382 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> TC - Sandspit Airport - Sandspit, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation

EZ899-150873/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

002

File No. - N° du dossier

PWY-4-37156

Buyer ID - Id de l'acheteur

pw015

CCC No./N° CCC - FMS No/ N° VME

---

Please find Addendum #1 attached.

All other terms and conditions remain unchanged.

THE FOLLOWING CHANGES IN THE TENDER DOCUMENTS ARE EFFECTIVE IMMEDIATELY.  
THIS ADDENDUM WILL FORM PART OF THE CONTRACT DOCUMENTS.

---

Addendum #1

**1) Section – 32 31 13;**

.1 Add the following sentence to clause 32 31 13 1.3.5:

Independent testing certification verifying the fences compliance with ICAO frangibility requirements shall also be included in the submittals.

**2) Questions received by PWGSC Contracting Oct 14, 2014;**

**1) Frangible Fencing**

*We have contacted many different suppliers and have had difficulty finding a fence supplier/ manufacturer that meets the frangibility and radio transparency requirements. Do you have any product names that comply with this specification?*

*Finding a supplier for the frangible fence is proving to be very difficult. Does the designer have a specific supplier or manufacturer in mind?*

Acceptable fence suppliers that are considered to meet the contract specifications include:

- .1 Fibre Net Fibrefence Mesh fencing.
- .2 Exel Composites frangible airport fencing.

**2) Additional Question**

*The fence is 4' high. The drawing does not show barbed wire however the written spec is asking for it. Barbed wire on a 4' high fence is unusual. Please clarify?*

The specifications included details for barbed wire as they are comprehensive for any possible fencing needs. The drawings do not show barbed wire as none is required.

**3) Additional Question**

*On drawing C2 it shows where the new proposed fencing will be but in the fencing schedule it shows that there is a lot more. I have attached a the drawing C2 for your review.*

The lengths of fence detailed on the drawings are accurate. If the drawings being reviewed are plotted on paper 11" x 17" in size, any measurements from the drawings need to be modified for the change in scale, as the drawings were created to be full sized A1 sheets.

**END OF ADDENDUM #1**