



Project Title: Emergency Generator Installation
Building 49
Central Experimental Farm (CEF), Ottawa (Ontario)

Solicitation No: 14-1234

November 5, 2014

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents

Q & A

Q1. Can you please clarify what are the requirements for the duct bank from the generator pad to the building?

A1. In regards to the duct bank details, refer to drawing E02 details 5 and 6, one detail is for under the parking lot which is concrete encased, and the other is for outside of the parking lot which is not concrete encased.

INVITATION TO TENDER

1. At SI04 “Revision of Bid” of the Special Instructions to Bidders (SI):

Delete: A bid may be revised by letter or facsimile in accordance with GI09 of the GENERAL INSTRUCTIONS TO BIDDERS. The facsimile number for receipt of revisions is .

Replace with: A bid may be revised by letter in accordance with GI09 of the GENERAL INSTRUCTIONS TO BIDDERS.

2. At GI09 “Revision of Bid” of the General Instructions to Bidders, paragraph 1:

Delete: A bid submitted in accordance with these instructions may be revised by letter or facsimile provided the revision is received at the office designated for the receipt of bids, on or before the date and time set for the closing of the solicitation. The letter or facsimile shall be on the Bidder's letterhead or bear a signature that identifies the bidders;

Replace with: A bid submitted in accordance with these instructions may be revised by letter provided the revision is received at the office designated for the receipt of bids, on or before the date and time set for the closing of the solicitation. The letter shall be on the Bidder's letterhead or bear a signature that identifies the bidders;

SPECIFICATIONS

1. At Section 26 32 13.04 “Generator and Transfer Switch”, Article 1.1.1:

Add: .2 The Contractor must provide a letter confirming the delivery of the proposed generator and the Automatic Transfer Switch (ATS) within 2 weeks after shop drawings approval. The brand names and models of the proposed equipment must be indicated. This letter must be submitted with the Contractor's bid.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME