

PART 1 - GENERAL

- 1.1 Related Work .1 General requirements: Division 1  
.2 Refer to other specification sections for related work.

PART 2 - PRODUCTS

- 2.1 Wire & Cable .1 Wire and cable shall conform fully to the latest specifications of the Canadian Standards Association (CSA), Electrical & Electronic Manufacturers Association of Canada, (EEMAC) the Insulated Power Cable Engineers Association (IPCEA), and the American Society of Testing Materials (ASTM).  
.2 Wiring on circuits exceeding 50 V to ground shall be of solid copper of 98% conductivity and of full size AWG gauge, minimum #12. Insulation shall be cross linked polyethylene rated 600 V on conductors smaller than No 8 and 1000 volts larger than No. 10. Wiring shall be colour coded as follows:  
  
Phase A - Black  
  
Phase B - Red  
  
Neutral - White  
  
Ground - Green  
.3 Copper conductors sized as indicated with 1000 V insulation of Chemically cross-linked thermosetting polyethylene material rated RW 90: to CSA C22.2 No. 75-M1983.  
.4 Teck Cable; Rated 90°C:  
.1 Conductor: Class B stranded soft copper.  
.2 Insulation: cross-linked polyethylene or ethylene propylene rubber, as approved by CSA on Types RW90 (X-LINK) Minus 40°C or RW90 (EP) Minus 40°C per CSA C22.2, No. 131 (and IPCEA).

2.1 Wire & Cable  
(Cont'd)

- .4 Teck Cable; Rated 90°C: (Cont'd)
- .3 Identification: Surface color coding for sizes up to and including #2 AWG. For sizes larger than #2 AWG, number coding.
  - .4 Grounding Conductor: grounding conductor included in the cable assembly.
  - .5 Multiple conductor cables assembled with suitable fillers and binder tape.
  - .6 Inner Jacket: Polyvinyl Chloride (PVC) heat, flame and moisture resistant jacket, suitable for installation in temperatures down to Minus 40°C.
  - .7 Armour: Aluminum interlocking armour.
  - .8 Outer Jacket: Polyvinyl Chloride (PVC) heat, flame and moisture resistant jacket, black, suitable for installation in temperatures down to Minus 40°C.
  - .9 Size and number of conductors as indicated on the drawings.

2.2 Wire  
Connections

- .1 Splices and joints in circuit wiring shall be made using: a) Mechanical connectors of the copper sleeve pressure crimping type with four indentation and a snap-on nylon insulating cap. Acceptable manufacturers - Buchanan "pressure" connectors, Thomas & Betts.
- .2 Teck Connectors:
- .1 PVC coated teck connectors.
  - .2 Standard of acceptance:
    - .1 T & B Star Series.
- .3 Cable Guards:
- .1 Galvanized steel cable guards to protect cables at all poles, to meet utility standards.

---

PART 3 - EXECUTION

- 3.1 Installation of Wire & Cable
- .1 Identify wiring with permanent indelible identifying marks, either numbered or coloured plastic tapes, on both ends of phase conductors of feeders and branch circuit.
  - .2 Maintain phase sequence and colour coding throughout in accordance with Item 4-036 of the Canadian Electrical Code Part I.
  - .3 Install teck cable as indicated on the drawings.
  - .4 Support teck cable as indicated on drawings and according to requirements of the Canadian Electrical Code. Use corrosion resistant cable supports.
  - .5 All Teck cables to be continuous with no splices.
- 3.2 Wire & Cable Connection
- .1 All connections shall be made electrically and mechanically secure. Sizes of connectors shall be according to manufacturer's recommendations for each wire size and combination of wires.
  - .2 Install PVC coated teck connectors at all teck cable termination points.