

Project No.: F2470-140031

November 21, 2014

---

The following changes to the tender documents are effective immediately and will form part of the contract documents:

---

Thompson, Valerie  
Telephone No. - (204) 983-2372  
Fax No. - (204) 983-7796  
Email: valerie.thompson@pwgsc-tpsgc.gc.ca

#### **ITEM 1) HEADER SPECIFICATIONS:**

Pages 26 to 28 **DELETE** header number and title "*Section 03 41 02 PRECAST CONCRETE BLOCKS*" and **INSERT** in the header of Pages 26 to 28 number and title "**Section 05 14 12 ALUMINUM GANGWAY FABRICATION**".

#### **ITEM 2) CLARIFICATION:**

**Q** : Does the 40 ft ramp require main tubing to be one continuous 40 ft piece?

**A** : One splice would be allowed, however details of the splice need to be approved when shop drawings are submitted in accordance with Section 05 14 12 – part 2.2.1.