

Part 1 General

1.1 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CSA C22.1-12, Canadian Electrical Code, Part 1 (22nd Edition), Safety Standard for Electrical Installations.
 - .2 CAN3-C235-83(R2000), Preferred Voltage Levels for AC Systems, 0 to 50,000 V.
- .2 Electrical and Electronic Manufacturer's Association of Canada (EEMAC)
 - .1 EEMAC 2Y-1-1958, Light Gray Colour for Indoor Switch Gear.
- .3 Institute of Electrical and Electronics (IEEE)/National Electrical Safety Code Product Line (NESC)
 - .1 IEEE SP1122-2000, The Authoritative Dictionary of IEEE Standards Terms, 7th Edition.

1.2 DEFINITIONS

- .1 Electrical and electronic terms: unless otherwise specified or indicated, terms used in these specifications, and on drawings, are those defined by IEEE SP1122.

1.3 DESIGN REQUIREMENTS

- .1 Operating voltages: to CAN3-C235.
- .2 Motors, electric heating, control and distribution devices and equipment to operate satisfactorily at 60 Hz within normal operating limits established by above standard.
 - .1 Equipment to operate in extreme operating conditions established in above standard without damage to equipment.
- .3 Language operating requirements: provide identification nameplates and labels for control items in English.

1.4 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Shop drawings:
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of Nova Scotia, Canada.
 - .2 Submit wiring diagrams and installation details of equipment indicating proposed location, layout and arrangement, control panels, accessories, piping, ductwork, and other items that must be shown to ensure co-ordinated installation.
 - .3 Identify on wiring diagrams circuit terminals and indicate

		internal wiring for each item of equipment and interconnection between each item of equipment.
	.4	Indicate of drawings clearances for operation, maintenance, and replacement of operating equipment devices.
	.5	Submit copies drawings in PDF format and product data to authority having jurisdiction.
	.6	If changes are required, notify Departmental Representative of these changes before they are made.
	.3	Quality Control: in accordance with Section 01 45 00 - Quality Control. Provide CSA certified equipment and material.
	.1	Where CSA certified equipment and material is not available, submit such equipment and material to authority having jurisdiction for approval before delivery to site.
	.2	Submit test results of installed electrical systems and instrumentation.
	.3	Permits and fees: in accordance with General Conditions of contract.
	.4	Submit, upon completion of Work, load balance report as described in 3.6.1.
	.5	Submit certificate of acceptance from authority having jurisdiction upon completion of Work to Departmental Representative.
	.4	Manufacturer's Field Reports: submit to Departmental Representative manufacturer's written report, within 3 days of review, verifying compliance of Work and electrical system and instrumentation testing, as described in PART 3 - FIELD QUALITY CONTROL.
1.5 QUALITY ASSURANCE	.1	Quality Assurance: in accordance with Section 01 45 00 - Quality Control.
	.2	Qualifications: electrical Work to be carried out by qualified, licensed electricians who hold valid Master Electrical Contractor license or apprentices as per the conditions of Provincial Act respecting manpower vocational training and qualification.
	.1	Employees registered in provincial apprentices program: permitted, under direct supervision of qualified licensed electrician, to perform specific tasks.
	.2	Permitted activities: determined based on training level attained and demonstration of ability to perform specific duties.
1.6 DELIVERY, STORAGE AND HANDLING	.1	Material Delivery Schedule: provide Departmental Representative with schedule within 2 weeks after award of Contract.
	.2	Construction/Demolition Waste Management and Disposal: separate

waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

1.7 SYSTEM STARTUP

- .1 Instruct Departmental Representative and operating personnel in operation, care and maintenance of systems, system equipment and components.
- .2 Arrange and pay for services of manufacturer's factory service engineer to supervise start-up of installation, check, adjust, balance and calibrate components and instruct operating personnel.
- .3 Provide these services for such period, and for as many visits as necessary to put equipment in operation, and ensure that operating personnel are conversant with aspects of its care and operation.

1.8 OPERATING INSTRUCTIONS

- .1 Provide for each system and principal item of equipment as specified in technical sections for use by operation and maintenance personnel.
- .2 Operating instructions to include following:
 - .1 Wiring diagrams, control diagrams, and control sequence for each principal system and item of equipment.
 - .2 Start up, proper adjustment, operating, lubrication, and shutdown procedures.
 - .3 Safety precautions.
 - .4 Procedures to be followed in event of equipment failure.
 - .5 Other items of instruction as recommended by manufacturer of each system or item of equipment.
- .3 Print or engrave operating instructions and frame under glass or in approved laminated plastic.
- .4 Post instructions where directed.
- .5 For operating instructions exposed to weather, provide weather-resistant materials or weatherproof enclosures.
- .6 Ensure operating instructions will not fade when exposed to sunlight and are secured to prevent easy removal or peeling.

Part 2 Products

2.1 MATERIALS AND EQUIPMENT

- .1 Provide material and equipment in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Material and equipment to be CSA certified. Where CSA certified material and equipment are not available, obtain special approval

		from authority having jurisdiction before delivery to site and submit such approval as described in 1.4.																												
	.3	Factory assemble control panels and component assemblies.																												
2.2 ELECTRIC MOTORS, EQUIPMENT AND CONTROLS	.1	Verify installation and co-ordination responsibilities related to motors, equipment and controls, as indicated.																												
2.3 WARNING SIGNS	.1	Warning Signs: in accordance with requirements of authority having jurisdiction.																												
	.2	Porcelain enamel signs, minimum size 175 x 250 mm.																												
2.4 WIRING TERMINATIONS	.1	Ensure lugs, terminals, screws used for termination of wiring are suitable for either copper or aluminum conductors.																												
2.5 EQUIPMENT IDENTIFICATION	.1	Identify electrical equipment with nameplates as follows: .1 Nameplates: lamicoid 3 mm, black face, white core, lettering accurately aligned and engraved into core. .2 Sizes as follows: NAMEPLATE SIZES <table><tr><td>Size 1</td><td>10 x 50 mm</td><td>1 line</td><td>3 mm high letters</td></tr><tr><td>Size 2</td><td>12 x 70 mm</td><td>1 line</td><td>5 mm high letters</td></tr><tr><td>Size 3</td><td>12 x 70 mm</td><td>2 lines</td><td>3 mm high letters</td></tr><tr><td>Size 4</td><td>20 x 90 mm</td><td>1 line</td><td>8 mm high letters</td></tr><tr><td>Size 5</td><td>20 x 90 mm</td><td>2 lines</td><td>5 mm high letters</td></tr><tr><td>Size 6</td><td>25 x 100 mm</td><td>1 line</td><td>12 mm high letters</td></tr><tr><td>Size 7</td><td>25 x 100 mm</td><td>2 lines</td><td>6 mm high letters</td></tr></table>	Size 1	10 x 50 mm	1 line	3 mm high letters	Size 2	12 x 70 mm	1 line	5 mm high letters	Size 3	12 x 70 mm	2 lines	3 mm high letters	Size 4	20 x 90 mm	1 line	8 mm high letters	Size 5	20 x 90 mm	2 lines	5 mm high letters	Size 6	25 x 100 mm	1 line	12 mm high letters	Size 7	25 x 100 mm	2 lines	6 mm high letters
Size 1	10 x 50 mm	1 line	3 mm high letters																											
Size 2	12 x 70 mm	1 line	5 mm high letters																											
Size 3	12 x 70 mm	2 lines	3 mm high letters																											
Size 4	20 x 90 mm	1 line	8 mm high letters																											
Size 5	20 x 90 mm	2 lines	5 mm high letters																											
Size 6	25 x 100 mm	1 line	12 mm high letters																											
Size 7	25 x 100 mm	2 lines	6 mm high letters																											
	.2	Labels: embossed plastic labels with 6mm high letters unless specified otherwise.																												
	.3	Wording on nameplates to be approved by Departmental Representative prior to manufacture.																												
	.4	Allow for minimum of twenty-five (25) letters per nameplate.																												
	.5	Nameplates for terminal cabinets and junction boxes to indicate system and/or voltage characteristics.																												
	.6	Terminal cabinets and pull boxes: indicate system and voltage.																												
2.6 WIRING IDENTIFICATION	.1	Identify wiring with permanent indelible identifying markings, coloured plastic tapes, on both ends of phase conductors of feeders and branch circuit wiring.																												

	.2	Maintain phase sequence and colour coding throughout.		
	.3	Colour coding: to CSA C22.1.		
	.4	Use colour coded wires in communication cables, matched throughout system.		
2.7 CONDUIT AND CABLE IDENTIFICATION	.1	Colour code conduits, boxes and metallic sheathed cables.		
	.2	Code with plastic tape or paint at points where conduit or cable enters wall, ceiling, or floor, and at 15 m intervals.		
	.3	Colours: 25 mm wide prime colour and 20 mm wide auxiliary colour.		
		up to 250 V	Prime Yellow	Auxiliary
		up to 600 V	Yellow	Green
		Fire Alarm	Red	
2.8 FINISHES	.1	Shop finish metal enclosure surfaces by application of rust resistant primer inside and outside, and at least two coats of finish enamel.		
	.1	Paint indoor switchgear and distribution enclosures light gray to EEMAC 2Y-1.		
Part 3 Execution				
3.1 INSTALLATION	.1	Do complete installation in accordance with CSA C22.1 except where specified otherwise.		
	.2	Do overhead and underground systems in accordance with CSA C22.3 No.1 except where specified otherwise.		
3.2 NAMEPLATES AND LABELS	.1	Ensure manufacturer's nameplates, CSA labels and identification nameplates are visible and legible after equipment is installed.		
3.3 CONDUIT AND CABLE INSTALLATION	.1	If plastic sleeves are used in fire rated walls or floors, remove before conduit installation.		
	.2	Install cables, conduits and fittings embedded or plastered over, close to building structure so furring can be kept to minimum.		
	.3	Conduit and cables should be run perpendicular or parallel to building lines.		
	.4	Penetrations through walls shall be properly fire sealed.		

**3.4 MOUNTING
HEIGHTS**

- .1 Mounting height of equipment is from finished floor to centreline of equipment unless specified or indicated otherwise.
- .2 If mounting height of equipment is not specified or indicated, verify before proceeding with installation.

**3.5 CO-ORDINATION
OF PROTECTIVE
DEVICES**

- .1 Ensure circuit protective devices such as overcurrent trips, relays and fuses are installed to required values and settings.

**3.6 FIELD QUALITY
CONTROL**

- .1 Load Balance:
 - .1 Measure phase current to panelboards with normal loads (lighting) operating at time of acceptance; adjust branch circuit connections as required to obtain best balance of current between phases and record changes.
 - .2 Measure phase voltages at loads and adjust transformer taps to within 2% of rated voltage of equipment.
 - .3 Provide upon completion of work, load balance report as directed in PART 1 - SUBMITTALS: phase and neutral currents on panelboards, dry-core transformers and motor control centres, operating under normal load, as well as hour and date on which each load was measured, and voltage at time of test.
- .2 Conduct following tests in accordance with Section 01 45 00 - Quality Control.
 - .1 Motors, heaters and associated control equipment including sequenced operation of systems where applicable.
 - .2 Systems: fire alarm system.
 - .3 Insulation resistance testing:
 - .1 Megger circuits, feeders and equipment up to 350 V with a 500 V instrument.
 - .2 Megger 350-600 V circuits, feeders and equipment with a 1000 V instrument.
 - .3 Check resistance to ground before energizing.
- .3 Carry out tests in presence of Departmental Representative.
- .4 Provide instruments, meters, equipment and personnel required to conduct tests during and at conclusion of project.
- .5 Manufacturer's Field Services:
 - .1 Obtain written report from manufacturer verifying compliance of Work, in handling, installing, applying, protecting and cleaning of product and submit Manufacturer's Field Reports as described in 1.4.
 - .2 Provide manufacturer's field services consisting of product

use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.

.3 Schedule site visits, to review Work, as directed in 1.5.

3.7 CLEANING

- .1 Clean and touch up surfaces of shop-painted equipment scratched or marred during shipment or installation, to match original paint.
- .2 Clean and prime exposed non-galvanized hangers, racks and fastenings to prevent rusting.

END OF SECTION

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 26 05 00 – Common Work Results for Electrical.

1.2 REFERENCES

- .1 CSA International CAN/CSA-C22.2 No.18-98(R2003), Outlet Boxes, Conduit Boxes and Fittings.
- .1 CAN/CSA-C22.2 No.65-03(R2008), Wire Connectors (Tri-National Standard with UL 486A-486B and NMX-J-543-ANCE-03).
- .2 Electrical and Electronic Manufacturers' Association of Canada (EEMAC)
- .1 EEMAC 1Y-2-1961, Bushing Stud Connectors and Aluminum Adapters (1200 Ampere Maximum Rating).
- .3 National Electrical Manufacturers Association (NEMA)

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
- .1 Submit manufacturer's instructions, printed product literature and data sheets for wire and box connectors and include product characteristics, performance criteria, physical size, finish and limitations.

1.4 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for wire and box connectors for incorporation into manual.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
- .1 Store materials indoors and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
- .2 Store and protect wire and box connectors from nicks, scratches, and blemishes.
- .3 Replace defective or damaged materials with new.

- .4 Develop Construction Waste Management Plan related to Work of this Section.
- .5 Packaging Waste Management: remove for reuse and return of packaging materials as specified in Construction Waste Management Plan in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

Part 2 Products

2.1 MATERIALS

- .1 Pressure type wire connectors to: CAN/CSA-C22.2 No.65, with current carrying parts of copper sized to fit copper conductors as required.
- .2 Bushing stud connectors: to NEMA to consist of:
 - .1 Connector body and stud clamp for copper conductors.
 - .2 Clamp for copper conductors.
 - .3 Stud clamp bolts.
 - .4 Bolts for copper conductors.
 - .5 Sized for conductors as indicated.
- .3 Clamps or connectors for TECK cable as required to: CAN/CSA-C22.2 No.18.

Part 3 Execution

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for wire and box connectors installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied.

3.2 INSTALLATION

- .1 Remove insulation carefully from ends of conductors and cables and:
 - .1 Install mechanical pressure type connectors and tighten screws. Installation shall meet secureness tests in accordance with CAN/CSA-C22.2 No.65.
 - .2 Install bushing stud connectors in accordance with NEMA.

3.3 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

END OF SECTION

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 26 05 00 – Common Work Results for Electrical.
- .2 Section 26 05 20 – Wire and Box Connectors (0-1000V).
- .3 Section 26 05 34 - Conduits, Conduit Fastenings and Conduit Fittings.

1.2 PRODUCT DATA

- .1 Provide product data in accordance with Section 01 33 00 - Submittal Procedures.

1.3 DELIVERY, STORAGE AND HANDLING

- .1 Packaging Waste Management: remove for reuse and return of packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

Part 2 Products

2.1 BUILDING WIRES

- .1 Conductors: stranded for 10 AWG and larger. Minimum size: 12 AWG.
- .2 Copper conductors: size as indicated, with 1000 V insulation of cross-linked thermosetting polyethylene material rated RW90 XLPE.

2.2 TECK 90 CABLE

- .1 Cable: in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Conductors:
 - .1 Grounding conductor: copper.
 - .2 Circuit conductors: copper, size as indicated.
- .3 Insulation:
 - .1 Cross-linked polyethylene XLPE.
 - .2 Rating: 1000 V.
- .4 Inner jacket: polyvinyl chloride material.
- .5 Armour: interlocking.
- .6 Overall covering: thermoplastic polyvinyl chloride, compliant to applicable Building Code classification for this project.
- .7 Fastenings:
 - .1 One hole malleable iron straps to secure surface cables 50 mm and smaller. Two hole steel straps for cables larger than

50 mm.

.2 Threaded rods: 6 mm diameter to support suspended channels.

.8 Connectors:

.1 Watertight, approved for TECK cable.

Part 3 Execution

3.1 FIELD QUALITY CONTROL

.1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.

.2 Perform tests using method appropriate to site conditions and to approval of Departmental Representative and local authority having jurisdiction over installation.

.3 Perform tests before energizing electrical system.

3.2 GENERAL CABLE INSTALLATION

.1 Terminate cables in accordance with Section 26 05 20 - Wire and Box Connectors - (0-1000 V).

.2 Cable Colour Coding: to Section 26 05 00 - Common Work Results for Electrical.

.3 Conductor length for parallel feeders to be identical.

.4 Lace or clip groups of feeder cables at distribution centres, pull boxes, and termination points.

.5 Wiring in walls: typically drop or loop vertically from above to better facilitate future renovations. Generally wiring from below and horizontal wiring in walls to be avoided unless indicated.

3.3 INSTALLATION OF BUILDING WIRES

.1 Install wiring as follows:

.1 In conduit systems in accordance with Section 26 05 34 - Conduits, Conduit Fastenings and Conduit Fittings.

3.4 INSTALLATION OF TECK90 CABLE (0 -1000 V)

.1 Group cables wherever possible on channels.

.2 Install cable, securely supported by straps.

END OF SECTION

Part 1 General

1.1 RELATED REQUIREMENTS	.1	Section 26 05 00 – Common Work Results for Electrical.
1.2 REFERENCES	.1	American National Standards Institute /Institute of Electrical and Electronics Engineers (ANSI/IEEE)
	.1	ANSI/IEEE 837-02, IEEE Standard for Qualifying Permanent Connections Used in Substation Grounding.
1.3 ACTION AND INFORMATIONAL SUBMITTALS	.1	Submit in accordance with Section 01 33 00 - Submittal Procedures.
	.2	Product Data:
	.1	Submit manufacturer's instructions, printed product literature and data sheets for grounding equipment and include product characteristics, performance criteria, physical size, finish and limitations.
1.4 CLOSEOUT SUBMITTALS	.1	Submit in accordance with Section 01 78 00 - Closeout Submittals.
	.2	Operation and Maintenance Data: submit operation and maintenance data for grounding equipment for incorporation into manual.
1.5 DELIVERY, STORAGE AND HANDLING	.1	Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
	.2	Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
	.3	Storage and Handling Requirements:
	.1	Store materials indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
	.2	Store and protect grounding equipment from nicks, scratches, and blemishes.
	.3	Replace defective or damaged materials with new.
	.4	Develop Construction Waste Management Plan related to Work of this Section.
	.5	Packaging Waste Management: remove for reuse of packaging materials as specified in Construction Waste Management Plan.

Part 2 Products

- 2.1 EQUIPMENT** .1 Insulated grounding conductors: green, copper conductors RW90, size as indicated.

Part 3 Execution

- 3.1 EXAMINATION** .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for grounding equipment installation in accordance with manufacturer's written instructions.
- .1 Visually inspect substrate in presence of Departmental Representative.
- .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
- .3 Proceed with installation only after unacceptable conditions have been remedied.
- 3.2 EQUIPMENT GROUNDING** .1 Install grounding connections to typical equipment included in, but not necessarily limited to following list. Frames of motors and control panels.
- 3.3 FIELD QUALITY CONTROL** .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Perform ground continuity and resistance tests using method appropriate to site conditions and to approval of Departmental Representative and local authority having jurisdiction over installation.
- .3 Perform tests before energizing electrical system.
- .4 Disconnect ground fault indicator during tests.
- 3.4 CLEANING** .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
- .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

- .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

END OF SECTION

Part 1 General

1.1 RELATED SECTIONS

- .1 Section 26 05 00 – Common Work Results for Electrical.

1.2 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
- .2 Remove from site and dispose of all packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal packaging material for recycling in accordance with Waste Management Plan.
- .4 Fold up metal banding, flatten and place in designated area for recycling.

Part 2 Products

2.1 SUPPORT CHANNELS

- .1 U shape, size 41 x 41 mm, 2.5 mm thick, surface mounted.

Part 3 Execution

3.1 INSTALLATION

- .1 Secure equipment to masonry, tile and plaster surfaces with lead anchors or nylon shields.
- .2 Secure equipment to poured concrete with expandable inserts.
- .3 Secure equipment to hollow masonry walls or suspended ceilings with toggle bolts.
- .4 Secure surface mounted equipment with twist clip fasteners to inverted T bar ceilings. Ensure that T bars are adequately supported to carry weight of equipment specified before installation.
- .5 Support equipment, conduit or cables using clips, spring loaded bolts, cable clamps designed as accessories to basic channel members.
- .6 Fasten exposed conduit or cables to building construction or support system using straps.
- .1 One-hole malleable iron straps to secure surface conduits and cables 50 mm and smaller.
- .2 Two-hole steel straps for conduits and cables larger than 50 mm.

- .3 Beam clamps to secure conduit to exposed steel work.
- .7 Suspended support systems.
 - .1 Support individual cable or conduit runs with 6 mm dia threaded rods and spring clips.
 - .2 Support 2 or more cables or conduits on channels supported by 6 mm dia threaded rod hangers where direct fastening to building construction is impractical.
- .8 For surface mounting of two or more conduits use channels at 1 m on centre spacing.
- .9 Provide metal brackets, frames, hangers, clamps and related types of support structures where indicated or as required to support conduit and cable runs.
- .10 Ensure adequate support for raceways and cables dropped vertically to equipment where there is no wall support.
- .11 Do not use wire lashing or perforated strap to support or secure raceways or cables.
- .12 Do not use supports or equipment installed for other trades for conduit or cable support except with permission of other trade and approval of Engineer.
- .13 Install fastenings and supports as required for each type of equipment cables and conduits, and in accordance with manufacturer's installation recommendations.

END OF SECTION

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 26 05 00 – Common Work Results for Electrical.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA International)

- .1 CSA C22.1-12, Canadian Electrical Code, Part 1, 22nd Edition.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.

- .2 Product Data:

- .1 Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.

- .3 Provide shop drawings: in accordance with Section 01 33 00 - Submittal Procedures. Provide drawings stamped and signed by professional engineer registered or licensed in Province of Nova Scotia, Canada.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Waste Management and Disposal:

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

Part 2 Products

2.1 JUNCTION AND PULL BOXES

- .1 Construction: welded steel enclosure.

- .2 Covers Flush Mounted: 25 mm minimum extension all around.

- .3 Covers Surface Mounted: screw-on flat covers.

Part 3 Execution

3.1 JUNCTION, PULL BOXES AND CABINETS INSTALLATION

- .1 Install pull boxes in inconspicuous but accessible locations.

- .2 Mount cabinets with top not higher than 2 m above finished floor except where indicated otherwise.

- .3 Only main junction and pull boxes are indicated. Install additional

pull boxes as required by CSA C22.1.

3.2 IDENTIFICATION

- .1 Equipment Identification: to Section 26 05 00 - Common Work Results for Electrical.
- .2 Identification Labels: size 2 indicating voltage and phase or as indicated.

END OF SECTION

Part 1 General

- | | | |
|---|----|---|
| <u>1.1 RELATED SECTIONS</u> | .1 | Section 26 05 00 – Common Work Results for Electrical. |
| <u>1.2 REFERENCES</u> | .1 | Canadian Standards Association (CSA International) |
| | .1 | CSA C22.2 No. 45-M1981 (R2003), Rigid Metal Conduit. |
| | .2 | CSA C22.2 No. 83-M1985 (R2003), Electrical Metallic Tubing. |
| | .3 | CSA C22.2 No. 56 04, Flexible Metal Conduit and Liquid Tight Flexible Metal Conduit. |
| <u>1.3 SUBMITTALS</u> | .1 | Provide submittals in accordance with Section 01 33 00 - Submittal Procedures. |
| | .2 | Product data: submit manufacturer's printed product literature, specifications and datasheets. |
| | .1 | Submit cable manufacturing data. |
| | .3 | Quality assurance submittals: |
| | .1 | Test reports: submit certified test reports. |
| | .2 | Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties. |
| | .3 | Instructions: submit manufacturer's installation instructions. |
| <u>1.4 WASTE MANAGEMENT AND DISPOSAL</u> | .1 | Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal. |
| | .2 | Place materials defined as hazardous or toxic waste in designated containers. |
| | .3 | Ensure emptied containers are sealed and stored safely for disposal away from children. |

Part 2 Products

- | | | |
|----------------------------|----|--|
| <u>2.1 CONDUITS</u> | .1 | Rigid metal conduit: to CSA C22.2 No. 45, galvanized steel threaded. |
| | .2 | Electrical metallic tubing (EMT): to CSA C22.2 No. 83, with couplings. |
| | .3 | Flexible metal conduit: to CSA C22.2 No. 56, liquid tight flexible |

metal.

2.2 CONDUIT FASTENINGS

- .1 One hole malleable iron straps to secure surface conduits 50 mm and smaller.
 - .1 Two hole steel straps for conduits larger than 50 mm.
- .2 Beam clamps to secure conduits to exposed steel work.
- .3 Channel type supports for two or more conduits at 1 m on centre.
- .4 Threaded rods, 6 mm diameter, to support suspended channels.

2.3 CONDUIT FITTINGS

- .1 Fittings: to CAN/CSA C22.2 No. 18, manufactured for use with conduit specified. Coating: same as conduit.
- .2 Ensure factory "ells" where 90 degrees bends for 25 mm and larger conduits.
- .3 Watertight connectors and couplings for EMT.
 - .1 Set-screws are not acceptable.

2.4 FISH CORD

- .1 Polypropylene.

Part 3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION

- .1 Install conduits to conserve headroom in exposed locations and cause minimum interference in spaces through which they pass.
- .2 Conceal conduits except in mechanical and electrical service rooms.
- .3 Minimum conduit size for lighting and power circuits: 19 mm.
- .4 Bend conduit cold:
 - .1 Replace conduit if kinked or flattened more than 1/10th of its original diameter.
- .5 Mechanically bend steel conduit over 19 mm diameter.
- .6 Field threads on rigid conduit must be of sufficient length to draw conduits up tight.
- .7 Install fish cord in empty conduits.

- .8 Use liquid tight flexible metal conduit for connection to motors or vibrating equipment.
- .9 Remove and replace blocked conduit sections.
 - .1 Do not use liquids to clean out conduits.
- .10 Dry conduits out before installing wire.

3.3 SURFACE CONDUITS

- .1 Run parallel or perpendicular to building lines.
- .2 Locate conduits behind infrared or gas fired heaters with 1.5 m clearance.
- .3 Run conduits in flanged portion of structural steel.
- .4 Group conduits wherever possible on surface channels.
- .5 Do not pass conduits through structural members except as indicated.
- .6 Do not locate conduits less than 75 mm parallel to steam or hot water lines with minimum of 25 mm at crossovers.

3.4 CONCEALED CONDUITS

- .1 Run parallel or perpendicular to building lines.

3.5 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 26 05 00 – Common Work Results for Electrical.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA International).
- .1 CSA-C22.2 No. 5-02, Moulded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures (Tri-national standard with UL 489, tenth edition, and the second edition of NMX-J-266-ANCE).

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit product data in accordance with Section 01 33 00 - Submittal Procedures.

1.4 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Collect and separate for disposal packaging material for recycling in accordance with Waste Management Plan.
- .3 Separate for reuse and recycling and place in designated containers in accordance with Waste Management Plan.

Part 2 Products

2.1 BREAKERS GENERAL

- .1 Moulded-case circuit breakers: to CSA C22.2 No. 5
- .2 Bolt-on moulded case circuit breaker: quick- make, quick-break type, for manual and automatic operation with temperature compensation for 40 degrees C ambient.
- .3 Common-trip breakers: with single handle for multi-pole applications.
- .4 Circuit breakers to have minimum symmetrical rms interrupting capacity rating equal to or greater than panel/switchboard in which they are installed.

2.2 THERMAL MAGNETIC BREAKERS

- .1 Moulded case circuit breaker to operate automatically by means of thermal and magnetic tripping devices to provide inverse time current tripping and instantaneous tripping for short circuit protection.

Part 3 Execution

3.1 INSTALLATION .1 Install circuit breakers as indicated.

END OF SECTION

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 26 05 00 – Common Work Results for Electrical.

1.2 REFERENCES

- .1 CSA International
- .1 CAN/CSA C22.2 No. 94.2-07, Enclosures for Electrical Equipment, Environmental Considerations.
- .2 National Fire Protection Association (NFPA)
- .1 NFPA 20-2010, Standard for the Installation of Stationary Fire Pumps for Fire Protection.
- .3 Underwriters' Laboratories of Canada (ULC)

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
- .1 Submit manufacturer's instructions, printed product literature and data sheets for fire pump controller and accessories and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop Drawings:
- .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of Nova Scotia, Canada.
- .2 Indicate:
- .1 Overall dimensions.
- .2 Fixing support dimensions, details.
- .3 Schematic, wiring, interconnection diagrams.

1.4 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for fire pump controller and accessories for incorporation into manual.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
- .1 Store materials indoors and in accordance with manufacturer's recommendations in clean, dry, well-

ventilated area.

- .2 Store and protect fire pump controller from nicks, scratches, and blemishes.
- .3 Replace defective or damaged materials with new.
- .4 Develop Construction Waste Management Plan related to Work of this Section.
- .5 Packaging Waste Management: remove for reuse of packaging materials as specified in Construction Waste Management Plan in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

Part 2 Products

2.1 ELECTRIC FIRE PUMP-CONTROLLER

- .1 Main combined manual and automatic controller for induction motor-driven fire pump, reduced voltage, auto-transformer starting, accommodated in drip-proof CSA Type 3R Enclosure, completely wired and tested by manufacturer before shipment from factory.
- .2 Dual load interlocked, capable of selecting between two 50 hp pumps in event of failure. Both loads shall not be driven simultaneously.
- .3 Integral automatic transfer switch and disconnecting means.
- .4 To NFPA 20.
- .5 Rating: 50 hp, 600 V, 3 phase, 60 Hz. Normal and alternate power supply.
- .6 Alarm relay to energize audible and visible alarm through independent source of power to indicate circuit breaker open or power failure.
- .7 Alarm and signal devices in controller to indicate trouble on controller and pumping unit, and loss of power.
- .8 2 digital remote annunciator interfaces. 4-line, 20 character continuously back lit with keypad type pushbuttons complete with alarm indication and provision for remote alarm signal output.
- .9 Label as "FIRE PUMP CONTROLLER" in accordance with Section 26 05 00 – Common Work Results for Electrical.
- .10 Standard of Acceptance: Tornatech Model GPR+GPU.
- .11 Bill of materials shall include but not limited to:
 - .1 Contactor
 - .2 Contactor for Start Logic
 - .3 Alarm Bell
 - .4 Auto Transformer
 - .5 Circuit Breaker 100A
 - .6 Disconnect Switch Handle Assembly

- .7 Power Relay
- .8 Current Transformer
- .9 Enclosure
- .10 I/O Logic Board
- .11 Isolating Switch 100A
- .12 Pressure Sensor
- .13 Surge Arrestor 3 Phase
- .14 Solenoid Valve
- .15 Automatic Transfer Switch
- .16 I/O Automatic Transfer Switch Board
- .17 ViZiTouch Main Board
- .18 Transformer 50 VA
- .19 Transformer 25 VA

Part 3 Execution

3.1 EXAMINATION

- .1 Verification of Conditions: verify conditions of substrates previously installed under other Sections or Contracts are acceptable for fire pump controller installation in accordance with manufacturer's written instructions.
 - .1 Inform Departmental Representative of unacceptable conditions immediately upon discovery.

3.2 INSTALLATION

- .1 Install fire pump controller and system to requirements of authority having jurisdiction. Including installation of annunciator and alarm signal to existing remote annunciator.
- .2 Program fire pump controller as required, including regular testing schedules as chosen by owner.
- .3 Connect make-up pressure pump to emergency supply, using properly supported rigid conduit.

3.3 FIELD QUALITY CONTROL

- .1 Conduct acceptance tests on complete system.
- .2 Submit written statement that work covered in this installation has been completed and tested to approved plans and specifications, by authority having jurisdiction together with request for approval and acceptance testing.
- .3 System is subject to final inspection, test and approval by authority having jurisdiction.
- .4 System is subject to an operational test witnessed by authority having jurisdiction.
- .5 Participate in fire pump controller commissioning activities in accordance with manufacturer's recommendations and Section 01 91 13 – General Commissioning Requirements.

- .6 Commissioning activities are to include but are not limited to:
 - .1 Simulated start-up for fire event.
 - .2 Emergency power operation testing.
 - .3 Dual pump duty cycle operation testing.
- .7 Provide fire pump controller operation and maintenance training to facility staff in accordance with manufacturer's recommendations and Section 01 79 00 – Demonstration and Training.

3.4 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

3.5 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by fire pump control installation.

END OF SECTION