

1.1 DESCRIPTION OF WORK

- .1 Site of Work is at: Heating Plant at Agriculture and Agri-food Canada Kentville Research Facility at 32 Main Street, Kentville, Nova Scotia.
- .2 In general, work under this contract includes but is not limited to the supply of all equipment, material, services and personnel required to complete the following:
 - .1 Replacement of existing diesel fire pump with new electric fire pump, complete with new dual fire pump controller and dedicated transfer switches.
 - .2 Removal of existing electric fire pump controller and associated electrical.
 - .3 Removal, purging of contents and associated lines and disposal of an above ground diesel storage tank in accordance with authority having jurisdiction.
 - .4 All permits, licenses, certificates as well as permission, approval or letters of authority must be submitted prior to commencement of work.
 - .5 Mobilization and Demobilization:
 - .1 Mobilization and demobilization will not be measured for payment and is considered incidental to the contract.
 - .2 Mobilization and demobilization will involve mobilization to and from the site as well as requirements on the site.
 - .6 Site maintenance is considered incidental to the work. No separate payment shall be made for site maintenance.
 - .7 Provision of Site Security inclusive of safety signage, enclosures, gates, barricades and personnel is considered incidental to the work. No separate payment shall be made for provision of site security.

1.2 FAMILIARIZATION WITH SITE

- .1 Before submitting a bid, it is recommended that bidders visit the site to review and verify the form, nature and extent of the work, materials needed, the means of access and the temporary facilities required to perform the Work.

1.3 CODES AND STANDARDS

- .1 Perform work in accordance with the National Building Code of Canada (of latest edition as adopted by the province and municipality of the work location) and any other code of provincial or local application, including all amendments up to bid closing date, provided that in any case of conflict or discrepancy, the more stringent requirement shall apply.

- .2 Perform electrical work in accordance with CSA C22.1-2006. Use only licensed electricians to carry out such work.
- .3 Materials and workmanship must meet or exceed requirements of specified standards, codes and referenced documents.

1.4 SETTING OUT
WORK

- .1 Assume full responsibility for and execute complete layout of work.
- .2 Coordinate with facilities existing service providers where required (ex.: sprinkler system, fire panel, etc.).

1.5 COST BREAKDOWN

- .1 Before submitting first progress claim submit breakdown of Contract price in detail as directed by Departmental Representative. The following information is required with application of progress payment.
 - .1 Submit to Departmental Representative, with application for Progress Payment, all verification of work for with application for payment is submitted. The required Material Removal Log and Weigh slips from the disposal facility(ies) shall be deemed acceptable verification.
 - .2 The required Material Removal Log to record items such as: time of departure, type of material, type of transport, destination.
- .2 List items of work numerically following the same division/section number system of the specification manual and thereafter sub-divide into major work components and building systems as directed by Departmental Representative.
- .3 Upon approval, cost breakdown will be used as basis for progress payment.

1.6 MEASUREMENT FOR
PAYMENT

- .1 Refer to Section 01 22 00 - Measurement and Payment.

1.7 CONTRACTOR'S
USE OF THE SITE

- .1 Use of site: limited to areas of work being carried out and as follows:
 - .1 Access to all exits must be maintained during normal working hours and where work shall be performed outside of the

- normal working hours. Access to heating plant will be via the Overhead door or the front door. AAFC will be responsible for opening and closing of the doors.
- .2 Normal Working Hours defined as:
 - .1 Monday to Friday from 8:00AM to 4:30PM.
 - .2 Work outside of Normal Working Hours must be approved by the Departmental Representative. Commissionaire services are required for security purposes for work outside of Normal Working Hours at the contractor's expense.
 - .3 Limited on-site parking is permitted for construction work force at the construction site. Provide signage to clearly define and separate construction work force parking from the Facility staff parking.
 - .4 Limited storage on site is permitted within the construction areas, provided that operations at the Facility are not restricted.
 - .5 Do not unreasonably encumber the site with materials and equipment. Move materials and/or equipment as directed by the Departmental Representative which interferes with Facility operations, or with ongoing construction operations of other contracts at the site.
 - .6 Move stored materials, products and/or equipment which interfere with the operations of the Facility and the Departmental Representative.
 - .7 Maintain mechanical, electrical, and other services to all existing structures on a continuous basis. Disruptions to services are not permitted.
 - .8 Maintain the access to the Heating Plant for the duration of the Contract. Access for emergency vehicles is to be kept open at all times.

1.8 PROJECT MEETINGS

- .1 Schedule and administer project meetings, held on a minimum bi-weekly basis, for entire duration of work and more often when directed by Departmental Representative as deemed necessary due to progress of work on particular situation.
- .2 Prepare agenda for meetings.
- .3 Notify participants in writing 4 days in advance of meeting date.
 - .1 Ensure attendance of all subcontractors.
 - .2 Departmental Representative will provide list of other attendees to be notified.
- .4 Hold meetings at project site or where approved by Departmental Representative.

- .5 Preside at meetings and record minutes.
 - .1 Indicate significant proceedings and decisions. Identify action items by parties.
 - .2 Each meeting shall review schedule and progress to date.
 - .3 Distribute to participants by mail or by facsimile within 3 calendar days after each meeting.
 - .4 Make revisions as directed by Departmental Representative.
 - .5 Departmental Representative will advise whether submission of minutes by e-mail is acceptable. Decision will be based on compatibility of software among participants.

1.9 DOCUMENTS
REQUIRED

- .1 Maintain at job site, one copy each of the following:
 - .1 Contract Drawings
 - .2 Specifications
 - .3 Addenda
 - .4 Change Orders
 - .5 Other modifications to Contract
 - .6 Field Test Reports
 - .7 Copy of Approved Work Schedule
 - .8 Site-Specific Health and Safety Plan and other safety-related documents
 - .9 Environmental Protection Plan
 - .10 Other documents as stipulated elsewhere in the Contract Documents.

1.10 PERMITS

- .1 Obtain and pay for building permit, certificates, licenses and other permits as required by municipal, provincial and federal authorities.
- .2 Provide appropriate notifications of project to municipal and provincial inspection authorities having jurisdiction.
- .3 Obtain compliance certificates as prescribed by legislative and regulatory provisions of municipal, provincial and federal authorities as applicable to the performance of work.
- .4 Submit to Departmental Representative, copy of application forms and approval documents received from above referenced authorities.

1.11 EXISTING
SERVICES

- .1 Where work involves breaking into or connecting to existing services, carry out work at times directed by governing authorities, with minimum of disturbance to Facility operations.
- .2 Before commencing work, establish location and extent of service lines in area of work and notify Departmental Representative of findings.
- .3 Submit schedule to and obtain approval from Departmental Representative for any shut-down or closure of active service or facility. This includes disconnection of electrical power and communication services to tenant's operational areas. Adhere to approved schedule and provide notice to affected parties. Provide minimum 48 hours' notice for any closure of active service.
- .4 Provide temporary services when directed by Departmental Representative to maintain critical building or site service systems.
- .5 Provide adequate bridging over trenches which cross sidewalks or roads to permit normal traffic.
- .6 Where unknown services are encountered, immediately advise Departmental Representative and confirm findings in writing.
- .7 Protect, relocate or maintain existing active services as required. When inactive services are encountered, cap off in manner approved by authorities having jurisdiction over service. Record locations of maintained, re-routed and abandoned service lines.

1.12 ACCEPTANCES

- .1 Notify Departmental Representative in writing when work is complete and ready for final inspection.
 - .1 Make a check of all work and correct all discrepancies, defects and outstanding work before sending notification.
- .2 Accompany Departmental Representative during final inspection.
- .3 Rectify all defects, faults and outstanding items identified by Departmental Representative during inspection.
- .4 Be aware that the Final Certificate of Completion will not be issued until such time that Contractor has fully completed and turned over all specified as-built project documents, training and maintenance manuals, test results and any guarantee/warranty certificates as issued by any manufacturer.

1.13 WORK
COORDINATION

- .1 Contractor is responsible for coordinating the work of the various trades and pre-determining where the work of such trades interfaces with each other.
 - .1 Designate one person from own employ having overall responsibility to review contract documents and shop drawings, plan and manage such coordination.
 - .2 Contractor shall convene meetings between trades whose work interfaces and ensure that they are fully aware of the areas and the extent of where interfacing is required.
 - .1 Provide each trade with the plans and specs of the interfacing trade, as required, to assist them in planning and carrying out their respective work.
 - .2 Develop coordination drawings when deemed required illustrating potential interference between work of various trades and distribute to all affected parties including structural trade.
 - .1 Pay particularly close attention to overhead work and within or near to building structural elements.
 - .2 Coordination drawings to identify all building elements, service lines, rough-in points and indicate from where various services are coming.
 - .3 Review coordination drawings at purposely called meetings. Have subcontractors sign-off on drawings and publish minutes of each meeting.
 - .4 Plan and coordinate work in such a way to minimize quantity of service line offsets.
 - .5 Submit copy of coordination drawings and meeting minutes to Departmental Representative.
- .3 Submission of shop drawings and ordering of prefabricated equipment or prebuilt components shall only occur once coordination meeting for such items has taken place between trades and all conditions affecting the work of the interfacing trades has been made known and accounted for.
- .4 Work Cooperation:
 - .1 Ensure cooperation between trades in order to facilitate the general progress of the work and avoid situations of spatial interference.
 - .2 Ensure that each trade provides all other trades reasonable opportunity for the completion of the work and in such a way as to prevent unnecessary delays, cutting, patching and the need to remove and replace completed work.
- .5 Public Works and Government Services Canada will not be responsible for or held accountable for any extra costs incurred as a result of the failure to carry out coordination work. Disputes between the various trades as a result of their not being informed of the areas

and extent of interface work shall be the sole responsibility of the General Contractor and shall be resolved by him at no extra cost to the Contract.

1.14 SANITARY
SYSTEM AND
SANITARY WASTE
TREATMENT

- .1 Existing site sanitary system and all sanitary lines shall remain fully functional throughout the duration of the contract.

1.15 OWNER'S
OPERATIONS AT THE
SITE

- .1 Where the Owners normal operations at the site are negatively impacted by the operations of the Contractor, the Contractor shall modify, reschedule or otherwise change such construction operations so the Owner's operations can be maintained. No additional compensation under the Contract will be paid to the Contractor as a result of the adjustment of construction operations.

1.16 DEMOLITION
PHASING

- .1 Removal and proper disposal of hazardous materials see Section 01 33 00 - Submittals.

1.17 BUILDING
SMOKING
ENVIRONMENT

- .1 Comply with smoking restrictions.

1.18 ASBESTOS
DISCOVERY

- .1 Demolition of spray or trowel-applied asbestos can be hazardous to health. Should material resembling spray or trowel-applied asbestos be encountered in course of work, stop work and notify Departmental Representative immediately. Do not proceed with relevant work until written instructions have been received from Departmental Representative.

1.19 INSPECTION AND
TESTING

- .1 The Departmental Representative may employ an inspector and/or testing company to ensure work conforms with contract.

1.20 SITE CONDITIONS

- .1 Protect and/or maintain existing site conditions of areas not directly affected by work under this contract.

1.21 PROGRESSIVE
CLEANING

- .1 Maintain site in tidy condition, free from accumulation of waste products and debris.
- .2 Make arrangements with and obtain permits from authorities having jurisdiction for disposal of waste and debris.
- .3 Waste Management
 - .1 Refer to section 01 74 21 - Construction/ Demolition Waste Management and Disposal.

END OF SECTION

1.1 SUBMITTALS

- .1 Upon acceptance of bid and prior to commencement of work, submit to Departmental Representative the following work management documents:
 - .1 Work Schedule as specified herein.
 - .2 Hazardous Waste Management Plan as specified in Section 01 74 21.
 - .3 Environmental Plan specified in section 01 35 43.
 - .4 Site-Specific Health and Safety Plan specified in Section 01 35 29.
 - .5 Hot Work procedures specified in Section 01 35 24.
 - .6 Lockout procedures specified in Section 01 35 25.

1.2 WORK SCHEDULE

- .1 Upon acceptance of bid submit:
 - .1 Work schedule within 7 calendar days of contract award.
- .2 Schedule to indicate all calendar dates from commencement to completion of all work within the time stated in the accepted bid.
- .3 Provide sufficient details in schedule to clearly illustrate entire implementation plan, depicting efficient coordination of tasks and resources, to achieve completion of work on time and permit effective monitoring of work progress in relation to established milestones.
- .4 Work schedule content to include as a minimum the following:
 - .1 Bar (GANTT) Charts, indicating all work activities, tasks and other project elements, their anticipated durations, planned dates for achieving key activities and major project milestones supported with;
 - .2 Written narrative on key elements of work illustrated in bar chart, providing sufficient details to demonstrate a reasonable implementation plan for completion of project within designated time.
 - .3 Generally Bar Charts derived from commercially available computerized project management system are preferred but not mandatory.
- .5 Detailed work schedule;
 - .1 Prepare by use of Critical Path Method (CPM) indicating:
 - .1 Complete and detailed sequence of all construction activities. Show projected start and completion dates for each activity.
 - .2 Number of calendar days required to carry out each activity.
 - .3 Critical Path items with resulting critical dates, non-critical activities and resulting float time.
 - .4 Actual workdays from non-working days such as

- weekend and statutory days etc.
- .5 Projected and actual percentage of work completed for each major work activity.
- .2 Prepare CPM schedule by use of well recognized and widely used electronic software. Submit copy of schedule in paper format and one electronic version for each submission.
- .3 Accompany CPM with written narrative as required and in sufficient detail to fully describe work and demonstrate a reasonable implementation plan for completion of project within designated time.
- .6 Work schedule must take into consideration and reflect the work phasing, required sequence of work, special conditions and operational restrictions as specified below.
- .7 Schedule work in cooperation with the Departmental Representative. Incorporate within Work Schedule, items identified by Departmental Representative during review of schedule.
- .8 Completed schedule shall be approved by Departmental Representative. When approved, take necessary measures to complete work within scheduled time. Do not change schedule without Departmental Representative's approval.
- .9 Ensure that all subtrades and subcontractors are made aware of the work restraints and operational restrictions specified.
- .10 Schedule Updates:
- .1 Submit when requested by Departmental Representative.
- .2 Provide information and pertinent details explaining reasons for necessary changes to implementation plan.
- .3 Identify problem areas, anticipated delays, impact on schedule and proposed corrective measures to be taken.
- .11 Departmental Representative will make interim reviews and evaluate progress of work based on approved schedule. Frequency of such reviews will be as decided by Departmental Representative. Address and take corrective measures on items identified by reviews and as directed by Departmental Representative. Update schedule accordingly.
- .12 In every instance, change or deviation from the Work Schedule, no matter how minimal the risk or impact on safety or inconvenience to tenant or public might appear, will be subject to prior review and approval by the Departmental Representative.

1.3 PROJECT PHASING

- .1 Be aware that Facility and tenants must be kept operational for the full duration of work of this contract. Building services to areas under use by tenants must also be maintained at all times during the Facility's operational hours and as specifically defined in operational restrictions specified in this section.
- .2 Perform work of this contract in individual phases in the following sequence of activities:
 - .1 Isolate and remove existing diesel fire pump and associated infrastructure, including cutting of existing housekeeping pad.
 - .2 Install new electric fire pump and dual fire pump controller.
 - .3 Commission new electric fire pump and dual fire pump controller.
 - .4 Disconnect existing electric fire pump from existing electric fire pump controller.
 - .5 Reconnect existing electric fire pump to new dual fire pump controller. Commission dual pump operation of new dual fire pump controller
 - .6 Remove existing electric fire pump controller, to be returned to Departmental Representative.
- .3 Unless indicated or approved otherwise, complete all work of a particular phase prior to commencement of another phase. Obtain Departmental Representative's permission prior to moving between phases.
- .4 Phasing of work is sequenced to avoid simultaneous shutdown of both fire pumps. Any requirement for interruption to fire protections services is to be approved by Departmental Representative and coordinated with service provider.

1.4 OPERATIONAL
RESTRICTIONS

- .1 Permit Departmental Representative and any inspection/testing company employed by the Departmental Representative to collect samples as directed. Contractor to assist in collection of samples.
- .2 Comply with all regulations and authorities having jurisdiction.
- .3 Safety Signage:
 - .1 Provide on-site, and erect as required during progress of work, proper bilingual signage, mounted on self-supporting stands, warning the public and building occupants of construction activities in progress and alerting need to exercise caution in proceeding through disturbed areas.
 - .2 Signage to be professionally printed and mounted on wooden backing, coloured and to express messages as directed by the Departmental Representative.
 - .3 Generally maximum size of sign should be in the order of 1.0

square meters.
.4 Include costs for the supply and installation of these signs in the lump sum bid price.

- .4 Safety Barriers:
- .1 Erect barriers as required to restrict access to the construction sites during progress of work. Coordination will be crucial when operating the access panel in the heating plant floor for moving equipment in and out of the fire pump room.
 - .2 Include costs for the supply and installation of these barriers in the lump sum bid price.

1.5 PROJECT MEETINGS

- .1 Schedule and administer project meetings, held on a minimum bi-weekly basis, for entire duration of work and more often when directed by Departmental Representative as deemed necessary due to progress of work or particular situation.
- .2 Contractor to prepare agenda for meetings.
- .3 Contractor to notify participants in writing 4 days in advance of meeting date.
 - .1 Ensure attendance of all subcontractors.
 - .2 Departmental Representative will provide list of other attendees to be notified.
- .4 Hold meetings at project site or where approved by Departmental Representative.
- .5 Contractor to preside at meetings and record minutes.
 - .1 Indicate significant proceedings and decisions. Identify action items by parties.
 - .2 Distribute to participants by mail or by facsimile. Departmental Representative will advise whether submission of minutes by Email is acceptable. Decision will be based on compatibility of software among participants.
 - .3 Make revisions as directed by Departmental Representative.

1.6 WORK COORDINATION

- .1 The General Contractor is responsible for coordinating the work of the various trades and predetermining where the work of such trades interfaces with each other.
 - .1 Designate one person from own employ having overall responsibility to review contract documents and shop drawings, plan and manage such coordination.

- .2 The General Contractor shall convene meetings between trades whose work interfaces and ensure that they are fully aware of the areas and the extent of where interfacing is required.
 - .1 Provide each trade with the plans and specs of the interfacing trade, as required, to assist them in planning and carrying out their respective work.
 - .2 Develop coordination drawings when deemed required illustrating potential interference between work of various trades and distribute to all affected parties including structural trade.
 - .1 Pay particularly close attention to overhead work above ceilings and within or near to building structural elements.
 - .2 Coordination drawings to identify all building elements, services lines, rough-in points and indicate from where various services are coming.
 - .3 Review coordination drawings at purposely called meetings. Have subcontractors sign-off on drawings and publish minutes of each meeting.
 - .4 Plan and coordinate work in such a way to minimize quantity of service line offsets.
 - .5 Submit copy of coordination drawings and meeting minutes to Departmental Representative for information purposes.
- .3 Work Cooperation:
 - .1 Ensure cooperation between trades in order to facilitate the general progress of the work and avoid situations of spatial interference.
 - .2 Ensure that each trade provides all other trades reasonable opportunity for the completion of the work and in such a way as to prevent unnecessary delays, cutting, patching and the need to remove and replace completed work.
- .4 No extra costs to the Contract will be considered by the Departmental Representative as a result of Contractor's failure to effectively coordinate all portions of the Work. Disputes between the various trades as a result of their not being informed of the areas and extent of interface work shall be the sole responsibility of the General Contractor to be resolved at own cost.

1.7 RECORDS OF
CONSTRUCTION

- .1 Refer to Section 01 78 00 - Closeout Submittals.

1.8 INSPECTION
COOPERATION

- .1 Cooperate with Departmental Representative on inspection of work.

- .2 Provide assistance when requested and any necessary equipment required.

END OF SECTION

PART 1 - GENERAL

1.1 GENERAL

- .1 The Lump Sum prices are full compensation for the work necessary to complete each item in the Contract in the Form of Tender. The prices bid are complete and separate from other or related bid items.
- .2 In the case of a conflict between the instructions for measurement and payment contained in Section 01 22 00 and another Section of the Specifications, the requirements of Section 01 22 00 shall govern.
- .3 No separate payment will be made for:
 - .1 Unauthorized work beyond the limits shown.
 - .2 Contractor's specified Quality Control testing.
 - .3 Layout of work.

1.2 LUMP SUM WORK

- .1 The tendered price for lump sum work includes all items listed within the specification and drawings. Price includes all labour, materials, and equipment for complete supply and installation of the work.
- .2 Mobilization / Demobilization including all equipment, temporary facilities, security, maintenance, and cleaning of site, securing all necessary regulatory permits, insurance and bonding, establishing health and safety protocol.
- .3 All demolition, material disposal (hazardous and non-hazardous), service disconnection / reconnection, site excavation, construction, building renovation, repairs and improvements and site restoration and landscaping, as contained in the specifications.

PART 2 - PRODUCTS

2.1 NOT USED

- .1 Not Used.

PART 3 - EXECUTION

3.1 NOT USED .1 Not Used.

END OF SECTION

PART 1 - GENERAL

1.1 RELATED
SECTIONS

- .1 Section 01 78 00 - Closeout Submittals.
- .2 Section 01 74 21 - Construction/Demolition, Waste Management and Disposal.

1.2 SUBMITTAL
GENERAL
REQUIREMENTS

- .1 Submit to Departmental Representative for review requested submittals specified in various sections of the specifications including shop drawings, samples, permits, compliance certificates, test reports, work management plans and other data required as part of the work.
- .2 Submit with reasonable promptness and in orderly sequence so as to allow for Departmental Representative's review and not cause delay in Work. Failure to submit in ample time will not be considered sufficient reason for an extension of Contract time and no claim for extension by reason of such default will be allowed.
- .3 Do not proceed with work until relevant submissions have been reviewed.
- .4 Where items or information is not produced in SI Metric units, provide soft converted values.
- .5 Verify field measurements and affected adjacent Work are coordinated.
- .6 Notify Departmental Representative, in writing at time of submission, identifying deviations from requirements of Contract Documents stating reasons for deviations.
- .7 Contractor's responsibility for errors, omissions or deviations in submission from requirements of Contract Documents is not relieved by Departmental Representative's review.

1.3 ACTION AND
INFORMATION
SUBMITTALS

- .1 Prepare and submit the following prior to project start-up:
 - .1 Submit 3 copies of Environmental Protection Plan.
 - .2 Refer to Section 01 35 43 - Environmental Procedures for the requirements of the Environmental Protection Plan.
- .2 Submit 3 copies of Site-Specific Health and Safety Plan.
 - .1 Refer to Section 01 35 29 - Health and Safety Requirements

for the requirements of the Site-Specific Health and Safety Plan.

- .3 Prepare and submit the following prior to notification to Departmental Representative of Substantial Completion:
 - .1 Submit color photograph(s) of all work.
 - .2 Submit as-built construction drawings.
 - .3 Submit a copy of the Material Removal Log, and all Weigh bills from disposal facilities.

1.4 PHOTOGRAPHIC DOCUMENTATION

- .1 Submit electronic copy of colour digital photography in jpg format, standard resolution as directed by Departmental Representative.
- .2 Project identification: name and number of project and date of exposure indicated.
- .3 Number of viewpoints:
 - .1 Viewpoints and their location as determined by Departmental Representative.
- .4 Frequency of photographic documentation: as directed by Departmental Representative.
 - .1 Upon completion of: of Work, and as directed by Departmental Representative.

END OF SECTION

- 1.1 SECTION INCLUDES
- .1 Fire Safety Requirements
 - .2 Hot Work Permit
 - .3 Existing Fire Protection and Alarm Systems
- 1.2 RELATED WORK
- .1 Section 01 35 29 Health and Safety Requirements.
- 1.3 REFERENCES
- .1 Fire Protection Standards issued by Fire Protection Services, Labour Program Division of Service Canada:
 - .1 FCC No. 301-June 1982 Standard for Construction Operations.
 - .2 FCC No. 302-June 1982 Standard for Welding and Cutting.
 - .2 FCC standards may be viewed at:
 - .1 <http://www.hrsdc.gc.ca/en/lp/lo/fp/standards/commissioner.shtml>
 - .2 Fire Protection Services - Atlantic Region office, Halifax, N.S., Tel. (902) 426-6053.
- 1.4 DEFINITIONS
- .1 Hot Work defined as:
 - .1 Welding work
 - .2 Cutting of materials by use of torch or other open flame devices
 - .3 Grinding with equipment which produces sparks.
 - .4 Use of open flame torches such as for roofing work.
- 1.5 SUBMITTALS
- .1 Submit copy of Hot Work Procedures and sample of Hot Work permit to Departmental Representative for review, within 14 calendar days of acceptance of bid.
 - .2 Submit in accordance with section 01 33 00.
- 1.6 FIRE SAFETY REQUIREMENTS
- .1 Implement and follow fire safety measures during Work. Comply with following:
 - .1 National Fire Code.
 - .2 Fire Protection Standards FCC 301 and FCC 302.
 - .3 Federal and Provincial Occupational Health and Safety Acts and Regulations.

- .2 In event of conflict between any provisions of above authorities the most stringent provision will apply. Should a dispute arise in determining the most stringent requirement, Departmental Representative will advise on the course of action to be followed.

1.7 HOT WORK
AUTHORIZATION

- .1 Obtain Departmental Representative's written "Authorization to Proceed" before conducting any form of Hot Work on site.
- .2 To obtain authorization submit to Departmental Representative:
 - .1 Contractor's typewritten Hot Work Procedures to be followed on site as specified below.
 - .2 Description of the type and frequency of Hot Work required.
 - .3 Sample Hot Work Permit to be used.
- .3 Upon review and confirmation that effective fire safety measures will be implemented and followed during performance of hot work, Departmental Representative will give authorization to proceed as follows:
 - .1 Issue one written "Authorization to Proceed" covering the entire project for duration of work or;
 - .2 Subdivide the work into pre-determined, individual activities, each activity requiring a separately written authorization to proceed.
- .4 Requirement for individual authorization will be based on:
 - .1 Nature or phasing of work;
 - .2 Risk to Facility operations;
 - .3 Quantity of various trades needing to perform hot work on project or;
 - .4 Other situation deemed necessary by Departmental Representative to ensure fire safety on premises.
- .5 Do not perform any Hot Work until receipt of Departmental Representative's written "Authorization to Proceed" for that portion of work.
- .6 In tenant occupied Facility, coordinate performance of Hot Work with Facility Manager through the Departmental Representative. When directed, perform Hot Work only during non-operative hours of the Facility. Follow Departmental Representative's directives in this regard.

1.8 HOT WORK
PROCEDURES

- .1 Develop and implement safety procedures and work practises to be followed during the performance of Hot Work.
- .2 Hot Work Procedures to include:
 - .1 Requirement to perform hazard assessment of site and immediate work area beforehand for each hot work event in accordance with Safety Plan specified in section 01 35 29.
 - .2 Use of a Hot Work Permit system with individually issued permit by Contractor's Superintendent to worker or subcontractor granting permission to proceed with Hot Work.
 - .3 Permit required for each Hot Work event.
 - .4 Designation of a person on site as a Fire Safety Watcher responsible to conduct a fire safety watch for a minimum duration of 60 minutes immediately following the completion of the Hot Work.
 - .5 Compliance with fire safety codes, standards and occupational health and safety regulations specified.
 - .6 Site specific rules and procedures in force at the site as provided by the Facility Manager.
- .3 Generic procedures, if used, must be edited and supplemented with pertinent information tailored to reflect specific project conditions. Label document as being the Hot Work Procedures for this contract.
- .4 Procedures shall clearly establish responsibilities of:
 - .1 Worker performing hot work,
 - .2 Person issuing the Hot Work Permit,
 - .3 Fire Safety Watcher,
 - .4 Subcontractor(s) and Contractor.
- .5 Brief all workers and subcontractors on Hot Work Procedures and of Permit system. Stringently enforce compliance.

1.9 HOT WORK
PERMIT

- .1 Hot Work Permit to include the following:
 - .1 Project name and project number;
 - .2 Building name and specific room or area where hot work will be performed;
 - .3 Date of issue;
 - .4 Description of hot work type needed;
 - .5 Special precautions to be followed, including type of fire extinguisher needed;
 - .6 Name and signature of permit issuer.
 - .7 Name of worker to which the permit is issued.
 - .8 Permit validity period not to exceed 8 hours. Indicate start time/date and termination time/date.

- .9 Worker's signature with time/date of hot work completion.
- .10 Stipulated time period of safety watch.
- .11 Fire Safety Watcher's signature with time/date.

- .2 Permit to be typewritten form. Industry Standard forms shall only be used if all data specified above is included on form.
- .3 Each Hot Work Permit to be completed in full, signed and returned to Contractor's Superintendent for safe keeping on site.

1.10 FIRE PROTECTION
AND ALARM SYSTEMS

- .1 Fire protection and alarm systems shall not be:
 - .1 Obstructed.
 - .2 Shut-off, unless approved by Departmental Representative.
 - .3 Left inactive at the end of a working day or shift.
- .2 Do not use fire hydrants, standpipes and hose systems for purposes other than firefighting.
- .3 Costs incurred, from the fire department, Facility owner and tenants, resulting from negligently setting off false alarms will be charged to the Contractor in the form of financial progress payment reductions and holdback assessments against the Contract.

1.11 DOCUMENTS
ON SITE

- .1 Keep Hot Work Permits and Hazard assessment documentation on site for duration of Work.
- .2 Upon request, make available to Departmental Representative or to authorized safety Representative for inspection.

END OF SECTION

<u>1.1 SECTION INCLUDES</u>	.1	Procedures to isolate and lockout electrical facility and other equipment from energy sources.
<u>1.2 RELATED WORK</u>	.1	Section 01 35 29: Health and Safety
<u>1.3 REFERENCES</u>	.1	CSA C22.1-06 - Canadian Electrical Code, Part 1, Safety Standard for Electrical Installations.
	.2	CAN/CSA C22.3 No.1-06 - Overhead Systems.
	.3	CSA C22.3 No.7-06 - Underground Systems.
	.4	COSH: Canada Occupational Health and Safety Regulations made under Part II of the Canada Labour Code.
<u>1.4 DEFINITIONS</u>	.1	Electrical Facility: means any system, equipment, device, apparatus, wiring, conductor, assembly or part thereof that is used for the generation, transformation, transmission, distribution, storage, control, measurement or utilization of electrical energy, and that has an amperage and voltage that is dangerous to persons.
	.2	Guarantee of Isolation: means a guarantee by a competent person in control or in charge that a particular facility or equipment has been isolated.
	.3	De-energize: in the electrical sense, that a piece of equipment is isolated and grounded, e.g. if the equipment is not grounded, it cannot be considered de-energized (DEAD).
	.4	Guarded: means that an equipment or facility is covered, shielded, fenced, enclosed, inaccessible by location, or otherwise protected in a manner that, to the extent that is reasonably practicable, will prevent or reduce danger to any person who might touch or go near such item.
	.5	Isolate: means that an electrical facility, mechanical equipment or machinery is separated or disconnected from every source of electrical, mechanical, hydraulic, pneumatic or other kind of energy that is capable of making it dangerous.
	.6	Live/alive: means that an electrical facility produces, contains, stores or is electrically connected to a source of alternating or direct current of

an amperage and voltage that is dangerous or contains any hydraulic, pneumatic or other kind of energy that is capable of making the facility dangerous to persons.

1.5 COMPLIANCE
REQUIREMENTS

- .1 Comply with the following in regards to isolation and lockout of electrical facilities and equipment:
 - .1 Canadian Electrical Code
 - .2 Federal and Provincial Occupational Health and Safety Acts and Regulations.
 - .3 Regulations and code of practice as applicable to mechanical equipment or other machinery being de-energized.
 - .4 Procedures specified herein.
- .2 In event of conflict between any provisions of above authorities the most stringent provision will apply.

1.6 SUBMITTALS

- .1 Submit copy of lockout procedures, sample of lockout permit and lockout tags proposed for use in accordance with Section 01 33 00. , Submit within 14 calendar days of acceptance of bid.

1.7 ISOLATION OF
EXISTING SERVICES

- .1 Obtain Departmental Representative's written authorization prior to working on existing live or active electrical facilities and equipment and before proceeding with isolation of such item.
- .2 To obtain authorization, submit to Departmental Representative the following documentation:
 - .1 Written request to isolate the particular service or facility and;
 - .2 Copy of Contractor's Lockout Procedures.
- .3 Make a Request for Isolation for each event, unless directed otherwise by Departmental Representative, as follows:
 - .1 Fill-out standard form in current use at the Facility as provided by Departmental Representative or;
 - .2 Where no form exist, make written request indicating:
 - .1 The equipment, system or service to be isolated and its location;
 - .2 Duration of isolation period (ie: start time & date and completion time & date).
 - .3 Voltage of service feed to system or equipment being isolated.
 - .4 Name of person making the request.

- .4 Do not proceed with isolation until receipt of written notification from Departmental Representative granting the Isolation Request and authorization to proceed with the work.
 - .1 Note that Departmental Representative may designate another person at the Facility being authorized to grant the Isolation Request.
- .5 Conduct safe, orderly shutdown of equipment or facility. De-energize, isolate and lockout power and other sources of energy feeding the equipment or facility.
- .6 Determine in advance, as much as possible, in cooperation with the Departmental Representative, the type and frequency of situations which will require isolation of existing services.
- .7 Plan and schedule shut down of existing services in consultation with the Departmental Representative and the Facility Manager. Minimize impact and downtime of Facility operations. Follow Departmental Representative's directives in this regard.
- .8 Conduct hazard assessment as part of the process in accordance with health and safety requirements specified Section 01 35 29.

1.8 LOCKOUTS

- .1 De-energize, isolate and lockout electrical facility, mechanical equipment and machinery from all potential sources of energy prior to working on such items.
- .2 Develop and implement clear and specific lockout procedures to be followed as part of the Work.
- .3 Prepare typed written Lockout Procedures describing safe work practices, procedures, worker responsibilities and sequence of activities to be followed on site by workforce to safely isolate an active piece of equipment or electrical facility and effectively lockout and tag out its sources of energy.
- .4 Include as part of the Lockout Procedures a system of lockout permits managed by Contractor's Superintendent or other qualified person designated by him/her as being "in-charge" at the site.
 - .1 A lockout permit shall be issued to specific worker providing a Guarantee of Isolation before each event when work must be performed on a live equipment or electrical facility.
 - .2 Duties of person managing the permit system to include:
 - .1 Issuance of permits and lockout tags to workers.
 - .2 Determining permit duration.

- .3 Maintaining record of permits and tags issued.
- .4 Making a Request for Isolation to Departmental Representative when required as specified above.
- .5 Designating a Safety Watcher, when one is required based on type of work.
- .6 Ensuring equipment or facility has been properly isolated.
- .7 Collecting and safekeeping lockout tags returned by workers as a record of the event.

- .5 Clearly establish, describe and allocate responsibilities of:
 - .1 Workers.
 - .2 Person managing the lockout permit system.
 - .3 Safety Watcher.
 - .4 Subcontractor(s) and General Contractor.
- .6 Generic procedures, if used, must be edited and supplemented with pertinent information to reflect specific project requirements.
 - .1 Incorporate site specific rules and procedures in force at site as provided by Facility Manager through the Departmental Representative.
 - .2 Clearly label the document as being the Lockout procedures applicable to work of this contract.
- .7 Use energy isolation lockout devices specifically designed and appropriate for type of facility or equipment being locked out.
- .8 Use industry standard lockout tags.
- .9 Provide appropriate safety grounding and guards as required.

1.9 CONFORMANCE

- .1 Brief all workers and subcontractors on requirements of this section. Stringently enforce use and compliance.

1.10 DOCUMENTS
ON SITE

- .1 Post Lockout Procedures on site in common location for viewing by workers.
- .2 Keep copies of Request for Isolation forms and lockout permits and tags issued to workers on site for full duration of Work.

- .3 Upon request, make available to Departmental Representative or to authorized safety Representative for inspection.

END OF SECTION

-
- 1.1 RELATED WORK
- .1 Section 01 35 24: Special Procedures on Fire Safety Requirements.
 - .2 Section 01 35 25: Special Procedures on Lockout Requirements.
- 1.2 DEFINITIONS
- .1 COSH: Canada Occupational Health and Safety Regulations made under Part II of the Canada Labour Code.
 - .2 Competent Person: means a person who is:
 - .1 Qualified by virtue of personal knowledge, training and experience to perform assigned work in a manner that will ensure the health and safety of persons in the workplace, and;
 - .2 Knowledgeable about the provisions of occupational health and safety statutes and regulations that apply to the Work and;
 - .3 Knowledgeable about potential or actual danger to health or safety associated with the Work.
 - .3 Medical Aid Injury: any minor injury for which medical treatment was provided and the cost of which is covered by Workers' Compensation Board of the province in which the injury was incurred.
 - .4 PPE: personal protective equipment
 - .5 Work Site: where used in this section shall mean areas, located at the premises where Work is undertaken, used by Contractor to perform all of the activities associated with the performance of the Work.
- 1.3 SUBMITTALS
- .1 Make submittals in accordance with Section 01 33 00.
 - .2 Submit site-specific Health and Safety Plan prior to commencement of Work.
 - .1 Submit within 7 work days of notification of Bid Acceptance. Provide 3 copies.
 - .2 Departmental Representative will review Health and Safety Plan and provide comments.
 - .3 Revise the Plan as appropriate and resubmit within 5 work days after receipt of comments.
 - .4 Departmental Representative's review and comments made of the Plan shall not be construed as an endorsement, approval or implied warranty of any kind by Canada and does not reduce Contractor's overall responsibility for Occupational Health and Safety of the Work.
 - .5 Submit revisions and updates made to the Plan during the course of Work.
 - .3 Submit name of designated Health & Safety Site Representative and

support documentation specified in the Safety Plan.

- .4 Submit building permit, compliance certificates and other permits obtained.
- .5 Submit copy of Letter in Good Standing from Provincial Workers Compensation or other department of labour organization.
 - .1 Submit update of Letter of Good Standing whenever expiration date occurs during the period of Work.
- .6 Submit copies of reports or directions issued by Federal, Provincial and Territorial health and safety inspectors.
- .7 Submit copies of incident reports.
- .8 Submit WHMIS MSDS - Material Safety Data Sheets.

1.4 COMPLIANCE REQUIREMENTS

- .1 Comply with Occupational Health and Safety Act for Province of Nova Scotia, and Regulations made pursuant to the Act.
- .2 Comply with Canada Labour Code - Part II (entitled Occupational Health and Safety) and the Canada Occupational Health and Safety Regulations (COSH) as well as any other regulations made pursuant to the Act.
 - .1 The Canada Labour Code can be viewed at:
[www.http://laws.justice.gc.ca/en/L-2/](http://laws.justice.gc.ca/en/L-2/)
 - .2 COSH can be viewed at:
[www.http://laws.justice.gc.ca/eng/SOR-86-304/n e .html](http://laws.justice.gc.ca/eng/SOR-86-304/n_e.html)
 - .3 A copy may be obtained at: Canadian Government Publishing
Public Works & Government Services Canada Ottawa,
Ontario, K1A 0S9 Tel: (819) 956-4800 (1-800-635-7943)
Publication No. L31-85/2000 E or F)
- .3 Observe construction safety measures of:
 - .1 Part 8 of National Building Code
 - .2 Municipal by-laws and ordinances.
- .4 In case of conflict or discrepancy between above specified requirements, the more stringent shall apply.
- .5 Maintain Workers Compensation Coverage in good standing for duration of Contract. Provide proof of clearance through submission
- .6 Medical Surveillance: Where prescribed by legislation or regulation, obtain and maintain worker medical surveillance documentation.

1.5 RESPONSIBILITY

- .1 Be responsible for health and safety of persons on site, safety of property on site and for protection of persons and environment adjacent to the site to extent that they may be affected by conduct of Work.
- .2 Comply with and enforce compliance by all workers, sub-contractors and other persons granted access to Work Site with safety requirements of Contract Documents, applicable federal, provincial, and local by-laws, regulations, and ordinances, and with site-specific Health and Safety Plan.

1.6 SITE CONTROL
AND ACCESS

- .1 Control the Work and entry points to Work Site. Approve and grant access only to workers and authorized persons. Immediately stop and remove non-authorized persons.
 - .1 Departmental Representative will provide names of those persons authorized by Departmental Representative to enter onto Work Site and will ensure that such authorized persons have the required knowledge and training on Health and Safety pertinent to their reason for being at the site, however, Contractor remains responsible for the health and safety of authorized persons while at the Work Site.
- .2 Isolate Work Site from other areas of the premises by use of appropriate means.
 - .1 Erect fences, hoarding, barricades and temporary lighting as required to effectively delineate the Work Site, stop non-authorized entry, and to protect pedestrians and vehicular traffic around and adjacent to the Work and create a safe environment.
 - .2 Post signage at entry points and other strategic locations indicating restricted access and conditions for access.
 - .3 Use professionally made signs with bilingual message in the 2 official languages or international known graphic symbols.
- .3 Provide safety orientation session to persons granted access to Work Site. Advise of hazards and safety rules to be observed while on site.
- .4 Ensure persons granted site access wear appropriate PPE. Supply PPE to inspection authorities who require access to conduct tests or perform inspections.
- .5 Secure Work Site against entry when inactive or unoccupied and to protect persons against harm. Provide security guard where adequate protection cannot be achieved by other means.

- 1.7 PROTECTION
- .1 Give precedence to safety and health of persons and protection of environment over cost and schedule considerations for Work.
 - .2 Should unforeseen or peculiar safety related hazard or condition become evident during performance of Work, immediately take measures to rectify situation and prevent damage or harm. Advise Departmental Representative verbally and in writing.
- 1.8 FILING OF NOTICE
- .1 File Notice of Project with pertinent provincial health and safety authorities prior to beginning of Work.
 - .1 Departmental Representative will assist in locating address if needed.
- 1.9 PERMITS
- .1 Post permits, licenses and compliance certificates, specified in section 01 10 10, at Work Site.
 - .2 Where a particular permit or compliance certificate cannot be obtained, notify Departmental Representative in writing and obtain approval to proceed before carrying out applicable portion of work.
- 1.10 HAZARD ASSESSMENTS
- .1 Perform site specific health and safety hazard assessment of the Work and its site.
 - .2 Carryout initial assessment prior to commencement of Work with further assessments as needed during progress of work, including when new trades and subcontractors arrive on site.
 - .3 Record results and address in Health and Safety Plan.
 - .4 Keep documentation on site for entire duration of the Work.
- 1.11 PROJECT/SITE CONDITIONS
- .1 Following are potential health, environmental and safety hazards at the site for which Work may involve contact with:
 - .1 Existing hazardous substances or contaminated building

materials:

- .1 Lead/lithium batteries.
- .2 Diesel fuel.
- .3
- .2 Known latent site and environmental conditions:
 - .1 Access panel in floor of heating plant.
 - .2
 - .3
- .3 Facility on-going operations:
 - .1 Vehicular and Pedestrian Traffic
 - .2 Active heating plant with mechanical heating and cooling systems (boilers, generator, etc.).

- .2 Above items shall not be construed as being complete and inclusive of potential health and safety hazards encountered during Work.
- .3 Include above items in the hazard assessment of the Work.
- .4 MSDS Data sheets of pertinent hazardous and controlled products stored on site can be obtained from Departmental Representative.

1.12 MEETINGS

- .1 Attend pre-construction health and safety meeting convened and chaired by Departmental Representative, prior to commencement of Work, at time, date and location determined by Departmental Representative. Ensure attendance of:
 - .1 Superintendent of Work
 - .2 Designated Health & Safety Site Representative
 - .3 Subcontractors
- .2 Conduct regularly scheduled tool box and safety meetings during the Work in conformance with Occupational Health and Safety regulations.
- .3 Keep documents on site.

1.13 HEALTH AND SAFETY PLAN

- .1 Prior to commencement of Work, develop written Health and Safety Plan specific to the Work. Implement, maintain, and enforce Plan for entire duration of Work and until final demobilization from site.
- .2 Health and Safety Plan shall include the following components:
 - .1 List of health risks and safety hazards identified by hazard assessment.
 - .2 Control measures used to mitigate risks and hazards identified.

- .3 On-site Contingency and Emergency Response Plan as specified below.
- .4 On-site Communication Plan as specified below.
- .5 Name of Contractor's designated Health & Safety Site Representative and information showing proof of his/her competence and reporting relationship in Contractor's company.
- .6 Names, competence and reporting relationship of other supervisory personnel used in the Work for occupational health and safety purposes.
- .3 On-site Contingency and Emergency Response Plan shall include:
 - .1 Operational procedures, evacuation measures and communication process to be implemented in the event of an emergency.
 - .2 Evacuation Plan: site and floor plan layouts showing escape routes, marshalling areas. Details on alarm notification methods, fire drills, location of firefighting equipment and other related data.
 - .3 Name, duties and responsibilities of persons designated as Emergency Warden(s) and deputies.
 - .4 Emergency Contacts: name and telephone number of officials from:
 - .1 General Contractor and subcontractors.
 - .2 Pertinent Federal and Provincial Departments and Authorities having jurisdiction.
 - .3 Local emergency resource organizations.
 - .5 Harmonize Plan with Facility's Emergency Response and Evacuation Plan. Departmental Representative will provide pertinent data including name of PWGSC and Facility Management contacts.
- .4 On-site Communication Plan:
 - .1 Procedures for sharing of work related safety information to workers and subcontractors, including emergency and evacuation measures.
 - .2 List of critical work activities to be communicated with Facility Manager which have a risk of endangering health and safety of Facility users.
- .5 Address all activities of the Work including those of subcontractors.
- .6 Review Health and Safety Plan regularly during the Work. Update as conditions warrant to address emerging risks and hazards, such as whenever new trade or subcontractor arrive at Work Site.
- .7 Departmental Representative will respond in writing, where deficiencies or concerns are noted and may request re-submission of the Plan with correction of deficiencies or concerns.

1.14 SAFETY
SUPERVISION

- .8 Post copy of the Plan, and updates, prominently on Work Site.

- .1 Employ Health & Safety Site Representative responsible for daily supervision of health and safety of the Work.

- .2 Health & Safety Site Representative may be the Superintendent of the Work or other person designated by Contractor and shall be assigned the responsibility and authority to:
 - .1 Implement, monitor and enforce daily compliance with health and safety requirements of the Work
 - .2 Monitor and enforce Contractor's site-specific Health and Safety Plan.
 - .3 Conduct site safety orientation session to persons granted access to Work Site.
 - .4 Ensure that persons allowed site access are knowledgeable and trained in health and safety pertinent to their activities at the site or are escorted by a competent person while on the Work Site.
 - .5 Stop the Work as deemed necessary for reasons of health and safety.

- .3 Health & Safety Site Representative must:
 - .1 Be qualified and competent person in occupational health and safety.
 - .2 Have site-related working experience specific to activities of the Work.
 - .3 Be on Work Site at all times during execution of the Work.

- .4 All supervisory personnel assigned to the Work shall also be competent persons.

- .5 Inspections:
 - .1 Conduct regularly scheduled safety inspections of the Work on a minimum bi-weekly basis. Record deficiencies and remedial action taken.
 - .2 Conduct Formal Inspections on a minimum monthly basis. Use standardized safety inspection forms. Distribute to subcontractors.
 - .3 Follow-up and ensure corrective measures are taken.

- .6 Cooperate with Facility's Occupational Health and Safety representative should one be designated by Departmental Representative.

- .7 Keep inspection reports and supervision related documentation on site.

1.15 TRAINING

- .1 Use only skilled workers on Work Site who are effectively trained in occupational health and safety procedures and practices pertinent to their assigned task.
- .2 Maintain employee records and evidence of training received. Make data available to Departmental Representative upon request.
- .3 When unforeseen or peculiar safety-related hazard, or condition occur during performance of Work, follow procedures in place for Employee's Right to Refuse Work in accordance with Acts and Regulations of Province having jurisdiction and advise Departmental Representative verbally and in writing.

1.16 MINIMUM
SITE SAFETY RULES

- .1 Notwithstanding requirement to abide by federal and provincial health and safety regulations; ensure the following minimum safety rules are obeyed by persons granted access to Work Site:
 - .1 Wear appropriate PPE pertinent to the Work or assigned task: minimum being hard hat, safety footwear, safety glasses.
 - .2 Immediately report unsafe condition at site, near-miss accident, injury and damage.
 - .3 Maintain site and storage areas in a tidy condition free of hazards causing injury.
 - .4 Obey warning signs and safety tags.
- .2 Brief persons of disciplinary protocols to be taken for non-compliance. Post rules on site.

1.17 CORRECTION OF
NON-COMPLIANCE

- .1 Immediately address health and safety non-compliance issues identified by authority having jurisdiction or by Departmental Representative.
- .2 Provide Departmental Representative with written report of action taken to correct non-compliance of health and safety issues identified.
- .3 Departmental Representative will stop Work if non-compliance of health and safety regulations is not corrected in a timely manner.

1.18 INCIDENT
REPORTING

- .1 Investigate and report the following incidents to Departmental Representative:
 - .1 Incidents requiring notification to Provincial Department of

- Occupational Safety and Health, Workers Compensation Board or to other regulatory Agency.
 - .2 Medical aid injuries.
 - .3 Property damage in excess of \$10,000.00,
 - .4 Interruptions to Facility operations resulting in an operational lost to a Federal department in excess of \$5000.00.
- .2 Submit report in writing.
- 1.19 HAZARDOUS PRODUCTS
- .1 Comply with requirements of Workplace Hazardous Materials Information System (WHMIS).
 - .2 Keep MSDS data sheets for all products delivered to site.
 - .1 Post on site.
 - .2 Submit copy to Departmental Representative.
 - .3 For interior work in an occupied Facility, post additional copy in one or more publically accessible locations.
- 1.20 BLASTING
- .1 Blasting or other use of explosives is not permitted on site.
- 1.21 POWDER ACTUATED DEVICES
- .1 Use powder actuated fastening devices only after receipt of written permission from Departmental Representative.
- 1.22 CONFINED SPACES
- .1 Abide by occupational health and safety regulations regarding work in confined spaces.
 - .2 Obtain an Entry Permit in accordance with Part XI of the Canada Occupational Health and Safety Regulations for entry into an existing identified confined space located at the Facility or premises of Work.
 - .1 Obtain permit from Facility Manager
 - .2 Keep copy of permit issued.
 - .3 Safety for Inspectors:
 - .1 Provide PPE and training to Departmental Representative and other persons who require entry into confined space to perform inspections.
 - .2 Be responsible for efficacy of equipment and safety of persons during their entry and occupancy in the confined space.

1.23 SITE RECORDS

- .1 Maintain on Work Site copy of safety related documentation and reports stipulated to be produced in compliance with Acts and Regulations of authorities having jurisdiction and of those documents specified herein.
- .2 Upon request, make available to Departmental Representative or authorized Safety Officer for inspection.

1.24 POSTING OF DOCUMENTS

- .1 Ensure applicable items, articles, notices and orders are posted in conspicuous location on Work Site in accordance with Acts and Regulations of Province having jurisdiction.
- .2 Post other documents as specified herein, including:
 - .1 Site specific Health and Safety Plan
 - .2 WHMIS data sheets

END OF SECTION

PART 1 - GENERAL

1.1 RELATED
REQUIREMENTS

.1 Not Used.

1.2 REFERENCES

.1 Definitions:

- .1 Environmental Pollution and Damage: presence of chemical, physical, biological elements or agents which adversely affect human health and welfare; unfavorably alter ecological balances of importance to human life; affect other species of importance to humankind; or degrade environment aesthetically, culturally and/or historically.
- .2 Environmental Protection: prevention/control of pollution and habitat or environment disruption during construction. Control of environmental pollution and damage requires consideration of land, water, and air; biological and cultural resources; and includes management of visual aesthetics; noise; solid, chemical, gaseous, and liquid waste; radiant energy and radioactive material as well as other pollutants.
- .3 Hazardous Material: Product, substance or organism that is used for its original purpose; and that is either dangerous goods or a material that may cause adverse impact to the environment or adversely affect the health of persons, animals or plant life when released into the environment.

.2 Reference Standards:

- .1 U.S. Environmental Protection Agency (EPA)/Office of Water
 - .1 EPA 832/R-92-005-92, Storm Water Management for Construction Activities, Chapter 3.
 - .2 Canadian Council of Ministers of the Environment (CCME), Environment Quality Guidelines.
 - .3 Environment Canada, Section 36 (3) of the Fisheries Act - prohibits the planned or accidental discharge of deleterious substances to waters frequented by fish
 - .4 Environment Canada, Migratory Birds Convention Act - prohibits the deposit of oil, oil wastes, or other substances harmful to migratory birds or in any area frequented by birds.
 - .5 Any Provincial Standards and Federal requirements.

1.3 ACTION AND
INFORMATIONAL
SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Prior to commencing construction activities or delivery of materials to site, provide Environmental Protection Plan for review by Departmental Representative.
- .3 Ensure Environmental Protection Plan includes comprehensive overview of known or potential environmental issues to be addressed during construction.
- .4 Address topics at level of detail commensurate with environmental issue and required construction tasks.
- .5 Include in Environmental Protection Plan:
 - .1 Names of persons responsible for ensuring adherence to Environmental Protection Plan.
 - .2 Names and qualification of persons responsible for manifesting hazardous waste to be removed from site, and the name and location of the wastes destination (disposal facility).
 - .3 Names and qualifications of persons responsible for training site personnel.
 - .4 Descriptions of environmental protection personnel training program.
 - .5 Spill Control Plan including procedures, instructions, and reports to be used in event of unforeseen spill of regulated substance.
 - .6 Non-Hazardous solid waste disposal plan identifying methods and locations for solid waste disposal including clearing debris.
 - .7 Air pollution control plan detailing provisions to assure that dust, debris, materials, and trash, are contained on project site.
 - .8 Contaminant Prevention Plan identifying potentially hazardous substances to be used on job site; intended actions to prevent introduction of such materials into air, water, or ground; and detailing provisions for compliance with Federal, Provincial, and Municipal laws and regulations for storage and handling of these materials.
 - .9 Historical, archaeological, cultural resources biological resources and wetlands plan that defines procedures for identifying and protecting historical, archaeological, cultural resources, biological resources and wetlands.

1.4 FIRES

- .1 Fires and burning of rubbish on site not permitted.

1.5 POLLUTION
CONTROL

- .1 Maintain temporary erosion and pollution control features installed under this Contract.
- .2 Control emissions from equipment and plant to local authorities' emission requirements.
- .3 Have appropriate emergency spill response equipment and rapid clean-up kit on site located adjacent to hazardous materials storage area. Provide personal protective equipment required for clean-up.
- .4 Report spills of petroleum and other hazardous materials as well as accidents having potential of polluting the environment to Federal and Provincial Department of Environment.
 - .1 Notify the Departmental Representative and submit a written spill report to the Departmental Representative within 24 hours of occurrence.

1.6
HISTORICAL/ARCHAEOLOGICAL
CONTROL

- .1 Provide historical, archaeological, cultural resources biological resources and wetlands plan that defines procedures for identifying and protecting historical, archaeological, cultural resources, biological resources and wetlands known to be on project site: and/or identifies procedures to be followed if historical archaeological, cultural resources, biological resources and wetlands not previously known to be onsite or in area are discovered during construction.
- .2 Plan: include methods to assure protection of known or discovered resources and identify lines of communication between Contractor personnel and Departmental Representative.

1.7 NOTIFICATION

- .1 Departmental Representative will notify Contractor in writing of observed noncompliance with Federal, Provincial or Municipal environmental laws or regulations, permits, and other elements of Contractor's Environmental Protection plan.
- .2 Contractor: after receipt of such notice, inform Departmental Representative of proposed corrective action and take such action for approval by Departmental Representative.
 - .1 Do not take action until after receipt of written approval by Departmental Representative.
- .3 Departmental Representative may issue stop order of work until

satisfactory corrective action has been taken.

- .4 No time extensions granted or equitable adjustments allowed to Contractor for such suspensions.

1.8 HAZARDOUS
MATERIAL HANDLING

- .1 Store and handle hazardous materials in accordance with applicable federal and provincial laws, regulations, codes and guidelines. Store in location that will prevent spillage into the environment.
- .2 Label containers to WHMIS requirements and keep MSDS data sheets on site for all hazardous materials.
- .3 Maintain inventory of hazardous materials and hazardous waste stored on site. List items by product name, quantity and date when storage began.
- .4 Store and handle flammable and combustible materials in accordance with the National Fire Code.
- .5 Transport hazardous materials in accordance with federal Transportation of Dangerous Goods regulations and applicable Provincial regulations.

1.9 DISPOSAL OF
WASTES

- .1 Do not bury rubbish and waste materials on site. Dispose in accordance with project waste management requirements specified in section 01 74 21.
- .2 Do not dispose of hazardous waste or volatile materials, such as mineral spirits, paints, thinners, oil or fuel into waterways, storm or sanitary sewers or waste landfill sites.
- .3 Dispose of hazardous waste in accordance with applicable federal and provincial legislation, regulations, codes and guidelines.

PART 2 - PRODUCTS

2.1 NOT USED

- .1 Not Used.

PART 3 - EXECUTION

3.1 CLEANING

- .1 Ensure public waterways, storm and sanitary sewers remain free of waste and volatile materials disposal.
- .2 Perform final decontamination of construction facilities, equipment and materials which may have come in contact with potentially contaminated materials prior to removal from site.
 - .1 Perform decontamination as specified and to satisfaction of Departmental Representative and in accordance with regulatory requirements.

3.2 MITIGATION OF IMPACTS

- .1 The proponent must ensure that a copy of these "Environmental Requirements" will be readily available on site for inspection and reference purposes during the construction phase of the project, and that all contractors and their agents will be made aware of and respect the following requirements where applicable to their direct involvement in the work.
- .2 Machinery must be checked for leakage of lubricants or fuel and must be in good working order. Refueling must be done at least 30 m from any water body and on an impermeable surface. Basic petroleum spill clean-up equipment should be on-site. All spills or leaks should be promptly contained, cleaned up and reported to the 24-hour environmental emergencies reporting system (1-800-565-1633).
- .3 Fuel level must be inspected on a daily basis to ensure there is no leakage to the surrounding environment.
- .4 All construction waste material will be disposed of in a provincially approved manner.
- .5 All equipment must be maintained in proper running order to prevent leaking or spilling of potentially hazardous or toxic products. This includes hydraulic fluid, diesel, gasoline and other petroleum products.
- .6 All waste materials will be disposed of according to Provincial Waste Management Regulations so as to mitigate potential effects generated by leachate entering soils.

- .7 Existing potentially hazardous materials are listed in Section 01 35 29 - Health and Safety Requirements.
- .8 Engines must not be allowed to idle between work periods.
- .9 All machinery must be well muffled. If necessary, trucks may be required to avoid the use of "hammer" braking along specific sections of the route.
- .10 Adherence is required to the regulations set out by the Migratory Birds Convention Act.
- .11 Contractors must ensure that food scraps and garbage are not left at the work site.

END OF SECTION

PART 1 - GENERAL

1.1 RELATED
SECTIONS

.1 Not Used.

1.2 REFERENCES

.1 Not Used.

1.3 INSPECTION

- .1 Allow Departmental Representative access to Work. If part of Work is in preparation at locations other than Place of Work, allow access to such Work whenever it is in progress.
- .2 Give timely notice requesting inspection if Work is designated for special tests, inspections or approvals by Departmental Representative instructions, or law of Place of Work.
- .3 If Contractor covers or permits to be covered Work that has been designated for special tests, inspections or approvals before such is made, uncover such Work, have inspections or tests satisfactorily completed and make good such Work.
- .4 Departmental Representative will order part of Work to be examined if Work is suspected to be not in accordance with Contract Documents. If, upon examination such work is found not in accordance with Contract Documents, correct such Work and pay cost of examination and correction.

1.4 INDEPENDENT
INSPECTION AGENCIES

- .1 Independent Inspection/Testing Agencies may be engaged by Departmental Representative for purpose of inspecting and/or testing portions of Work.
- .2 Provide equipment required for executing inspection and testing.

- .3 Employment of inspection/testing agency does not relax responsibility to perform work in accordance with Contract Documents.
- .4 If defects are revealed during inspection and/or testing, appointed agency will request additional inspection and/or testing to ascertain full degree of defect. Correct defect and irregularities as advised by Departmental Representative at no cost to Departmental Representative. Pay costs for retesting and re-inspection.

1.5 ACCESS TO WORK

- .1 Allow inspection/testing agencies access to Work.
- .2 Co-operate to provide reasonable facilities for such access.

1.6 PROCEDURES

- .1 Notify appropriate agency and Departmental Representative in advance of requirement for tests, in order that attendance arrangements can be made.
- .2 Submit samples and/or materials required for testing, as specifically requested in specifications. Submit with reasonable promptness and in orderly sequence to not cause delays in Work.
- .3 Provide labour and facilities to obtain and handle samples and materials on site. Provide sufficient space to store and cure test samples.

1.7 REJECTED WORK

- .1 Remove defective Work, whether result of poor workmanship, use of defective products or damage and whether incorporated in Work or not, which has been rejected by Departmental Representative as failing to conform to Contract Documents. Replace or re-execute in accordance with Contract Documents.
- .2 Make good other Contractor's work damaged by such removals or replacements promptly.
- .3 If in opinion of Departmental Representative it is not expedient to correct defective Work or Work not performed in accordance with Contract Documents, Owner will deduct from Contract Price difference in value between Work performed and that called for by Contract Documents, amount of which will be determined by

Departmental Representative.

PART 2 – PRODUCTS

2.1 NOT USED .1 Not Used.

END OF SECTION

- 1.1 SITE ACCESS AND PARKING
- .1 The Departmental Representative will designate Contractor's access to project site as well as parking facilities for equipment and workers.
 - .2 Parking facilities at site is limited. If insufficient, make arrangements elsewhere for Contractor's vehicles including those of subcontractors and workers.
- 1.2 MATERIAL STORAGE
- .1 Locate site storage trailers where directed by Departmental Representative or assigned to at start-up meeting. Observe work area restrictions. Place in location of least interference with existing Facility operations.
 - .2 Material storage space on site is limited.
- 1.3 SANITARY FACILITIES
- .1 Provide sanitary facilities for work force in accordance with governing regulations and ordinances. No use of facilities on site is permitted.
- 1.4 POWER
- .1 AAFC will provide access to power.
- 1.5 WATER SUPPLY
- .1 AAFC will provide access to water.
- 1.6 SCAFFOLDING
- .1 Design, construct and maintain scaffolding in rigid, secure and safe manner in accordance with the following codes and standards:
 - .1 CAN/CSA-S269.2-M87 (R2003), Access Scaffolding for Construction Purposes.
 - .2 National Building Code of Canada (most recent edition)
 - .3 The Canada Labour Code Part II.
 - .4 Provincial Worker's Compensation Board.
 - .5 The Nova Scotia Workplace Health and Safety Regulations, NS Reg 52/2013.
 - .6 The Nova Scotia Construction Safety Association.
 - .2 Where codes and standards conflict, the most stringent shall apply.
 - .3 Erect scaffolding independent of walls. Remove when no longer required.

1.7 CONSTRUCTION
SIGN AND NOTICES

- .1 Contractor or subcontractor advertisement signboards are not permitted on site.
- .2 Safety and Instruction Signs and Notices:
 - .1 Signs and notices for safety and instruction shall be in both official languages or commonly understood graphic symbols conforming to CAN3-Z321-96(R2006).
 - .3 Maintenance and Disposal of Site Signs:
 - .1 Maintain approved signs and notices in good condition for duration of project and dispose of off-site on completion of project or earlier if directed by Departmental Representative.

1.8 REMOVAL OF
TEMPORARY
FACILITIES

- .1 Remove temporary facilities from site when directed by Departmental Representative at no additional cost.

END OF SECTION

PART 1 - GENERAL

1.1 RELATED
SECTIONS

.1 Not Used.

1.2 REFERENCES

.1 Not Used.

1.3 INSTALLATION
AND REMOVAL

.1 Submit a temporary barriers and enclosures plan to the Departmental Representative.

.2 Provide temporary controls in order to execute work expeditiously.

.3 Remove from site all such work after use.

1.4 HOARDING

.1 Not Used.

1.5 GUARD RAILS AND
BARRICADES

.1 Provide secure, rigid guard rails and barricades around deep excavations, open shafts, open stair wells, open edges of floors and roofs, etc. Removable barrier will be required when opening access panel in the heating plant floor. Coordination with facility during such work will be crucial.

.2 Provide as required by governing authorities.

1.6 WEATHER
ENCLOSURES

.1 Not Used.

<u>1.7 DUST TIGHT SCREENS</u>	.1	Not Used.
<u>1.8 ACCESS TO SITE</u>	.1	Provide and maintain access roads, sidewalk crossings, ramps and construction runways as may be required for access to Work.
<u>1.9 PUBLIC TRAFFIC FLOW</u>	.1	Provide and maintain competent signal flag operators, traffic signals, barricades and flares, lights, or lanterns as required to perform Work and protect public.
<u>1.10 FIRE ROUTES</u>	.1	Maintain access to property including overhead clearances for use by emergency response vehicles.
<u>1.11 PROTECTION FOR OFF-SITE AND PUBLIC PROPERTY</u>	.1	Protect surrounding private and public property from damage during performance of Work.
	.2	Be responsible for damage incurred.
<u>1.12 PROTECTION OF BUILDING FINISHES</u>	.1	Not Used.
<u>1.13 WASTE MANAGEMENT AND DISPOSAL</u>	.1	Not Used.
<u>PART 2 - PRODUCTS</u>		
<u>2.1 NOT USED</u>	.1	Not Used.

PART 3 - EXECUTION

3.1 NOT USED .1 Not Used.

END OF SECTION

PART 1 - GENERAL

1.1 RELATED
SECTIONS

- .1 Not Used.

1.2 REFERENCES

- .1 Within text of each specifications section, reference may be made to reference standards. List of standards reference writing organizations is contained in Section.
- .2 Conform to these reference standards, in whole or in part as specifically requested in specifications.
- .3 If there is question as to whether products or systems are in conformance with applicable standards, Departmental Representative reserves right to have such products or systems tested to prove or disprove conformance.

1.3 QUALITY

- .1 Products, materials, equipment and articles incorporated in Work shall be new, not damaged or defective, and of best quality for purpose intended. If requested, furnish evidence as to type, source and quality of products provided.
- .2 Procurement policy is to acquire, in cost effective manner, items containing highest percentage of recycled and recovered materials practicable consistent with maintaining satisfactory levels of competition. Make reasonable efforts to use recycled and recovered materials and in otherwise utilizing recycled and recovered materials in execution of work.
- .3 Defective products, whenever identified prior to completion of Work, will be rejected, regardless of previous inspections. Inspection does not relieve responsibility, but is precaution against oversight or error. Remove and replace defective products at own expense and be responsible for delays and expenses caused by rejection.
- .4 Should disputes arise as to quality or fitness of products, decision rests strictly with Departmental Representative based upon requirements of

Contract Documents.

- .5 Unless otherwise indicated in specifications, maintain uniformity of manufacture for any particular or like item throughout building.
- .6 Permanent labels, trademarks and nameplates on products are not acceptable in prominent locations, except where required for operating instructions, or when located in mechanical or electrical rooms.

1.4 STORAGE,
HANDLING AND
PROTECTION

- .1 Handle and store products in manner to prevent damage, adulteration, deterioration and soiling and in accordance with manufacturer's instructions when applicable.
- .2 Store packaged or bundled products in original and undamaged condition with manufacturer's seal and labels intact. Do not remove from packaging or bundling until required in Work.
- .3 Store products subject to damage from weather in weatherproof enclosures.
- .4 Store cementitious products clear of earth or concrete floors, and away from walls.
- .5 Keep sand, when used for grout or mortar materials, clean and dry. Store sand on wooden platforms and cover with waterproof tarpaulins during inclement weather.
- .6 Store sheet materials, on flat, solid supports and keep clear of ground. Slope to shed moisture.
- .7 Store and mix paints in heated and ventilated room. Remove oily rags and other combustible debris from site daily. Take every precaution necessary to prevent spontaneous combustion.
- .8 Remove and replace damaged products at own expense and to satisfaction of Departmental Representative.
- .9 Touch-up damaged factory finished surfaces to Departmental Representative's satisfaction. Use touch-up materials to match original. Do not paint over name plates.

1.5 TRANSPORTATION

- .1 Pay costs of transportation of products required in performance of Work.

- .2 Transportation cost of products supplied by Owner will be paid for by Departmental Representative. Unload, handle and store such products.

1.6 MANUFACTURER'S INSTRUCTIONS

- .1 Unless otherwise indicated in specifications, install or erect products in accordance with manufacturer's instructions. Do not rely on labels or enclosures provided with products. Obtain written instructions directly from manufacturers.
- .2 Notify Departmental Representative in writing, of conflicts between specifications and manufacturer's instructions, so that Departmental Representative will establish course of action.
- .3 Improper installation or erection of products, due to failure in complying with these requirements, authorizes Departmental Representative to require removal and re-installation at no increase in Contract Price or Contract Time.

1.7 QUALITY OF WORK

- .1 Ensure Quality of Work is of highest standard, executed by workers experienced and skilled in respective duties for which they are employed. Immediately notify Departmental Representative if required Work is such as to make it impractical to produce required results.
- .2 Do not employ anyone unskilled in their required duties. Departmental Representative reserves right to require dismissal from site, workers deemed incompetent or careless.
- .3 Decisions as to standard or fitness of Quality of Work in cases of dispute rest solely with Departmental Representative, whose decision is final.

1.8 CO-ORDINATION

- .1 Ensure co-operation of workers in laying out Work. Maintain efficient and continuous supervision.
- .2 Be responsible for coordination and placement of openings, sleeves and accessories.

- 1.9 CONCEALMENT
- .1 In finished areas conceal pipes, ducts and wiring in floors, walls and ceilings, except where indicated otherwise.
 - .2 Before installation, inform Departmental Representative if there is interference. Install as directed by Departmental Representative.
- 1.10 REMEDIAL WORK
- .1 Perform remedial work required to repair or replace parts or portions of Work identified as defective or unacceptable. Co-ordinate adjacent affected Work as required.
 - .2 Perform remedial work by specialists familiar with materials affected. Perform in a manner to neither damage nor put at risk any portion of Work.
- 1.11 LOCATION OF FIXTURES
- .1 Consider location of fixtures, outlets, and mechanical and electrical items indicated as approximate.
 - .2 Inform Departmental Representative of conflicting installation. Install as directed.
- 1.12 FASTENINGS
- .1 Provide metal fastenings and accessories in same texture, colour and finish as adjacent materials, unless indicated otherwise.
 - .2 Prevent electrolytic action between dissimilar metals and materials.
 - .3 Use non-corrosive hot dip galvanized steel fasteners and anchors for securing exterior work, unless stainless steel or other material is specifically requested in affected specification Section.
 - .4 Space anchors within individual load limit or shear capacity and ensure they provide positive permanent anchorage. Wood, or any other organic material plugs are not acceptable.
 - .5 Keep exposed fastenings to a minimum, space evenly and install neatly.
 - .6 Fastenings which cause spalling or cracking of material to which

anchorage is made are not acceptable.

1.13 FASTENINGS -
EQUIPMENT

- .1 Use fastenings of standard commercial sizes and patterns with material and finish suitable for service.
- .2 Use heavy hexagon heads, semi-finished unless otherwise specified. Use No. 304 stainless steel for exterior areas.
- .3 Bolts may not project more than one diameter beyond nuts.
- .4 Use plain type washers on equipment, sheet metal and soft gasket lock type washers where vibrations occur. Use resilient washers with stainless steel.

1.14 PROTECTION OF
WORK IN PROGRESS

- .1 Prevent overloading of parts of building. Do not cut, drill or sleeve load bearing structural member, unless specifically indicated without written approval of Departmental Representative.

1.15 EXISTING
UTILITIES

- .1 When breaking into or connecting to existing services or utilities, execute Work at times directed by local governing authorities, with minimum of disturbance to Work, and/or building occupants.
- .2 Protect, relocate or maintain existing active services. When services are encountered, cap off in manner approved by authority having jurisdiction. Stake and record location of capped service.

PART 2 - PRODUCTS

2.1 NOT USED

- .1 Not Used.

PART 3 - EXECUTION

3.1 NOT USED .1 Not Used.

END OF SECTION

1.1 GENERAL

- .1 Conduct cleaning and disposal operations to comply with local ordinances and anti-pollution laws.
- .2 Store volatile waste in covered metal containers, and remove from premises at end of each working day.
- .3 Provide adequate ventilation during use of volatile or noxious substances. Use of building ventilation systems is not permitted for this purpose.

1.2 MATERIALS

- .1 Use only cleaning materials recommended by manufacturer of surface to be cleaned, and as recommended by cleaning material manufacturer.

1.3 CLEANING DURING CONSTRUCTION

- .1 Maintain work site in a tidy condition, free from accumulations of waste material and debris. Clean areas on a daily basis.
- .2 Provide on-site containers for collection of waste materials and debris.
- .3 Use separate collection bins, clearly marked as to purpose, for source separation and recycling of waste and debris in accordance with waste management requirements specified.
- .4 Remove waste materials, and debris from site on a minimum weekly basis.
- .5 Schedule cleaning operations so that resulting dust, debris and other contaminants will not fall on wet, newly painted surfaces nor contaminate building systems.
- .6 Special instructions for the handling, storage and disposal of hazardous materials are provided in the respective hazardous materials specification sections for each material.
- .7 Remove snow and ice from access doors used by workforce.

1.4 FINAL CLEANING

- .1 In preparation for acceptance of the completed work perform final cleaning.

END OF SECTION

PART 1 - GENERAL

1.1 WASTE
MANAGEMENT GOALS

- .1 Preserve environment and prevent pollution and environment damage.

1.2 DEFINITIONS

- .1 Deconstruction: systematic dismantling of structure in a manner that achieves safe removal/disposal of hazardous materials.
- .2 Demolition: rapid destruction of structure with or without prior removal of hazardous materials.
- .3 Hazardous Materials: dangerous substances, dangerous goods, hazardous commodities and hazardous products, including but not limited to: asbestos-containing materials, corrosive agents, flammable substances, ammunition, explosives, radioactive substances, or other material that can endanger human health, well-being or environment if handled improperly.
- .4 Hazardous Waste: hazardous material no longer used for its original purpose and that is intended for recycling, treatment or disposal.
- .5 Inert Fill: inert waste - exclusively asphalt and concrete.
- .6 Recycle: process by which waste and recyclable materials are transformed or collected for purpose of being transferred into new products.

1.3 REFERENCE
STANDARDS

- .1 Canadian Standards Association (CSA International):
 - .1 CSA S350-R2003, Code of Practice for Safety in Demolition of Structures.
- .2 Federal Legislation:
 - .1 Canadian Environmental Assessment Act (CEAA), 1995, c. 37.
 - .2 Canadian Environmental Protection Act (CEPA), 1999, c. 33.
 - .3 Transportation of Dangerous Goods Act (TDGA), 1992, c. 34.
- .3 National Building Code 2010, Part 8 - Safety Measures at Construction and Demolition Sites.

- 1.4 DOCUMENTS .1 Maintain at job site, one copy of following documents:
- .1 Site Specific Health and Safety Plan
 - .2 Environmental Protection Plan
 - .3 Materials removal log.
- 1.5 SUBMITTALS .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- 1.6 STORAGE, HANDLING AND PROTECTION .1 Unless specified otherwise, materials for removal become Contractor's property.
- .2 Prevent contamination of materials to be recycled and handle material in accordance with requirements for acceptance by designated facilities.
- 1.7 DISPOSAL OF WASTES .1 Do not bury rubbish or waste materials.
- .2 Do not dispose of waste, volatile materials, mineral spirits, oil into waterways, storm, or sanitary sewers.
- .3 Remove materials from deconstruction as deconstruction/disassembly Work progresses.
- 1.8 DELIVERY, STORAGE AND HANDLING .1 Transport hazardous materials and wastes, in accordance with Transportation of Dangerous Goods Act, Transportation of Dangerous Goods Regulations, and applicable provincial regulations.
- .1 Comply with applicable federal, provincial and municipal laws and regulations for generators of hazardous waste.
 - .2 Use licensed carrier authorized by provincial authorities to accept subject material.
 - .3 Before shipping material obtain written notice from intended hazardous waste treatment or disposal facility it will accept material and it is licensed to accept this material. Provide photocopy of notice to the Departmental Representative.
 - .4 Label container(s) with legible, visible safety marks as

- .5 prescribed by federal and provincial regulations.
- .5 Only trained personnel handle, offer for transport, or transport dangerous goods.
- .6 Provide photocopy of shipping documents and waste manifests to the Departmental Representative.
- .7 Track receipt of completed manifest from consignee after shipping dangerous goods. Provide photocopy of completed manifest to Departmental Representative.

1.9 USE OF SITE AND FACILITIES .1 Execute work with least possible interference or disturbance to normal use of premises.

1.10 SCHEDULING .1 Co-ordinate Work with other activities at site to ensure timely and orderly progress of Work.

PART 2 - PRODUCTS

2.1 MATERIALS .1 Not used.

PART 3 - EXECUTION

3.1 APPLICATION .1 Complete removal of all hazardous materials prior to undertaking deconstruction/demolition activities.

3.2 REMOVAL OF HAZARDOUS MATERIALS .1 Remove contents of the above ground diesel tank and associated lines in accordance with authority having jurisdiction.
.2 Remove and dispose of lead/lithium batteries, through a licensed recycling facility.

3.3 DEMOLITION AND
DECONSTRUCTION

- .1 On-site sale of salvaged, reusable, recyclable, materials is not permitted.
- .2 Ensure workers and subcontractors are trained to carry out work in accordance with appropriate deconstruction techniques.
- .3 Based on previous investigations, hydrocarbon contamination at the project site is not anticipated. Stop work and contact Departmental Representative immediately if there is evidence of hydrocarbon contamination.

3.4 CLEANING

- .1 Remove tools and waste materials on completion of Work, and leave work area in clean and orderly condition.
- .2 Clean-up work area as work progresses.

END OF SECTION

- 1.1 SECTION INCLUDES .1 Administrative procedures preceding inspection and acceptance of Work by Departmental Representative or consultant.
- 1.2 RELATED SECTIONS .1 Section: 01 78 00 - Closeout Submittals.
- 1.3 INSPECTION AND DECLARATION .1 Contractor's Inspection: Coordinate and perform, in concert with subcontractors, an inspection and check of all Work. Identify and correct deficiencies, defects, repairs and perform outstanding items as required to complete work in conformance with Contract Documents.
- .1 Notify Departmental Representative in writing when deficiencies from Contractor's inspection have been rectified and that Work is deemed to be complete and ready for Departmental Representative's inspection of the completed work.
- .1 Submit color photographs of work; field drawings that supplies sufficient tie points to locate footprint of backfilled foundation; along with this written notification to the Departmental Representative.
- .2 Departmental Representative's Inspection: Accompany Departmental Representative during all substantial and final inspections of the Work.
- .1 Address defects, faults and outstanding items of work identified by such inspections.
- .2 Advise Departmental Representative when all deficiencies identified have been rectified. Submit color photographs of rectified work along with this written notification.
- .3 Note that Departmental Representative will not issue a Certificate of Substantial Performance of the work until such time that Contractor performs following work and turns over the specified documents:
- .1 Project record as-built field sketch showing location of capped foundation of former building
- .2 Compliance certificates from applicable authorities;
- .3 Reports resulting from designated tests;
- .4 Color photographs depicting all aspects of work completed.
- .5 Material Removal Log, and Waste Manifests.
- .4 Correct all discrepancies before Departmental Representative will issue the Certificate of Completion.

END OF SECTION

1.1 SECTION
INCLUDES

- .1 Project Record Documents.
- .2 Operations and Maintenance data.

1.2 PROJECT RECORD
DOCUMENTS

- .1 Departmental Representative will provide 2 white print sets of contract drawings and 2 copies of Specifications Manual specifically for "As-Built" purposes.
- .2 Maintain at site one set of the contract drawings and specifications to record actual As-Built site conditions.
- .3 Maintain up-to-date, real time as-built drawings and specifications in good condition and make available for inspection by the Departmental Representative upon request.
- .4 As-Built Drawings:
 - .1 Record changes in red ink on the prints. Mark only on one set of prints and at completion of work, neatly transfer notations to second set (also by use of red ink).
 - .2 Submit both sets to Departmental Representative prior to application for Certificate of Substantial Performance.
 - .3 Stamp all drawings with "As-Built". Label and place Contractor's signature and date.
 - .4 Show all modifications, substitutions and deviations from what is shown on the contract drawings.
 - .5 Record following information:
 - .1 Horizontal and vertical location of various elements in relation to Geodetic Datum;
 - .2 Location of internal utilities and appurtenances concealed in construction, referenced to visible and accessible features of structure;
 - .3 Field changes of dimension and detail;
 - .4 Location of all capped or terminated services and utilities.
 - .5 Chases for mechanical, electrical and other services;
 - .6 Plumbing, heating, air conditioning and ventilation, sprinkler and electrical service installation locations; all to be dimensioned and referenced to building columns or load bearing walls;
 - .7 Any details produced in the course of the contract by the Departmental Representative to supplement or to change existing design drawings;
 - .8 All change orders issued over the course of the contract must be documented on the finished As-Built

documents, accurately and consistently depicting the changed condition as it applies to all affected drawing details.

- .5 As-Built Specifications: legibly mark in red each item to record actual construction, including:
 - .1 Changes made by Addenda and Change Orders.
 - .2 Mark up both copies of specifications; stamp "As-Built", sign and date similarly to drawings as per above clause.
- .6 Maintain As-Built documents current as the contract progresses. Departmental Representative will conduct reviews and inspections of the documents on a regular basis. Failure to maintain As-Built documents current and complete to satisfaction of the Departmental Representative shall be subject to financial penalties in the form of progress payment reductions and holdback assessments.
- .7 Submit on paper and in electronic format as pdf files. Forward pdf files on USB compatible with PWGSC encryption requirements or through email or alternate electronic file sharing service such as ftp, as directed by Departmental Representative.

1.3 REVIEWED
SHOP DRAWINGS

- .1 Provide a complete set of all shop drawings reviewed for project to incorporate into each copy of the Operations and Maintenance Manuals.
- .2 Submit full sets at same time and as part of the contents of the Operation and Maintenance Manuals specified.

1.4 OPERATIONS &
MAINTENANCE MANUAL

- .1 O&M Manual - Definition: an organized compilation of operating and maintenance data including detailed technical information, documents and records describing operation and maintenance of individual products or systems as specified in individual sections of the specifications.
- .2 Manual Language: final manuals to be in English languages.
 - .1 Upon review and acceptance by Departmental Representative, submit 3 final copies. Interim copies are not to be considered as part of the final copies unless they have been fully revised and are identical to the final approved version.
- .3 Submission Date: submit complete operation and maintenance manual

to Departmental Representative 3 weeks prior to application for Certificate of Substantial Performance of the work.

- .4 Binding:
 - .1 Assemble, coordinate, bind and index required data into Operation and Maintenance Manual.
 - .2 Use vinyl, hard covered, 3 "D" ring binders, loose leaf, sized for 215 x 280 mm paper, with spine pocket.
 - .3 Where multiple binders are needed, correlate data into related consistent groupings.
 - .4 Identify contents of each binder on spine.
 - .5 Organize and divide data following same numerical system as the section numbers of the Specification Manual.
 - .6 Dividers: separate each section by use of cardboard dividers and labels. Provide tabbed fly leaf for each individual product and system and give description of product or component.
 - .7 Type lists and notes. Do not hand write.
 - .8 Drawings, diagrams and manufacturers' literature must be legible. Provide with reinforced, punched binder tab. Bind in with text; fold larger drawings to size of text pages.

- .5 Manual Contents:
 - .1 Cover sheet containing:
 - .1 Date submitted.
 - .2 Project title, location and project number.
 - .3 Names and addresses of Contractor, and all Sub-Contractors.
 - .2 Table of Contents: provide full table of contents in each binder(s), clearly indicate which contents are in each binder.
 - .3 List of maintenance materials.
 - .4 List of spare parts.
 - .5 List of special tools.
 - .6 Original or certified copy of warranties and product guarantees.
 - .7 Copy of approval documents and certificates issued by Inspection Authorities.
 - .8 Copy of reports and test results performed by Contractor as specified.
 - .9 Product Information (PI Data) on materials, equipment and systems as specified in various sections of the specifications. Data to include:
 - .1 List of equipment including manufacturer's name, supplier, local source of supplies and service depot(s). Provide full addresses and telephone numbers.
 - .2 Nameplate information including equipment number, make, size, capacity, model number and serial number.
 - .3 Parts list.
 - .4 Installation details.

- .5 Operating instructions.
 - .6 Maintenance instructions for equipment.
 - .7 Maintenance instructions for finishes.
- .6 Shop drawings:
- .1 Include complete set of reviewed shop drawings into each copy of the operations and maintenance manual.
 - .2 Fold and bind material professionally in a manner that corresponds with the specification section numbering system.
 - .3 When large quantity of data is submitted, place into separate binders of same size as O&M binders.
- .7 Equipment and Systems Data: the following list indicates the type of data and extent of information required to be included for each item of equipment and for each system:
- .1 Description of unit or system, and component parts. Give function, normal operation characteristics, and limiting conditions. Include performance curves, with engineering data and tests, and complete nomenclature and commercial number of replaceable parts.
 - .2 Panel board circuit directories: provide electrical service characteristics, controls, and communications.
 - .3 Include installed colour coded wiring diagrams.
 - .4 Operating Procedures: include start-up, break-in, and routine normal operating instructions and sequences. Include regulation, control, stopping, shut-down, and emergency instructions. Include summer, winter, and any special operating instructions.
 - .5 Maintenance Requirements: include routine procedures and guide for trouble-shooting; disassembly, repair, and reassembly instructions; and alignment, adjusting, balancing, and checking instructions.
 - .6 Servicing and lubrication schedule, and list of lubricants required.
 - .7 Manufacturer's printed operation and maintenance instructions.
 - .8 Sequence of operation by controls manufacturer.
 - .9 Provide original manufacturer's parts list, illustrations, assembly drawings, and diagrams required for maintenance.
 - .10 Provide installed control diagrams by controls manufacturer.
 - .11 Provide Contractor's coordination drawings, with installed colour coded piping diagrams.
 - .12 Provide list of original manufacturer's spare parts, current prices, and recommended quantities to be maintained in storage.
 - .13 Include test and balancing reports.
 - .14 Additional requirements as specified in individual specification sections.

- .8 Materials and Finishes Maintenance Data:
 - .1 Instructions for cleaning agents and methods, precautions against detrimental agents and methods, and recommended schedule for cleaning and maintenance.
 - .2 Additional Requirements: as specified in individual specifications sections.

- 1.5 SPARE PARTS,
TOOLS AND
MAINTENANCE
MATERIALS
 - .1 Provide spare parts, special tools and extra materials for maintenance purposes in quantities specified in individual specification sections.
 - .2 Tag all items with associated function or equipment.
 - .3 Provide items of same manufacture and quality as items in Work.
 - .4 Deliver to site in well packaged condition. Store in location as directed by Departmental Representative.
 - .5 Clearly mark as to contents indicating:
 - .1 Part number.
 - .2 Identification of equipment or system for which parts are applicable.
 - .3 Installation instructions or intended use as applicable.
 - .4 Name, address and telephone number of nearest supplier.
 - .6 Prepare and submit complete inventory list of items supplied. Include list within Maintenance Manual.

END OF SECTION

1.1 RELATED
SECTIONS

- .1 Operations and Maintenance Manual: Section 01 78 00.

1.2 DESCRIPTION

- .1 Demonstrate scheduled operation and maintenance of equipment and systems to Owner's personnel prior to date of final inspection.
- .2 Departmental Representative will provide a list of Owner's personnel to receive instructions,
- .3 Cooperate with Departmental Representative in coordinating time and attendance of Owner's personnel with manufacturer's training Representative(s).

1.3 QUALITY CONTROL

- .1 Ensure that only personnel from own forces, Subcontractors or Suppliers competent and fully knowledgeable in the particular material component, equipment or system installation are used to provide training and demonstrations.
- .2 When specified in individual Sections, obtain the manufacturers authorized Representative to demonstrate operation of equipment and systems, instruct Owner's personnel, and provide written report that demonstration and instructions have been completed.
- .3 Upon request, provide evidence to Departmental Representative of individual trainer's knowledge and qualifications.

1.4 SUBMITTALS

- .1 Submit schedule of time, date and complete list of equipment and systems for which demonstration and training sessions will be provided. Submit schedule a minimum of 2 weeks prior to designated dates, for Departmental Representative's approval.
- .2 Submit report within 1 week after completion of demonstration, that demonstration and instructions have been satisfactorily completed. Provide time and date of when each demonstration was actually given, with list of persons present.

- 1.5 CONDITIONS FOR DEMONSTRATIONS
- .1 Prior to carrying out demonstration and training, ensure that equipment has been inspected and tested, is fully operational, has been performance verified and TAB has been carried out.
 - .2 Provide copies of completed operation and maintenance manuals for use in demonstrations and instructions.
- 1.6 PREPARATION
- .1 Verify that conditions for demonstration and instructions comply with requirements.
 - .2 Verify that designated personnel are present.
- 1.7 DEMONSTRATION AND INSTRUCTIONS
- .1 Include the following items within the demonstration and training:
 - .1 Demonstrate start-up, operation, control, adjustment, trouble-shooting, servicing, and maintenance of each of equipment.
 - .2 Instruct personnel in all phases of operation and maintenance using operation and maintenance manuals as the basis of instruction.
 - .3 Review contents of manual in detail to explain all aspects of operation and maintenance.
 - .4 Prepare and insert additional data in operations and maintenance manuals when the need for additional data becomes apparent during instructions.
 - .5 Provide other specific training and instructions as specified in trade sections.
- 1.8 TIME ALLOCATED FOR INSTRUCTIONS
- .1 Observe the allocated time period specified in trade sections. Provide additional time when required to ensure all personnel fully understand all aspects of the information and instructions being provided. Allow for questions by participants.

END OF SECTION

1.1 SECTION
INCLUDES

- .1 This section deals with commissioning activities to occur during the construction stage and the early period of facility occupancy stage.
- .2 Section includes:
 - .1 Commissioning activities to be performed by the Contractor who is assigned membership on a Commissioning Team as part of the contract requirements.
 - .2 Commissioning activities to be performed by other members of the Commissioning Team.
- .3 In general, Contractor's commissioning activities consists of performing specified tasks and functions to assist the Commissioning Agent, along with other members of the commissioning team who will commission various components and systems of the Facility.

1.2 RELATED
SECTIONS

- .1 Operations and Maintenance Manuals: Section 01 78 00.
- .2 Demonstration and Training: Section 01 79 00.

1.3 BACKGROUND
INFORMATION

- .1 Historically in the past, the term commissioning has been used in reference to the process used to conduct testing, adjusting and balancing of the heating, ventilation and air conditioning (HVAC) systems of a building.
- .2 Commissioning (or the commissioning process), as understood by PWGSC, is a planned program of activities conducted in concert with other activities performed during each stage of project delivery.
 - .1 The commissioning process identifies issues during the Planning and Design stages which are addressed during the Construction and Occupancy Stages of a Facility to ensure that the built facility is constructed and proven to operate satisfactorily under all weather, environmental and occupancy conditions to meet operational and user requirements.
 - .2 Commissioning activities during the Construction stage incorporates a third-party verification process and a transfer of critical operational knowledge to Facility personnel.

1.4 COMMISSIONING
OBJECTIVES

- .1 A Commissioning Plan has been prepared by the Design Consultant, on behalf of PWGSC, which identifies, among other issues, specific

commissioning activities to be carried out by the commissioning team during the Construction and Occupancy Stages of the project.

- .2 The commissioning activities have the following objectives:
 - .1 Collect data on equipment and systems being supplied and document their installation;
 - .2 Conduct checks and tests on fully installed building components, equipment, systems and integrated systems to:
 - .1 Verify whether they operate in accordance with requirements of Contract Documents;
 - .2 Verify performance against design criteria and user requirements and measure peak capacities;
 - .3 Prepare a Building Management Manual (BMM) which contains operations and maintenance data, as-built record documents, commissioning reports, training data and other critical information for future use by Facility operational staff;
 - .4 Ensure transfer of knowledge on the operations, maintenance and management of the Facility to Tenant and Operational personnel by means of appropriate training.
- .3 Work to achieve the above objectives requires a collaborative effort from all members of the commissioning team.
 - .1 Contractor's commissioning activities and responsibilities are described in Clause 1.8 below.
- .4 Commissioning activities performed by the Commissioning Agent and the Design Consultant does not replace checks, tests, adjustments, balancing and other performance verification procedures to be carried out by the Contractor as an integral part of performing the Work of this contract as specified in other sections of the Specifications.

1.5 SYSTEMS TO BE
COMMISSIONED

- .1 The following systems and controls, complete with associated equipment and components, will be commissioned by the Commissioning Agent and requires related commissioning activities to be performed by Contractor as specified herein:
 - .1 New electric fire pump.
 - .2 New dual fire pump controller.
 - .3 End-state fire protection system affected as part of this Work.

1.6 DEFINITIONS

- .1 For the purpose of this contract, the various terms listed below, as they relate directly or indirectly to the commissioning process, shall be deemed to have the following meaning.

- .2 Commissioning Process: a planned program of tasks, activities and procedures carried out systematically during the Construction and Occupancy Stages in accordance with the commissioning objectives, specified in clause 1.4.2 above, to:
 - .1 Verify whether the fully installed equipment, systems and integrated systems operate in accordance with contract documents and design criteria and;
 - .2 Ensure that appropriate documentation is compiled to effectively train O& M staff and prepare a comprehensive Building Management Manual (BMM).
- .3 Commission (ie: to commission a building component or system): tests and checks conducted by Commissioning Agent on all systems and integrated systems of Facility; carried out only after they are fully installed, functional and Contractor's Performance Verification responsibilities have been completed and approved.
 - .1 Contractor provides assistance during this process by operating equipment and systems, by troubleshooting and making adjustments as may be required.
 - .2 Systems are run under their full operation and under various modes to determine if they function correctly, consistently, at peak efficiency and interactively with each other as intended in accordance with Contract Documents and design criteria.
 - .3 During these checks, adjustments may be made enhancing performance to meet environmental or user requirements.
- .4 Commissioning Agent: a specifically appointed person, representing the Departmental Representative, responsible for the development of a Commissioning Plan and managing its implementation by overseeing and coordinating various activities and responsibilities to be performed by members of the Commissioning Team.
 - .1 Commissioning Agent plays a lead role in support to the Departmental Representative to ensure that the commissioning objectives are achieved.
- .5 Commissioning Manager: a PWGSC departmental employee providing advice and guidance on commissioning requirements to the Commissioning Agent in support to the Departmental Representative.
- .6 Commissioning Plan: the document which describes the organization, scheduling, allocation of resources, required documentation, target dates, and team roles and responsibilities for verification that the built works meet Contract Document and design criteria requirements.
- .7 Contractor: means the General Contractor, however it also refers to any personnel from subcontractors, including the controls and TAB specialists, suppliers and manufacturer's technical persons which Contractor employs to carry out his/her designated commissioning duties and activities.

- .8 Design Consultant: persons from the civil, architectural, mechanical and electrical design disciplines of the engineering firm(s) which have been engaged by the Departmental Representative to prepare the final design and produce the contract documents. Design Consultant also has specifically identified commissioning activities for this project.
- .9 Design Criteria: All those factors included in the design of a Facility prescribed by the tenant needs or as determined by Designer as necessary in order to meet all Facility functional and user operational requirements
- .10 Installation/Start-up Checks: (sometimes referred to as pre-functional checks) A written compilation of checks and inspections to be performed by Contractor during the pre-start-up and start-up of a particular equipment or system component.
 - .1 Checklist sheets are produced which include the following data:
 - .1 Product manufacturer's installation instructions and recommended checks and;
 - .2 Special procedures as specified in relevant sections of Specifications;
 - .3 Other items considered good installation and engineering industry practices deemed appropriate for proper and efficient operation.
 - .2 Standard Installation/Start-Up Checklist sheets prepared by equipment manufacturer are acceptable for use. However, supplement with additional data representative of specific project conditions as deemed required by Commissioning Agent.
 - .3 Use Checklist sheets for all equipment installation. Document in writing on checklist the various checks made, deficiencies noted and corrective action taken.
 - .4 Installer to sign Checklist sheets upon completion, certifying that stated checks and inspections have been performed.
 - .5 Use of Installation/Start-Up Checklists shall not be considered part of the commissioning process but shall be stringently used for all equipment pre-start and start-up procedures.
 - .6 Return completed Installation/Start-Up Checklist sheets after use to Commissioning Agent for retention. Checklists are required by Commissioning Agent when Facility is commissioned and will be included in the BMM manual at completion of project.
- .11 Performance Verification: (sometimes referred to Functional Testing) checks, running dynamic tests and adjustments carried out by Contractor on equipment and systems, upon their installation, to ensure they operate correctly, efficiently and function independently and interactively with other systems as intended in accordance with

contract documents and manufacturer's recommendations.

- .1 Performance Verification shall not be considered part of the commissioning process. It is however considered an essential and integral part of Contractor's responsibilities in the equipment installation process which must be stringently conducted, successfully completed and approved by Departmental Representative before a piece of equipment or system is considered fully installed and functional.
- .2 Facility components and systems will not be commissioned by Commissioning Agent until performance verification has been completed and approved.
- .12 Performance Verification Report Sheets (PV sheets): forms developed by Commissioning Agent for Contractor's use to record measured data and readings taken during functional testing and Performance Verification procedures.
- .13 Product Information (PI Data): a compilation of data gathered on a particular piece of equipment, typically produced by manufacturer, which includes nameplate information, installation/startup instructions, parts list, operating instructions, maintenance guidelines and other pertinent technical data and recommended checks that is necessary to prepare for start-up and functional testing and used during operation and maintenance of such equipment. This documentation is included in the Building Management Manual (BMM) at completion of work.

1.7 COMMISSIONING TEAM

- .1 A commissioning team will be assembled to carryout various functions needed to effectively commission the Facility. Contractor shall be part of this team with duties and responsibilities as specified in this section and in other sections of the Specifications.
- .2 Members of the Commissioning Team are as follows:
 - .1 Commissioning Agent.
 - .2 Design Consultant.
 - .3 Contractor.
 - .4 Departmental Representative.
 - .5 PWGSC Commissioning Manager.
 - .6 PWGSC departmental personnel providing advice and project quality control to Departmental representative when required.
 - .7 Facility's operation and maintenance personnel staff as identified by Departmental Representative.
- .3 Effective commissioning requires coordination between members of the commissioning team. Cooperate with other team members in fulfilling assigned duties and as follows:

- .1 Communicate commissioning objectives, to subcontractors, suppliers and manufacturers.
- .2 Coordinate activities between subcontractors and trades as needed to carryout Contractor's assigned commissioning activities.
- .3 Ensure attendance of subcontractors and required specialist at commissioning meetings and during the commissioning process.

1.8 CONTRACTOR'S
COMMISSIONING
ACTIVITIES

- .1 General:
 - .1 Organize and arrange for the services of subcontractors, their specialists and manufacturer's technical representatives to perform Contractor's commissioning activities.
 - .2 Ensure that personnel forming part of the Commissioning Team are qualified and knowledgeable of installed equipment and systems and with design intent.
 - .3 Develop in conjunction with the Commissioning Agent a commissioning schedule as specified in clause 1.11.
 - .4 Notify Departmental Representative in writing when Facility is ready for be commissioned. Give 14 calendar day notice.
 - .5 Commissioning will only commence once that full documentation has been received and installed equipment and systems have undergone successful performance verification.
 - .6 Note that Certificate of Substantial Performance will only be issued when:
 - .1 All commissioning documentation has been received and found suitable by Departmental Representative;
 - .2 Designated equipment and systems have been commissioned and;
 - .3 Training has been completed.
- .7 Performance faults:
 - .1 Equipment and systems found not operating correctly or not performing as intended during commissioning shall be re-verified by checking 100% of all equipment and components of the non-functional system, including related controls as required to rectify the deficiencies and ensure correct performance.
 - .2 Costs to conduct additional tests and inspections, as deemed required by Departmental Representative, to determine acceptability and proper performance of

such item to be paid for by Contractor.

- .2 Prior to Facility being Commissioned:
 - .1 Submit commissioning documentation as specified in clause 1.13 below.
 - .2 Submit the Installation/Start-Up Checklist sheets to Commissioning Agent for review prior to conducting the pre-start and start-up of any piece of equipment. Incorporate additional start-up instructions onto checklist as determined by the Commissioning Agent's review.
 - .3 Conduct the pre-start and start-up of all equipment by following and filling out the approved Installation/Start-Up Checklists.
 - .4 Conduct Performance Verification on all installed equipment and systems. Use and fill out the PV Report Sheets provided.
 - .5 Upon completion of start-up and performance verification process, submit signed copy of Checklist and PV sheets to Commissioning Agent as affidavit that required checks and tests were successfully conducted.
 - .6 Record performance measurements and data reading on PV sheets and return to Commissioning Agent for compilation.
 - .7 Give Departmental Representative and Commissioning Agent a minimum of 5 days' notice for start-up and performance verification of equipment and systems which must be witnessed by Commissioning Agent as determined by Commissioning Agent beforehand on PV sheets.
 - .8 Provide missing information and data as identified by Commissioning Agent and Departmental Representative during documentation review.
 - .9 Submit above noted documentation before Commissioning will proceed.
 - .10 Address deficiencies in Work identified during performance verification of equipment and systems. Conduct additional performance verification thereafter.
 - .11 Arrange for special tools and devices, identified at commissioning meeting(s), as deemed required to assist with commissioning.
 - .12 Provide access ladders, two way radios and other equipment required by Team when facility will be commissioned.
- .3 When Facility is being Commissioned:
 - .1 Assist in commissioning mechanical and electrical systems specified and as follows:
 - .1 Operate designated building component, mechanical/electrical equipment and system under all modes of operation and conduct checks and tests as directed by Commissioning Agent.
 - .2 Check and verify that building component, equipment, systems and integrated systems, including their

- controls, are functioning and responding correctly and interactively with each other.
- .3 Test systems independently and then in unison with other related systems.
- .4 Conduct all Commissioning checks and tests in presence of and witnessed by Commissioning Agent and Departmental Representative.
- .5 Assist Design Consultant and other members of the commissioning team who will also be present to commission Facility.
- .2 Specific procedures used to commission Facility will be provided by Commissioning Agent which includes:
 - .1 Sequential order of building component and system to be tested.
 - .2 Running systems under various anticipated modes and demands (example: high and low cooling or heating loads, duplicating outside temperature conditions, fire alarm and power failure conditions etc.).
 - .3 Running building controls through all sequences of operation to verify and confirm that equipment and systems are responding as designed and intended.
 - .4 Operating designated equipment at peak capacities, recording output data against design criteria.
- .3 Run component or systems as long as necessary to effectively commission all items as deemed required by Commissioning Agent and Departmental Representative.
- .4 Monitor equipment and system responses.
- .5 Record test results, measurements and other data on commissioning forms provided by Commissioning Agent.
- .6 Assist in analyzing results. Identify system deficiencies and components not responding as intended.
- .7 Correct deficiencies and system non-conformance issues. Adjust, calibrate or fine tune system components as required. Debug system software as may be required.
- .8 Retest systems when directed to confirm compliance.
- .4 Upon completion of Facility Commissioning:
 - .1 Provide training to maintenance & operational personnel as specified in clause 1.12 below.
 - .2 Turn over any filled-in checks sheets or reports resulting from commissioning.

1.9 COMMISSIONING
ACTIVITIES OF
OTHER TEAM MEMBERS

- .1 Commissioning Agent:
 - .1 Represents the Departmental Representative during the commissioning process.
 - .2 Coordinates activities of the commissioning team members to

- ensure that commissioning activities are carried out properly and in a timely manner.
- .3 Prepares commissioning schedule in concert with Contractor.
 - .4 Chairs commissioning meetings.
 - .5 Works with Contractor, subcontractors, equipment suppliers, Design Consultant resources, PWGSC and Tenant Representatives to resolve technical problems which may arise during the process.
 - .6 Witnesses Contractor's pre-start, start-up and performance verification procedures for certain equipment and systems specified when deemed required due to their critical nature and function in the Facility.
 - .7 Verifies that Installation/Start-up Checklists and Performance Verification checks and tests are used and stringently followed by Contractor.
 - .8 Assists Contractor in coordination of training activities for facility staff.
 - .9 Submits final commissioning report to Departmental Representative.
- .2 Design Consultant:
- .1 Reviews Contractor's Installation/Start-up Checklists for completeness, incorporating supplement data not addressed on checklist. Provides to Contractor checklist for products which manufacturer does not provide installation and start-up instructions.
 - .2 Assists Commissioning Agent in witnessing pre-start, start-up and performance verification activities.
 - .3 Assists Commissioning Agent in reviewing and analyzing tests results.
 - .4 Participate in the training sessions provided by Contractor to tenant O&M staff by giving introductory information on design philosophy, design intent and systems designs,
 - .5 Assist in the resolution of issues relating to commissioning.
- .3 Tenant Representative:
- .1 Participates with other team members to ensure that systems as installed meet the operational and functional requirements.
 - .2 Periodically attends commissioning meetings as required.
 - .3 Attends final commissioning activities.
 - .4 Assists in resolving technical problems by providing additional details on operational requirements.
- .4 Facility Operations and Maintenance Staff:
- .1 Participates in the commissioning process to obtain early introduction to the facility systems and to provide early operator feedback.
 - .2 Prime interest is in the familiarization and training of appropriate maintenance staff.

- .3 Staff may attend certain critical equipment start-up and performance verification activities and provide comments and practical suggestions on issues which may arise during actual operation, maintenance and repair of the equipment and systems.
- .4 Attends commissioning meetings periodically, depending on issues being discussed.
- .5 Identifies the appropriate staff which must receive the O&M training.

1.10 COMMISSIONING
MEETINGS

- .1 General briefing on commissioning will be conducted at first project construction meeting at commencement of work.
 - .1 Issues discussed will include scope and extent of commissioning and clarify responsibilities of commissioning team members.
 - .2 All team members must attend, including subcontractors of equipment and systems to be commissioned.
- .2 Include commissioning as one agenda item at each construction meeting held and chaired by Contractor during construction. Give subject due consideration for each material and equipment supplied and for all matters of Work.
- .3 Whenever possible meetings will be held immediately following the construction meetings.
- .4 Meeting will be chaired by Contractor, who will record and distribute minutes.

1.11 COMMISSIONING
SCHEDULE

- .1 Address commissioning activities within the construction work schedule. Clearly identify allocated time period for commissioning and training activities.
- .2 Develop commissioning schedule in conjunction with Commissioning Agent. Indicate allocated time period and anticipated dates for:
 - .1 Submission of commissioning documentation, including O&M Manuals.
 - .2 Equipment and system start-up and performance verification, making them ready to be commissioned.
 - .3 Allocated period to commission designated building components and systems.
 - .4 Training period.
 - .5 Work during Warranty period.

- .4 Submit schedule to Departmental Representative for review.

1.12 TRAINING

- .2 Conduct formal demonstration and training sessions only after all identified systems have been commissioned by Commissioning Agent and Departmental Representative has given approval to proceed with the training process.
- .4 Carryout training in accordance with requirements of Section 01 79 00.
- .5 Submit written agenda of training session(s) 4 weeks beforehand for review by Commissioning Agent and Departmental Representative.
- .6 Coordinate content with Commissioning Agent.
- .7 Submit training manuals for review 2 weeks prior to actual training.
- .8 Ensure required tools and O&M Manuals are on site for training and system demonstration.
- .9 As a minimum, the training sessions to cover the following information:
 - .1 Introduction.
 - .2 Description of the system with factory personnel being involved at appropriate times.
 - .3 Instructions on start-up procedures including seasonal procedures, system check-lists and emergency procedures.
 - .4 Operational procedures, including occupancy considerations, seasonal change-over, manual and automatic operations and emergency modes.
 - .5 Instruction on system shutdowns, including checklists.
 - .6 Instructions on all aspects of system maintenance, including routine servicing, lubrication, overhaul and factory servicing.
 - .7 Information concerning the scope of warranties and their use.
 - .8 A description of spare parts in stock and their service.
 - .9 A description of normal tools required for servicing the systems/equipment.
- .10 Submit typewritten record of training sessions given and list of attendees. Use forms of format approved by Departmental Representative.

1.13 COMMISSIONING
DOCUMENTATION

- .1 Submit the following documentation for use during commissioning and for incorporation thereafter into a Building Management Manual (BMM):
 - .1 Operations and Maintenance Manuals, Project Record Documents and other data as specified in Section 01 78 00. Data to include:
 - .1 Equipment Product Information (PI Data) complete with:
 - .1 Nameplate info.
 - .2 Installation instructions.
 - .3 Operating procedures and
 - .4 Maintenance guidelines.
 - .2 Reviewed shop drawings.
 - .3 As-built record drawings and Specifications.
 - .2 Completed Installation/Start-up Checklist sheets used.
 - .3 Performance Verifications checks and test procedures and completed report sheets used.
 - .4 Copy of any static and dynamic test and reports conducted.
 - .5 TAB report and other reports as specified in various trade sections.
- .2 Above documentation is required by Commissioning Agent to commission Facility. Submit data minimum 3 weeks before commencement of commissioning.
- .3 Documentation to include detailed information and number of copies as specified for maintenance manuals of Section 01 78 00.
- .4 Commissioning Agent will compile above documentation and produce a BMM manuals for operation/maintenance staff and tenant use.

END OF SECTION