

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions/Travaux  
publics et Services gouvernementaux Canada  
The Cambridge Building  
3 Queen Street/3, rue Queen  
Charlottetown  
Prince Edward Island  
C1A 4A2

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada  
The Cambridge Building  
3 Queen Street/3 rue, Queen  
PO Box 1268/CP 1268  
Charlottetown  
Prince Ed  
C1A 4A2

<b>Title - Sujet</b> Disposal Cell, Tignish, PEI	
<b>Solicitation No. - N° de l'invitation</b> ED001-151448/A	<b>Amendment No. - N° modif.</b> 003
<b>Client Reference No. - N° de référence du client</b> R.034760.002	<b>Date</b> 2014-12-04
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWC-010-3499	
<b>File No. - N° de dossier</b> PWC-4-37109 (010)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2014-12-09</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Atlantic Standard Time AST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> MacDonald, Anne (PWC) D.	<b>Buyer Id - Id de l'acheteur</b> pwc010
<b>Telephone No. - N° de téléphone</b> (902) 626-4949 ( )	<b>FAX No. - N° de FAX</b> (902) 566-7514
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Addendum # 3  
December 4, 2014

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY. THIS ADDENDA SHALL FORM PART OF THE CONTRACT DOCUMENTS.

**1. Extension**

Notice is hereby given that the time for the reception of tenders previously due December 5, 2014 is hereby extended to **14:00, December 9, 2014**

**1. Prolongation**

Veuillez prendre avis que la date limite de réception des soumission dû le 05 décembre est reportée à **14h00 le 09 décembre 2014.**

**Part A – Contract Terms**

1. Please change Contract Completion date from January 16, 2015 to January 20, 2015.

**Part B – Specifications**

**2. Section 01 00 10, Clause 14.03**

In the last sentence, remove and replace the words “unit prices” with the words “lump sum price”.

**3. Section 01 35 44, Pages 3 and 4**

Remove and replace pages 3 and 4 both titled ‘General Instructions’ with the posted pages 3 and 4 both titled ‘Environmental Protection Procedures for Marine Work’.

**4. Section 31 23 10, Clause 1.3**

Add the following Clauses:

- 1.3.2 The 20,000 m3 volume of material to be removed was computer generated based on the following:

1. the modeled surveyed existing elevations (indicated on the Drawing) ,
2. the finish 3:1 side slopes (indicated as cross hatching on the Drawing), and
3. a finish inside cell elevation of +1.0 m.

1.3.3 The finish elevations will be used in the same computer generated model to verify the following measurements for payment purposes:

1. 20,000 m3 of material removed,
2. 3:1 finish side slopes, and
3. an inside finish cell elevation of +1.0 m.

1.3.4 Variation to any of the three measurement criteria outlined in Clause 12.2.3 will need to be approved (in advance) by the Departmental Representative.

### **Part C – Drawings**

5. Drawing 1 of 1, Note s

#### **Add the following Notes:**

- .4 All elevations shown are existing.
- .5 The inside cell finish elevation is to be +1.0 m.

*end*