



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

**Parks Canada Agency**  
1300 - 635 8 Ave SW  
Calgary, AB T2P3M3  
Bid Fax: (403) 292-4475

**INVITATION TO TENDER**

**APPEL D'OFFRES**

**Tender To: Parks Canada Agency**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Soumission aux: l'Agence Parcs Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address  
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency**  
Suite 1300  
635 - 8 Ave SW  
Calgary, AB T2P3M3

<b>Title-Sujet</b> Illecillewaet #1 Bridge Rehabilitation Glacier National Park	
<b>Solicitation No. - No. de l'invitation</b> 5P420-14-5138/A	<b>Date:</b> November 26, 2014
<b>GETS Reference No. - No de reference de SEAG</b> PW-14-00659410	<b>Amendment No. - N° de la modif.</b> 002
<b>Solicitation Closes:</b>	
<b>at - á</b> 02:00 PM	<b>on - le</b> November 27, 2014
<b>Time Zone - Fuseau horaire</b> MST - HDR	
<b>F.O.B. - F.A.B.</b>	
<b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b> Nathaniel Pahl	
<b>Telephone No. - No de téléphone</b> (403) 292-4572	<b>Fax No. - No de FAX:</b> (403) 292-4475
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b> See Herein - Voir ici	

**TO BE COMPLETED BY THE BIDDER (type or print)**

<b>Vendor/Firm Name</b>	
<b>Address - Adresse</b>	
<b>Name of person authorized to sign on behalf of the Vendor/Firm</b> <b>Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Titale - Titre</b>	
<b>Telephone No. - N° de telephone:</b>	_____
<b>Facsimile No. - N° de télécopieur:</b>	_____
<b>Signature</b>	<b>Date</b>

## **Amendment 2**

This amendment is issued to a question from a bidder.

- Q1. I would like to clarify the thickness of the asphalt approaches. It says in the specs in section 01 11 00 that they are to tie into the new deck elevation but it does not specify the thickness of the approach in general.
- A1. Contractor to assume removal and replacement of 200mm of existing asphalt full width.

**All other terms and conditions remain unchanged.**