

Solicitation No. - N° de l'invitation
EW525-151402/A

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
pwz202

Client Ref. No. - N° de réf. du client
PWGSC-EW525-151402

File No. - N° du dossier
PWZ-4-37224

CCC No./N° CCC - FMS No/ N° VME

Public Works and
Government Services
Canada

Addendum No. 3
Page 1 of 1

Project No.: R.059705.001

December 18, 2014

The following changes to the tender documents are effective immediately and will form part of the contract documents:

CLARIFICATION:

Q.1: Do we have to supply and fill the diesel fuel and gasoline fuel for the 11,000L tanks – 2 ea. for first fill and commissioning or is it by the Owner? Please advise so we can price accordingly.

A.1: See article 1.3 in specification section 23 08 01. After 1.3.1 is done, a half tank of fuel is required to test the pumping.