



REFER TO 1/M302 FOR CONTINUATION

REFER TO 1/M302 FOR CONTINUATION




- DRAWING NOTES: DEMOLITION**
- REMOVE EXISTING CONDENSATE PUMPS (CP-5 & CP-6) AS INDICATED.
  - REMOVE EXISTING P.COND, HPS AND HPC C/W ASSOCIATED VALVES AND ACCESSORIES AS INDICATED. CAP PIPING BACK AT TUNNEL ENTRANCE.
  - REMOVE EXISTING STEAM METER ORIFICE PLATE ASSEMBLY AND ASSOCIATED DEVICES.

- DRAWING NOTES: NEW WORK**
- PROVIDE NEW CONDENSATE PUMP (CP-5 & CP-6) C/W ASSOCIATED 50#P.COND PIPING, CHECK VALVES AND ISOLATION VALVES AS INDICATED. REVISE EXISTING BASE MOUNTED PUMP CONCRETE UP STANDS TO SUPPORT NEW VERTICAL INLINE PUMPS.
  - PROVIDE NEW STEAM TRAP C/W ASSOCIATED PIPING AND ACCESSORIES AS INDICATED.
  - PROVIDE NEW 150#HPS PIPING FROM 601 BOOTH SERVICE AND CONNECT INTO EXISTING DISTRIBUTION AS INDICATED. GENERAL ROUTING INDICATED TO REFLECT PIPE INSTALLATION WITHIN AVAILABLE SPACE IN MECHANICAL ROOM. PROVIDE NEW STEAM TRAPS C/W DRIP LEGS, ASSOCIATED ACCESSORIES AND PIPING TO EXISTING CONDENSATE MAINS AT LOW POINTS AND AS INDICATED.



**KEY PLAN  
PLAN-REPÈRE**

revision	date
05	ISSUED FOR TENDER 2014/12/10
04	ISSUED FOR REVIEW 2014/10/09
03	ISSUED FOR 99% REVIEW 2014/07/14
02	ISSUED FOR 66% REVIEW 2014/05/30
01	ISSUED FOR 33% REVIEW 2014/02/28



project 555/601/615 BOOTH  
STAND ALONE  
HEATING PLANT

**615 BOOTH  
BASEMENT FLOOR  
MECHANICAL WORK**

designed	R.LEONARD	conçu
date	2014/01/22	
drawn	S.VALLIER	dessiné
date	2014/01/22	
revised	R.LEONARD	révisé
date	2014/01/22	
approved	R.LEONARD	approuvé
date	2014/01/22	
tender	C.CAMPBELL	soumission
PWC Project Manager	Administrateur de projets TPC	
project no.	R.060128.002	no. du projet
drawing no.	M301	no. du dessin